



Eskom Holdings SOC Limited

---

# ESKOM MINIMUM EMISSION STANDARDS EXEMPTION APPLICATION FOR LETHABO POWER STATION

December 2024





Eskom Holdings SOC Limited

---

# **ESKOM MINIMUM EMISSION STANDARDS EXEMPTION APPLICATION FOR LETHABO POWER STATION**

December 2024

**REPORT (DRAFT) PUBLIC**

**PROJECT NO. 41107109**

**OUR REF. NO. LETHABO POWER STATION**

**DATE: DECEMBER 2024**



Eskom Holdings SOC Limited

---

# **ESKOM MINIMUM EMISSION STANDARDS EXEMPTION APPLICATION FOR LETHABO POWER STATION**

December 2024



WSP

Building 1, Maxwell Office Park  
Magwa Crescent West, Waterfall City  
Midrand, 1685  
South Africa

Phone: +27 11 361 1300

[WSP.com](http://WSP.com)

# QUALITY CONTROL

Issue/revision	First issue	Revision 1
Remarks	Draft Lethabo Exemption Report	Final Report – Ministerial Submission
Date	November 2024	10 December 2024
Prepared by	Aiden Stoop Tshepho Mamashela Sihle Dambuza Keenan Seafield Amber Thompson Brian Magongoa Steve Horak David de Waal	B. Keiser
Checked by	Cândida Boavida Anri Scheepers Jared Lodder	A. Scheepers
Signature		 <p>Digitally signed by Scheepers, Anri (ZAAS02690) DN: cn=Scheepers, Anri (ZAAS02690), ou=Active, email=Anri.Scheepers@wsp.com Date: 2024.12.10 21:54:55 +02'00'</p>
Authorised by	Brad Keiser	B. Keiser
Signature		 <p>Bradley.Keiser@wsp.com 2024.12.10 22:12:46 +02'00'</p>
Project number	41107109	41107109
Report number	1 of 9	1 of 9
File reference	\\corp.pbwan.net\za\Central_Data\Projects\41100xxx\41107109 - ESKOM MES EXEMPTION APPLICATIONS\41 EPA	



# INDEX AND REPORT STRUCTURE

CHAPTER	SUB-SECTION	PAGE	CONTENT DESCRIPTION
<b>Executive Summary</b>	N/A	1 – 9	Provides overview of report contents, highlighting key findings, motivations, and exemptions requested.
<b>Ch. 1: Introduction</b>	N/A	10 – 13	Provides introduction to the exemption application report with an overview of the history leading to Eskom submitting this application.
<b>Ch. 2: Station Background</b>	N/A	13 – 16	Provides background to the station, such as generation capacity, location and description of surrounding environment.
<b>Ch. 3: Legal Overview</b>	All	17 – 24	Provides overview of the applicable regulations, ambient standards, Priority Area's, and climate change policy overview.
<b>Ch. 4: Just Energy Transition and Repurposing Plans</b>	All	25 – 29	Provides overview of South Africa's challenges, Eskom's Just Energy Strategy and Repowering and Repurposing plans.
<b>Ch. 5: Eskom Emission Reduction Plan</b>	5.1. Eskom Journey and Overview	29 – 32	Introduces Eskom's Emission Reduction Plans (ERPs), highlighting existing abatement equipment, key emission reduction projects, and timelines to achieve these, as well as discussing the Eskom's Despatch Prioritisation Initiative.
	5.2. Power Station	32 – 43	Describes the relevant power station's current emissions performance, planned emission reduction projects and timelines, the fleet-wide emission trajectory, costs to reach MES compliance, and the requested emission limits for the relevant power station.
	5.3. Eskom Air Quality Offsets	43 - 47	Presents Eskom's Air Quality Offset Programme.
	5.4. National Electricity Supply Issues	48	Discusses challenges facing South Africa's electricity sector, highlighting impacts associated with reduced Security of Supply.
<b>Ch. 6: Health &amp; Environmental Impacts Quality Impacts</b>	6.1. Air Quality Impacts	49 – 54	Presents ambient air quality monitoring data for the region and dispersion modelling predictions for the various scenarios assessed.
	6.2. Health Impacts	55 – 56	Highlights health impacts associated with power station emissions.
	6.3. Water	56 – 58	Highlights water supply considerations for abatement equipment being considered.
	6.4. Waste	58 – 59	Highlights waste considerations for abatement equipment being considered.
	6.5. Climate Change	59 – 61	Presents Eskom's anticipated carbon dioxide emissions trajectory and the impact on this from the SO <sub>2</sub> abatement technology being considered.
<b>Ch. 7: Financial Consequences</b>	7.1. Financial Costs	62 – 65	Presents the financial costs associated with each of the Eskom ERPs, as well as potential impacts on electricity tariffs.
	7.2. Health Benefit Cost Analysis	65 – 69	Presents the findings of the Health Cost Benefit Analysis undertaken for the applications.

CHAPTER	SUB-SECTION	PAGE	CONTENT DESCRIPTION
	7.3. Socio-Economic Impacts	69 – 72	Highlights socio-economic impacts.
<b>Ch. 8: Stakeholder Engagement</b>	All	72 – 75	Presents the stakeholder engagement process followed, including methods of notification and meeting dates and venues.
<b>Ch. 9: Assumptions and Limitations</b>	N/A	76	Presents the assumption and limitations applicable to the application.
<b>Appendix A</b>	N/A	N/A	Power station specific Atmospheric Impact Report
<b>Appendix B</b>	N/A	N/A	Cumulative airshed Atmospheric Impact Report
<b>Appendix C</b>	N/A	N/A	Cumulative stack only emissions dispersion modelling results
<b>Appendix D</b>	N/A	N/A	Airshed Health Cost Benefit Analysis

# ACRONYMS AND ABBREVIATIONS

Acronym/Abbreviation	Definition
AEL	Atmospheric Emissions Licence
AOA	Annual Operational Analyses
AP-HRA	Air pollution health risk assessments
APHR-BCA	Air Pollution Health Risk Benefit Cost Analysis
AQMP	Air Quality Management Plan
AQO	Air Quality Offsets
ARM	Air Resource Management
BAT	Best Available Technology
BCA	Benefit-cost analysis
BPFS	Biodiversity Plan Free State Province
BU	Business Units
CAPEX	Capital Expenditure
CRA	Concept Release Approval
CV	Calorific value
DEA	Department of Environmental Affairs
DFFE	Department of Forestry, Fisheries and the Environment
DHP	Dust Handling Plant
DSI	Dry Sorbent Injection
DWS	Department of Water and Sanitation
EAF	Energy Availability Factors
EIA	Environmental Impact Assessment
ERF	Exposure-response functions
ERI	Eskom Rotek Industries
ERP	Emission Reduction Plan
ESA	Ecological Support Area
EWE	Extreme Weather Events
FDDM	Fezile Dabi District Municipality
FEPA	Freshwater Ecosystem Priority Areas
FGD	Flue Gas Desulphurisation
GBV	Gender-Based Violence
GCD	Group Capital Department
GDP	Gross Domestic Product
GHG	Greenhouse Gases

Acronym/Abbreviation	Definition
GHGP	Greenhouse Gas Protocol
GVA	Gross Value Added
HFPS	High Frequency Power Supplies
I&AP	Interested and Affected Parties
IDP	Integrated Development Plan
IPCC	Intergovernmental Panel on Climate Change
IPPs	Independent Power Producers
IRP	Integrated Resource Plan
IVRSv	Integrated Vaal River System
LCOE	Levelised cost of electricity
JET	Just Energy Transition
LNB	Low NO <sub>x</sub> burner
LPG	Liquid Petroleum Gas
MES	Minimum Emission Standards
MLM	Metsimaholo Local Municipality
Mt	Megatonnes
NAAQS	National Ambient Air Quality Standards
NAQO	National Air Quality Officer
NCCAS	National Climate Change Adaptation Strategy
NCCRP	National Policies such as the Climate Change Response
NDC	Nationally Determined Contribution
NDP	National Development Plan
NECA	National Environmental Consultative and Advisory
NECOM	National Energy Crisis Committee of Ministers
NEMAQUA	National Environmental Management: Air Quality Act
NERSA	National Energy Regulator of South Africa
NGER	National Greenhouse Gas Emission Reporting
NO <sub>x</sub>	Nitrogen Oxides
NPV	Net Present Value
NWA	National Water Act (No. 36 of 1998)
OEMs	Original Equipment Manufacturers
OFA	Over-fire Air
OIP	Offset Intervention Plan
Opex	Operating Expenditure
PCD	Pollution Control Dam
PF	Pulverised fuel

Acronym/Abbreviation	Definition
PJFF	Pulse Jet Fabric Filter
PM	Particulate Matter
PMV	Planning, Monitoring and Verification
PPE	Personal Protective Equipment
PV	Photovoltaic
RR	Relative Risk
R&R	Repowering and Repurposing
ROI	Return on investment
SAPS	South African Police Service
SAWS	South African Weather Services
SCR	Selective Catalytic Reduction
SO <sub>2</sub>	Sulphur dioxide
SPF	Spray Polyurethane Foam
UNEP	United Nations Environment Programme
UNFCCC	United Nations Framework Convention on Climate Change
VOC	Volatile Organic Compounds
VRESS	Vaal River Eastern Sub-system
VSL	Value of a statistical life
VTAPA	Vaal Triangle Airshed Priority Area
WBCSD	World Business Council for Sustainable Development
WCWDM	Water Conservation and Water Demand Measures
WHO	World Health Organisation
WMO	World Meteorological Organisation
WRI	World Resources Institute
WTP	Willingness to Pay

# CONTENTS

---

<b>EXECUTIVE SUMMARY</b>	<b>1</b>
<b>1 INTRODUCTION</b>	<b>10</b>
<b>2 STATION BACKGROUND</b>	<b>13</b>
<b>3 LEGAL FRAMEWORK</b>	<b>17</b>
3.1 NATIONAL ENVIRONMENTAL MANAGEMENT: AIR QUALITY ACT	17
3.2 NATIONAL AMBIENT AIR QUALITY STANDARDS	19
3.3 REGULATION FOR IMPLEMENTING AND ENFORCING PRIORITY AIR QUALITY MANAGEMENT PLANS	19
3.4 POLICIES AND LEGISLATION REGARDING CLIMATE CHANGE	21
<b>4 JUST ENERGY TRANSITION AND REPURPOSING PLANS</b>	<b>25</b>
4.1 INTRODUCTION	25
4.2 JET STRATEGY AND ENERGY BROADER POLICY LANDSCAPE	25
<b>5 ESKOM EMISSION REDUCTION PLAN</b>	<b>29</b>
5.1 ESKOM JOURNEY AND OVERVIEW	29
5.2 LETHABO POWER STATION	32
5.3 ESKOM AIR QUALITY OFFSETS	43
5.4 NATIONAL ELECTRICITY SUPPLY ISSUES	48
<b>6 HEALTH &amp; ENVIRONMENTAL IMPACTS</b>	<b>49</b>
6.1 AIR QUALITY IMPACTS	49
6.2 HEALTH IMPACTS	55
6.3 WATER	56
6.4 WASTE	58
6.5 CLIMATE CHANGE	59

---

<b>7</b>	<b>FINANCIAL CONSEQUENCES</b>	<b>62</b>
7.1	FINANCIAL ANALYSIS	62
7.2	HEALTH BENEFIT COST ANALYSIS	65
7.3	SOCIO-ECONOMIC IMPACTS	69
<b>8</b>	<b>STAKEHOLDER ENGAGEMENT</b>	<b>72</b>
8.1	PUBLIC PARTICIPATION	72
<b>9</b>	<b>ASSUMPTIONS AND LIMITATIONS</b>	<b>76</b>
<b>10</b>	<b>REFERENCES</b>	<b>77</b>

## TABLES

Table 0-1 – Eskom Fleet ERP Summaries and Impacts	7
Table 0-2 - Emission limits requested for Lethabo	8
Table 3-1 - Minimum emission standards for Category 1: Combustion installations, sub 1.1: Solid fuel installations	18
Table 3-2 – Applicable climate change related policies, legislation, guidelines and standards - International	21
Table 3-3 - Applicable policies, legislation, guidelines and standards - National	22
Table 5-1 – Current installed abatement on the Eskom Fleet	29
Table 5-2 - Emission limits requested for Lethabo	42
Table 5-3 - Implemented Air Quality Offset Interventions	44
Table 5-4 - Potential improvement in ambient air quality due to Eskom's Sharpeville AQO Project (Air Resource Management (ARM), 2024)	46
Table 5-5 - Selected Areas and associated Air Quality Offset Interventions (Air Resource Management (ARM), 2024)	47
Table 6-1 - Predicted maximum annual and short-term ground level concentrations occurring at selected receptors and ambient monitoring stations for each operational scenario (uMoya-NILU, report uMN220-24, 2024)	54
Table 6-2 – Summary of water changes with a semi-dry FGD	57

Table 7-1 – Eskom Fleet ERP financial summary	65
Table 7-2 - BCA ratios (lower and upper ranges) for each scenario (discounted at Eskom WACC)	69
Table 8-1 - I&AP Identification	73
Table 8-2 - Public Availability of Exemption Report	74
Table 8-3 - Placement of Adverts	75
Table 8-4 - Date, venue and time of public meeting	75

---

## **FIGURES**

Figure 1-1 - Eskom's coal-fired Power Station distribution	11
Figure 2-1 - Locality map for Lethabo Power Station	14
Figure 2-2 - Land cover map	16
Figure 4-1 - The Energy Crisis Management, Generation and JET strategies are interdependent, but have different areas of focus (Eskom JET, 2023)	26
Figure 4-2 - Location and expected R&R for coal power stations with a focus on Mpumalanga	27
Figure 5-1 - Eskom's abatement equipment installation schedule	31
Figure 5-2 - Eskom Fleet sulphur dioxide emission trajectories	38
Figure 5-3 - Eskom Fleet oxides of nitrogen emission trajectories	39
Figure 5-4 - Eskom Fleet particulate matter trajectories	40
Figure 5-5 - Total net reduction in emissions attributable to Eskom's Phase 1 AQO project (tonnes) for Ezamokuhle and Kwazamokuhle (Air Resource Management, 2024)	45
Figure 6-1 - Highveld and Vaal Triangle ambient PM <sub>10</sub> concentrations, 2021 – 2023	50
Figure 6-2 - Highveld and Vaal Triangle ambient PM <sub>2.5</sub> concentrations, 2021 – 2023	50
Figure 6-3 - Highveld and Vaal Triangle ambient SO <sub>2</sub> concentrations, 2021 – 2023	51
Figure 6-4 - Highveld and Vaal Triangle ambient NO <sub>2</sub> concentrations, 2021 – 2023	51
Figure 6-5 – Eskom coal-fired fleet CO <sub>2</sub> emission trajectory and contribution from FGDs	61
Figure 7-1 – APHR-BCA Methodology	65



## ***APPENDICES***

APPENDIX A

POWER STATION SPECIFIC ATMOSPHERIC IMPACT REPORT

APPENDIX B

CUMULATIVE ATMOSPHERIC IMPACT REPORT

APPENDIX C

CUMULATIVE STACK ONLY EMISSIONS DISPERSION MODELLING

APPENDIX D

HEALTH COST BENEFIT ANALYSIS

## EXECUTIVE SUMMARY

---

Eskom Holdings SOC Ltd (Eskom) is South Africa's public electricity utility, supplying about 95% of the country's electricity with a generation capacity exceeding 35,000 MW. Around 90% of its power comes from coal-fired stations, primarily located in the Mpumalanga Highveld, with others in the Free State and Limpopo provinces.

Coal-fired power stations must comply with strict environmental regulations under the National Environmental Management: Air Quality Act (NEM:AQA). Eskom sought postponements and alternative limits to the Minimum Emission Standards (MES) for oxides of nitrogen (NO<sub>x</sub>), sulphur dioxide (SO<sub>2</sub>) and particulate matter (PM) between 2018 and 2020. These applications were necessary due to several factors, such as the restrictive legal framework, the advanced age of Eskom's power plant fleet, and the technical challenges of reducing emissions. The high costs of emission reduction technologies, which could significantly impact electricity tariffs and the financial stability of the utility, further underscored the need for a phased approach to compliance.

In October 2021, the Department of Forestry, Fisheries, and the Environment (DFFE) granted conditional postponements for some power stations (Grootvlei, Arnot, Komati, Camden, Hendrina, Acacia, and Port Rex Power Stations), provided partial refusals for others (Majuba, Tutuka, Kendal, and Kriel), and rejected the applications for Lethabo, Matla, Medupi, Matimba, and Duvha.

In December 2021 Eskom initiated an appeal process, engaging with the DFFE, and other governmental departments, on the basis that immediate compliance would lead to the shutdown of about 16,000 MW of coal-fired capacity. Eskom emphasised that this would negatively impact the national grid and delay South Africa's energy transition, that flu gas desulphurisation (FGD) retrofit on "six-pack" power stations was not proven to be technically feasible and would be a world first, and that if funding was available to execute the required compliance projects in time to meet the MES, this would result in an approximate increase of 10% on existing electricity tariffs (Eskom, 2020).

In May 2024, the Minister approved the MES suspensions for the power stations set to shut down by 31 March 2030 (Hendrina, Grootvlei, Arnot, Camden, and Kriel) and, under Section 59 of NEM:AQA, instructed Eskom to apply for MES exemptions for the remaining stations (Lethabo, Kendal, Tutuka, Matla, Duvha, Majuba, Matimba, and Medupi). The Minister would then assess each application based on its merits and supporting information.

This report details the exemption application for Lethabo Power Station, highlighting the specific environmental and operational challenges it faces. While the primary focus is on Lethabo, the report also addresses broader issues affecting the entire Eskom Fleet. This holistic approach is necessary as a particular station's circumstances cannot be considered in isolation of the entire Eskom Fleet as station performance, emissions impacts, and financial impacts need to be considered cumulatively. By considering the entire Eskom fleet, the report aims to provide a cohesive strategy for achieving compliance while addressing the unique challenges of each power station.

South Africa faces the complex challenge of ensuring energy security, affordability and access, and sustainability, compounded by high unemployment, inequality, unreliable power generation, and reliance on coal. Eskom's Just Energy Transition (JET) Strategy was developed to address these issues. As Eskom's coal plants near the end of their operational life, there is a risk of declining living standards and local community well-being if no action is taken. The JET Strategy aims to develop new

energy capacity while ensuring that power station communities benefit from the transition, thus linking the need for new energy sources with socio-economic improvements.

This dual focus forms the core of Eskom's ambition to achieve a just and equitable energy transition. This involves a gradual shift to renewable energy, aligning with South Africa's broader climate goals and global efforts to mitigate climate change. The development of a renewables-dominant power system aims to create jobs and stimulate economic growth, ensuring that communities reliant on coal power plants benefit from the transition. Eskom has identified repowering and repurposing projects as key components of the JET strategy to preserve jobs and utilize existing grid capacity. Prioritizing power stations in Mpumalanga, these projects will leverage existing infrastructure to build new generation capacity, including solar, wind, batteries, and synchronous condensers. Additionally, the plants will be repurposed into new economic centres with training centres, water treatment facilities, manufacturing plants, microgrid assemblies, and aquaponic farms. This approach aims to retain economic activity, create jobs, and generate new economic opportunities for local communities.

Eskom has already commenced with the largest repowering and repurposing project in emerging markets at Komati, expected to have a significant impact by 2030, comprising ~600 direct full-time jobs, ~370MW of renewable generation capacity, and vocational training. Although Lethabo is not currently part of Eskom's repowering and repurposing plans since its shutdown is post 2035, a similar approach will be taken to identify suitable projects and plans aligned with the JET strategy.

To address emission reductions in the Eskom Fleet, Eskom developed an Emission Reduction Plan (ERP) in 2015, with this being updated in 2019 (EERP 2019), 2020 and 2022. In May 2024, as part of the Minister's decision, Eskom were required to review the 2022 ERP, with this having been revised by Eskom in 2024.

Eskom currently has abatement technologies to mitigate PM at all power stations since this is historically the pollutant of most concern considering health impacts, and boilers with low NO<sub>x</sub> design at Medupi, Kendal, Kusile, and Camden, with SO<sub>2</sub> abatement technology in the form of flue-gas desulphurisation (FGD) installed at Kusile. Further, Eskom is currently taking steps to further reduce PM emissions at the stations, with several abatement equipment upgrades and refurbishments completed, and currently being undertaken, focusing on projects such as electrostatic precipitator (ESP) refurbishments, high frequency power supply (HFPS) installations, sulphur trioxide (SO<sub>3</sub>) plant upgrades, and Dust Handling Plant (DHP) upgrades. In addition to these projects, and ensuring Eskom's commitment to emission reductions, as part of the 2024 ERP, Eskom are also planning and/or evaluating the following to reduce emissions:

- Wet flue gas desulphurisation (FGD) at Medupi (included in previous ERPs)
- Kendal (semi-dry FGD) and Majuba (Duct Sorbent Injection (DSI FGD)) SO<sub>2</sub> reduction projects have been identified as potential alternatives, although are being evaluated as part of this process.
- Low NO<sub>x</sub> Burner (LNB) technology at Majuba, Tutuka and Lethabo to mitigate NO<sub>x</sub> emissions.
- Despatch Prioritisation Strategy at specific power stations, initiated to reduce SO<sub>2</sub> emissions, however also positively impacting PM and NO<sub>x</sub> emissions.
- Efficiency improvement projects under the Generation Recovery Programme to optimise the air-to-fuel ratio which should abate some SO<sub>2</sub> emissions and maximise combustion efficiency.
- The progressive shutdown of coal-fired stations will reduce overall Eskom Fleet emissions.
- Although not a method of reducing emissions at source (i.e. the power stations), the cumulative impact on neighbouring communities is reduced through the air quality offset (addressing emission

sources within the community) projects already implemented by Eskom, therefore Eskom are looking to expand this beyond the 35,000 households originally planned.

As noted above, Despatch Prioritisation is an ERP 2024 strategy for implementation to reduce emissions. With the integration of alternative energy sources into the national grid as per the Integrated Resource Plan (IRP), coal-fired power stations are expected to operate in a load-following mode, resulting in lower running load factors as renewable sources are prioritized. Despatch Prioritisation aims to reduce SO<sub>2</sub> emissions, especially in older stations, due to the high costs and complexities of installing SO<sub>2</sub> abatement equipment. The Generation Recovery Programme, initiated in March 2023, has improved fleet reliability, enabling better load management. Eskom plans to limit coal station loads to essential levels, using other energy sources to reduce coal consumption, and therefore emissions. However, this strategy depends on the addition of alternative generation sources to the grid. If these sources are delayed or economic growth increases demand, Eskom may need to operate stations at higher loads, potentially increasing emissions to maintain grid stability.

Key emissions of concern, and regulated by NEM:AQA, are PM, SO<sub>2</sub>, and NO<sub>x</sub>. The following discussions provide key highlights for each pollutant, considering details such as current performance, planned projects, Eskom Fleet emission reductions and trajectories, and Eskom's exemption request, where applicable. The Eskom Fleet emission reduction trajectories consider four scenario projections:

- ERP 2024 A (PM and NO<sub>x</sub> reduction, Despatch Prioritisation strategy, efficiency improvements, and SO<sub>2</sub> abatement at Medupi and Kusile), representing Eskom's planned projection.
- ERP 2024 B (As per ERP 2024 A plus SO<sub>2</sub> reduction technology installed at Majuba and Kendal), representing a projection, that with additional guarantees and strategic decisions, could be achieved.
- ERP 2024 C (As per ERP 2024 A and B, plus SO<sub>2</sub> reduction technology at Lethabo and Tutuka), representing a projection that would require substantial guarantees and considerations of the significant financial impacts, such as on electricity tariffs.
- Eskom's Security of Supply Projection developed using conservative assumptions such as higher electricity demands due to a growing economy, a delay in IPP projects, and a delay in Kusile U6 generating unit coming online.

## **PARTICULATE MATTER**

Presently ambient air quality monitoring shows PM to be non-compliant in the Highveld and Vaal Triangle, with this impacted by multiple sources, such as Eskom power stations, mining, industrial activities, uncontrolled waste burning, veld fires, and domestic fuel burning; importantly, the non-compliant ambient concentrations are not only due to Eskom emissions. Cumulatively the Eskom Fleet shows a significant reduction in PM stack emissions in the coming years due to the various abatement projects being implemented. Eskom's emission trajectories for the options of ERP 2024 A, ERP 2024 B, and ERP 2024 C, show identical trajectories as the same PM abatement projects are planned for each. By FY2030, these show a 65-kilo tonne (kt) reduction from FY2025, representing a 74% decrease, due to PM abatement projects implemented in the fleet and stations entering shutdown phase.

Despite the significant PM emission reduction, and although the dispersion modelling indicated compliant PM<sub>10</sub> annual average concentrations, non-compliant 24-hour PM<sub>10</sub> concentrations are predicted, as well as non-compliant annual and 24-hour average PM<sub>2.5</sub> concentrations; although, the conservative approach to the PM simulations providing an absolute worst-case scenario must be

considered. The predicted ambient PM concentrations are predominantly due to the low-level fugitive sources, rather than the stack emissions themselves; the benefit of the stack emissions reductions, as evident in the trajectories, is over-shadowed by the impacts associated with fugitive emissions. This conclusion is supported by the additional dispersion modelling undertaken to assess particulate matter emissions only from the stacks, which showed full compliance with the annual and 24-hour average PM<sub>10</sub> and PM<sub>2.5</sub> National Ambient Air Quality Standards (NAAQS), with no exceedances predicted, indicating ground-level impacts associated with stack emissions are well below the NAAQS.

While the abovementioned emission trajectories show significant improvements in the next few years, to offset Eskom PM emissions further, Eskom has introduced an air quality offset (AQO) program, a key component of Eskom's ERP. This program aims to offset PM emissions by implementing interventions that deliver net ambient air quality benefits within communities impacted by Eskom's stations, focusing on PM<sub>10</sub> and PM<sub>2.5</sub>. Key interventions include the distribution of hybrid stoves, ceilings, electrical rewiring, and LPG heaters to households, as well as cleanup campaigns to remove illegally dumped waste. The program has been implemented in phases, with Phase 1 targeting Kwazamokuhle, Ezamokuhle, and Sharpeville. Preliminary results show significant reductions in PM<sub>10</sub> and PM<sub>2.5</sub> concentrations and improvements in indoor air quality in participating households. Eskom plans to expand its AQO program to additional communities and explore new interventions, such as dust suppression on unpaved roads, and veld fire management.

Considering Lethabo, exceedances of the existing plant limit (100mg/Nm<sup>3</sup>) have occurred, and to achieve MES compliance numerous PM abatement projects are being implemented. Amongst others, key projects include ESP upgrades on Unit (U) 2, U3, U1, U4, and U5 (U6 complete); SO<sub>3</sub> plant upgrades on U2, U3, and U5 (upgrades on U1, U4, and U6 are complete); while high frequency power supply (HFPS) installations have been completed on all units.

Following the completion and optimisation of these projects, Lethabo will achieve MES compliance, although the projects will not be fully completed on all units until October 2027, after the 1 April 2025 deadline. Given this and considering the Eskom Fleet PM emission reductions between FY2025 – FY2028, Lethabo is requesting exemption from the new plant MES on U2 and U3 until 1 April 2026; U5 until 1 October 2026; U4 until 1 April 2027; and U1 until 1 October 2027 (Table 0-2). U6 will comply with the new plant MES from 1 April 2025.

## NITROGEN DIOXIDE

Ambient nitrogen dioxide (NO<sub>2</sub>) concentrations in the Highveld and Vaal Triangle indicate compliance with the annual and hourly NAAQS. Cumulatively, the Eskom Fleet's emission trajectory shows significant decreases, and by FY2030 would have reduced by 292kt (40%), and by a further 574kt (78%) by FY2050. These reductions are predominantly due to the LNB installations at Lethabo, Tutuka, and Majuba, as well as assumed station shutdowns commencing. The dispersion modelling, undertaken to assess each of the trajectories (ERP 2024 A, ERP 2024 B, and ERP 2024 C), shows full compliance with the NAAQS at all receptors. Further, Scenario 1 and Scenario A (of the dispersion modelling scenarios), both of which do not include the LNBs at Lethabo, Tutuka, and Majuba, still predicts full compliance with the NAAQS.

Currently, Lethabo is compliant with the existing plant limit (1,100mg/Nm<sup>3</sup>), although exceedances have occurred; Lethabo will not achieve compliance with the new plant MES (750mg/Nm<sup>3</sup>) without the installation of NO<sub>x</sub> abatement. LNB installation is scheduled to commence in FY2027, with completion by FY2031, after which Lethabo will comply with the new plant MES. For this reason, Lethabo is



requesting exemption from the new plant NO<sub>x</sub> MES until 1 April 2031 (Table 0-2). Important considerations in this request include:

- The currently compliant ambient NO<sub>2</sub> concentrations in the Highveld and Vaal areas, recognising Eskom is currently contributing to these concentrations at current emission rates.
- The dispersion modelling predictions indicating concentrations associated with the Eskom Highveld and Vaal Fleet emissions, including Lethabo, remain compliant with the NAAQS under all scenarios.
- The cumulative Eskom Fleet NO<sub>x</sub> emission reductions.

## SULPHUR DIOXIDE

From 2021 to 2023, SO<sub>2</sub> concentrations in the Highveld and Vaal Triangle complied with the annual NAAQS across all monitoring stations. The Eskom Fleet trajectories show similar emissions until FY2032, when Majuba's DSI is completed, after which ERP 2024 B and ERP 2024 C reduce further. ERP 2024 C emissions are lower than ERP 2024 B in 2036, as ERP 2024 C also includes SO<sub>2</sub> abatement at Lethabo and Tutuka. Considering ERP 2024 A (Eskom planned option), by FY2030, a reduction of 555kt (32%) will be achieved across the fleet, with a further reduction of 165kt (14%) to FY2035. The dispersion modelling, undertaken to assess each of these scenarios, predicted full compliance for ERP 2024 A, ERP 2024 B, and ERP 2024 C, while also showed full compliance for the additional modelling scenarios simulated. Despite the differences in SO<sub>2</sub> abatement between ERP 2024 A (Kusile), ERP 2024 B (addition of Medupi, Kendal, and Majuba), and ERP 2024 C (addition of Lethabo and Tutuka), all model predictions showed full compliance.

Currently, Lethabo is compliant with the existing plant limit (2,600mg/Nm<sup>3</sup>), with no exceedances of this, although to achieve new plant MES compliance, Lethabo would require an FGD, or similar abatement technology. Semi-dry FGD would be the most suitable for Lethabo, however Eskom has consistently motivated in previous applications that an FGD at Lethabo is not feasible and has therefore not commenced with concept and design. Should Lethabo be required to install an FGD, if it is deemed technically feasible, installation would only commence in 2031, with a best-case completion date of 2035, with Lethabo entering shutdown phase in 2036, well before return on investment is realised. Eskom maintains this position in this application; considering the costs of an FGD (R40 billion nominal Capex and an Opex of R1 billion annually), timeframes until installation is complete, additional water requirements (13% increase on current Lethabo requirements), and the additional waste produced (840kta) requiring a new disposal facility. While CO<sub>2</sub> emissions will also increase due to the FGD, approximately 2.3Mt over Lethabo's remaining life, this will have little impact on Eskom's 2031 target for CO<sub>2</sub> emissions from fossil fuel generation.

Since Lethabo is unable to comply with the new plant MES without SO<sub>2</sub> abatement technologies, and it is not considered economically feasible to install these, to reduce SO<sub>2</sub> emissions, although recognising not to MES compliance, Lethabo will reduce emissions through efficiency improvement projects and Despatch Prioritisation.

Lethabo is required to comply with a SO<sub>2</sub> daily average new plant emission limit of 1,000mg/Nm<sup>3</sup> by 1 April 2025. Since it is not economically feasible to install an FGD at Lethabo, Lethabo is requesting exemption from the new plant MES (Table 0-2). Important considerations in this request include:

- The currently compliant ambient SO<sub>2</sub> concentrations in the Highveld and Vaal areas, recognising Eskom is currently contributing to these concentrations at current emission rates.

- The dispersion modelling predictions indicating cumulative concentrations associated with the Eskom Highveld and Vaal Fleet emissions, including Lethabo, remain compliant with the NAAQS. In addition, ERP 2024 A, which assumes only SO<sub>2</sub> abatement at Kusile with all remaining stations emitting at current rates (including Lethabo), still shows full compliance with the NAAQS.
- The cumulative Eskom Fleet SO<sub>2</sub> emission reductions that will be achieved.
- The costs associated with the installation of FGD at Lethabo, with installation completion only occurring one to two years before station shutdown commences.

## HEALTH COST BENEFIT ANALYSIS

While the above discussions are pollutant specific, consideration needs to be given to the health cost benefit analysis (CBA) undertaken for the Eskom Highveld and Vaal Triangle Fleet, which considers benefits and costs as a combination of pollutants. The CBA uses exposure-response functions (ERFs) to estimate the health benefits in terms of reduced mortality rates due to lower pollutant levels. The value of a statistical life (VSL) is applied to monetize these health benefits. The CBA assessed the implementation of various emission reduction technologies, evaluating the health benefits and costs associated with the ERP 2024 A, ERP 2024 B, and ERP 2024 C projections. The benefit:cost ratios (BCR) need to be interpreted with care. They are meant only to provide a perspective on and inform the decision-making process underlying the scenarios. They are not meant to be interpreted as a definitive answer to making abatement decisions. Decisions involving human health have to be informed by non-economic criteria as well. In addition, with uncertainty inherent in the analysis, the cost benefit ratio should thus not be viewed as absolute, but rather as a relative value from which to compare scenarios (Prime Africa Consult, 2024).

The analysis reveals that ERP 2024 A, which includes PM and NO<sub>x</sub> reduction and Despatch Prioritisation, has a benefit-cost ratio (BCR) greater than 1, indicating that health benefits exceed costs. ERP 2024 B, which adds SO<sub>2</sub> reduction at Majuba and Kendal, approaches a BCR of 1 in optimistic scenarios but generally shows lower benefits relative to costs. ERP 2024 C, which includes full compliance with MES for SO<sub>2</sub> at Lethabo and Tutuka, has a BCR significantly less than 1, suggesting that the costs far outweigh the health benefits, especially given the short operational period before decommissioning. In summary, greatest benefits relative to costs are evident from ERP 2024 A, which assumes all PM and NO<sub>x</sub> reduction projects as planned, with SO<sub>2</sub> abatement only installed at Medupi and Kusile. The analysis underscores the importance of considering both economic and health impacts in decision-making for emission reduction strategies.

## SUMMARY

Table 0-1 summarises key information associated with each ERP scenario, including the health BCR for the Highveld and Vaal Fleet.

**Table 0-1 – Eskom Fleet ERP Summaries and Impacts**

	ERP 2024 A (Current Plan)	ERP 2024 B (Partial Compliance)	ERP 2024 C (Full MES Compliance)	ERP 2024 A (Current)	ERP 2024 B (Partial Compliance)	ERP 2024 C (Full MES Compliance)
	Eskom Fleet (cumulative)			Lethabo		
<b>SO<sub>2</sub> Abatement</b>	Kusile, Medupi FGD	Kusile, Medupi, Kendal (FGD), Majuba (DSI)	Kusile, Majuba, Matimba, Kendal, Medupi, Tutuka, Lethabo (FGD)	-	-	FGD
<b>NO<sub>x</sub> Abatement</b>	Majuba, Lethabo, Tutuka LNB	Majuba, Lethabo, Tutuka LNB	Majuba, Lethabo, Tutuka LNB	LNB	LNB	LNB
<b>PM Abatement</b>	Kendal, Matimba, Lethabo, Tutuka, Duvha, Matla PM Projects	Kendal, Matimba, Lethabo, Tutuka, Duvha, Matla PM Projects	Kendal, Matimba, Lethabo, Tutuka, Duvha, Matla PM Projects	Lethabo ESP (U1 – U5); SO3 (U2, U3, U5)	Lethabo ESP (U1 – U5); SO3 (U2, U3, U5)	Lethabo ESP (U1 – U5); SO3 (U2, U3, U5)
CAPEX (nominal)	R77.2 billion	R134.6 billion	R256.9 billion	R7 billion	R7 billion	R40 billion
OPEX (real pa)	R2.1 billion	R4.2 billion	R6.3 billion	-	-	R1 billion
Benefit:Cost Ratio, Central (Highveld Only)	1.74	0.55	0.33	-	-	-

Eskom is requesting exemption from the new plant MES for PM, NO<sub>x</sub>, and SO<sub>2</sub> at Lethabo. While compliance with the PM and NO<sub>x</sub> new plant MES will be achieved once abatement equipment installations are complete, compliance with the SO<sub>2</sub> new plant MES cannot be achieved without abatement. As presented, Eskom maintains its position that installation of an FGD, or similar technology, at Lethabo is not feasible, predominantly due to the cost and timeframe of installation, with this only being complete one to two years before Lethabo enters shutdown. Eskom's exemption request is supported by the currently compliant ambient SO<sub>2</sub> concentrations in the area, as well as the dispersion modelling indicating cumulative Eskom contributions to ambient concentrations remain in compliance with the NAAQS. Further to this, the CBA undertaken for this application indicates the costs to achieve full SO<sub>2</sub> MES compliance (ERP 2024 C) far outweigh the health benefits that will be realised from this compliance, while also concludes that most health benefits, relative to costs, will be achieved in ERP 2024 A, which plans for SO<sub>2</sub> abatement only at Kusile.

Strict adherence to the legal framework and regulations (i.e. MES) will require Lethabo generating units to be taken offline, which will reduce available capacity in the grid, resulting in an increased degree of loadshedding. Approximately 3,558 MW at Lethabo will be at risk, and should generating



units need to be shutdown, will likely trigger load-shedding, and could significantly affect the economy, employment, standard of living, government revenue, electricity supply and investor confidence.

A balanced approach to energy policy is required, aiming to reduce reliance on coal while expanding renewable and lower-emission energy sources, although the roll-out of these transitions has been slow. Aligning with the National Energy Crisis Committee (NECOM) Energy Action Plan, Eskom aims to address the energy gap with immediate solutions such as demand reduction, accelerating the construction of new generation and storage capacity, improving infrastructure, and enhancing Eskom's operational efficiency.

From an economic/financial perspective a defined minimum load factor/take or pay agreement would ensure that the unit costs are acceptable compared to known alternatives, however if consideration could be given to the extension of the station life the economic/financial viability could improve.

While extension of a station's life may provide improved viability, this would mean an extension of South Africa's reliance on coal generation, potentially impacting South Africa's GHG commitments. A possible alternative to consider, would be that if funding is made available Eskom increases its investments in renewables and grid connection by the same amounts that would have been invested in such SO<sub>2</sub> retrofits; this would result in larger economic value add than FGD retrofits, and would progress South Africa's transition to renewables quicker.

Considering the above, and in summary, Lethabo is requesting exemption from the PM (for certain generating units), NO<sub>x</sub>, and SO<sub>2</sub> new plant MES, and requests the limits presented in Table 0-2 be applied, and remain applicable to Eskom as emission targets in terms of the Priority Area Plans. To achieve partial MES compliance (PM and NO<sub>x</sub>), as requested for Lethabo, a nominal cost of R7 billion will be incurred. To achieve full MES compliance, a nominal cost of R47 billion would be incurred.

**Table 0-2 - Emission limits requested for Lethabo**

POINT SOURCE CODE	POLLUTANT	MAXIMUM RELEASE RATE*			DURATION OF EMISSIONS
		mg/Nm <sup>3</sup>	Average Period	Date To Be Achieved	
U1, U2, U3, U4, U5, U6	SO <sub>2</sub>	2,600 mg/Nm <sup>3</sup>	Daily	Immediate - shutdown	Continuous
	NO <sub>x</sub>	1,100 mg/Nm <sup>3</sup>	Daily	Immediate	Continuous
		750 mg/Nm <sup>3</sup>	Daily	1 April 2031	Continuous
U6	PM	100 mg/Nm <sup>3</sup>	Daily	Immediate	Continuous
		50 mg/Nm <sup>3</sup>	Daily	1 April 2025	Continuous
U2, U3	PM	100 mg/Nm <sup>3</sup>	Daily	Immediate	Continuous
		50 mg/Nm <sup>3</sup>	Daily	1 April 2026	Continuous
U5	PM	100 mg/Nm <sup>3</sup>	Daily	Immediate	Continuous
		50 mg/Nm <sup>3</sup>	Daily	1 October 2026	Continuous
U4	PM	100 mg/Nm <sup>3</sup>	Daily	Immediate	Continuous
		50 mg/Nm <sup>3</sup>	Daily	1 April 2027	Continuous
U1	PM	100 mg/Nm <sup>3</sup>	Daily	Immediate	Continuous
		50 mg/Nm <sup>3</sup>	Daily	1 October 2027	Continuous

\*Emission limits requested are for normal operations, so excludes upset, startup, shutdown, or maintenance conditions.


The public participation phase is complete, which commenced on 6 November 2024 and ended 6 December 2024. The comments received during this process have been responded to, as contained within the Stakeholder Engagement Report. The final Exemption Application reports will be submitted to the Minister of the DFFE to consider the applications. Any further comments can be directed to the Minister.

# 1 INTRODUCTION

---

Eskom Holdings SOC Ltd (Eskom) is the public electricity utility company of South Africa, as of 2024, Eskom is responsible for supplying approximately 95% of electricity to South Africa's national grid, with an available generation capacity exceeding 35,000 MW (Eskom, 2024). Eskom's role is to help reduce the cost of doing business in South Africa, supporting economic growth, and ensuring a stable electricity supply by delivering power efficiently and sustainably. This mandate is guided by its vision and mission, which aim to enhance the quality of life for people in South Africa and the surrounding region, while maintaining a clean and healthy environment.

Eskom is responsible for generating, transmitting, and distributing electricity across the country and to neighbouring countries such as Namibia, Botswana, Zambia, Zimbabwe, and Mozambique. Approximately 90% of Eskom's generating capacity comes from coal-fired power stations, most of which are located in the Mpumalanga Highveld, with others such as Lethabo Power Station located in the Fezile Dabi District Municipality of the Free State province, and Matimba and Medupi Power Stations located in Limpopo's Waterberg District (Figure 1-1).



**Figure 1-1 - Eskom's coal-fired Power Station distribution**

Coal-fired power stations are subject to strict environmental regulations and monitoring due to their emissions. In terms of the National Environmental Management: Air Quality Act (No. 39 of 2004) (NEM:AQA), all coal and liquid fuel-fired power stations are required to meet the minimum emission standards (MES) contained in GNR 893 that was issued on 22 November 2013 (as amended by GNR 1207 on 31 October 2018) and promulgated in terms of Section 21 of the NEM:AQA. GNR 893 (as amended by GNR 1207) also provides for transitional arrangements in respect of the requirement for existing plants to meet the MES and provides that less stringent 'existing plant' limits must be achieved by 1 April 2015 for existing plants, and more stringent 'new plant' limits must be achieved by existing plants by 1 April 2020 unless specific legal indulgences are obtained.

Between 2018 and 2020, Eskom submitted applications for postponement, suspension and/or alternative limits to the MES for several of its power stations to the Department of Environmental Affairs (now the Department of Forestry, Fisheries, and the Environment (DFFE)) as the power utility sought more time to implement necessary pollution control technologies for Nitrogen Oxides (NO<sub>x</sub>), sulphur dioxide (SO<sub>2</sub>) and particulate matter (PM) emissions. These applications were necessary due to several factors, such as the restrictive legal framework, the advanced age of Eskom's power plant fleet, and the technical challenges of reducing emissions. Eskom's commitment to a Just Energy Transition (JET) and its broader climate change strategy also influenced this decision. The high costs of emission reduction technologies, which could significantly impact electricity tariffs and the financial stability of the utility, further underscored the need for a phased approach to compliance. Eskom's applications aimed to balance its legal obligations with the need to maintain stable electricity supply in South Africa (Eskom, 2020).

In response to Eskom's applications, the DFFE granted conditional postponements for several Power Stations in October 2021 (Grootvlei, Arnot, Komati, Camden, Hendrina, Acacia, and Port Rex Power Stations) through its National Air Quality Officer (NAQO); while partial refusals were issued for Majuba, Tutuka, Kendal, and Kriel Power Stations. However, the postponement applications for Lethabo, Matla, Medupi, Matimba, and Duvha Power Stations were rejected, citing concerns over the potential health impacts and the long-standing environmental challenges posed by emissions from the coal-fired power stations.

Eskom initiated an appeal process for the partial refusals and rejections on 13 December 2021, engaging with the DFFE and other governmental departments, on the basis that immediate compliance would lead to the shutdown of about 16,000 MW of coal-fired capacity. Eskom emphasised that this would negatively impact the national grid and delay South Africa's energy transition, and that flu gas desulphurisation (FGD) retrofit on "six-pack" power stations was not proven to be technically feasible and would be a world first. Eskom further argued that the cost of full compliance to the MES is estimated at R300 billion; and will not add any additional capacity to the national grid. Eskom added that if funding was available, and if it were possible to execute all the compliance projects in time to meet the requirements, these projects would add at least 10% to the existing electricity tariff.

Subsequently, appeals were lodged in respect of the NAQO's decisions concerning Eskom's Kendal, Tutuka, Majuba, Camden, Hendrina, Arnot, Komati, Grootvlei, and Kriel Power Stations on 9 February 2022. These appeals led to the establishment of the National Environmental Consultative and Advisory (NECA) Forum, in August 2022, by the Minister of Forestry, Fisheries and the Environment (Minister) to provide guidance on MES issues. .



On the 23<sup>rd</sup> of May 2024 the Minister issued its decision on the appeals made by Eskom, and other parties, with regards to the NAQO's decision made in October 2021. The decision prescribed that for power stations scheduled to be shut down by 2030 (Hendrina, Grootvlei, Arnot, Camden, and Kriel Power Stations), Eskom's request to suspend the MES limits was approved, with a further requirement to submit shutdown plans within 12 months to facilitate closure by 31 March 2030. For the remaining power stations, comprising Matla, Duvha, Tutuka, Kendal, Lethabo, Majuba, Matimba, and Medupi, Eskom was instructed to apply for an exemption under Section 59 of the NEM:AQA within 60 days from 23 May 2024. However, thereafter the Minister granted an extension to the 10<sup>th</sup> of December 2024 to apply for this exemption. The Minister would then assess each application based on its merits and supporting information. As part of this submission, Eskom was directed to notify all relevant stakeholders and provide them an opportunity to comment on the exemption applications, for inclusion in the submission.

Eskom has appointed WSP Group Africa (Pty) Ltd (WSP), as an independent service provider, to support on the exemption applications required in terms of the Minister's decision. This report is specific to the exemption request in terms of Section 59 of the NEM:AQA for the Lethabo Power Station. This report must be read in conjunction with the Eskom Fleet approach to the MES.

This report provides a comprehensive overview of the MES exemption application for Lethabo Power Station, detailing its background and the legal framework governing its operations. It outlines the Eskom's JET and repurposing plans, along with Eskom's emission reduction strategies and proposed emission limits. The report also examines the health and environmental impacts associated with the power station and discusses the financial consequences of compliance.

This draft MES exemption application report will be made available for public review to provide interested and affected parties (I&APs) the opportunity to comment on the report. Comments received during the public review period will be acknowledged and recorded in the final exemption application report submitted to the Minister for decision-making.


## 2 STATION BACKGROUND

---

Lethabo Power Station, a coal-fired facility, is situated approximately 10km south of Vereeniging and 25 km east of Sasolburg in the Free State Province of South Africa (Figure 2-1). Commissioned in 1985, the station's final unit was synchronised with the national grid in 1990 (Eskom, nd).

With an installed capacity of 3,810 MW, comprising six generating units, each with a capacity of approximately 635 MW, it stands as one of the largest power stations in South Africa. These units use tangentially fired, dry-bottom boilers designed for low-quality coal, and comprise of a boiler, a turbine coupled to a generator-rotor, control and auxiliary support systems (Eskom, nd).

Coal is sourced from the nearby mine, New Vaal Colliery, ensuring a steady and cost-effective supply. The planned shutdown for the Lethabo Power Station is over a period from financial year (FY) 2037 to FY 2042, with the retirement of its individual units staggered throughout these years; Unit 1 is set for shutdown in FY 2037, while Unit 6 will follow in FY 2042 (Eskom, nd). The final shutdown will be subject to obtaining all the necessary governance approvals from the National Energy Regulator of South Africa (NERSA), DFFE, National Treasury, and other relevant authorities.




**Figure 2-1 - Locality map for Lethabo Power Station**

Land uses in the vicinity of Lethabo Power Station, as illustrated in Figure 2-2, predominantly comprise mining and quarrying immediately north and northwest of Lethabo, with densely populated areas further north and north-west of this. Neighbouring densely populated areas comprise Viljoensdrif, Richmond, Vanderbijlpark, Sharpeville, Vereeniging, Vaalpark, and Sasolburg. Immediately south of Lethabo and to the east of the Vaal River, predominantly comprises agricultural areas, interspersed with farming residents.

Lethabo Power Station is bordered by the Vaal River. A depression wetland is located approximately 900 m east and an unchanneled valley bottom wetland is located approximately 4km north of the Power Station. On the eastern side, several non-perennial rivers exist, all of which are connected to a seep wetland.

With regards to the delineations of the Biodiversity Plan v10 Free State Province (BPFS) (2019), large tracts of natural habitat in the study area, particularly in the south, are delineated as Ecological Support Areas (ESAs 1 &2), while many other patches of habitat are delineated as Other Natural Areas. ESA play an important role in supporting the ecological functioning of critical biodiversity areas (cba's) or for generating or delivering important ecosystem services. These are areas that are required to support the persistence of species. They need to be maintained in at least an ecologically functional state, but some limited habitat loss may be acceptable. The surrounding area around Lethabo Power Station therefore serve as support areas for ecological functions.





**Figure 2-2 - Land cover map**

## 3 LEGAL FRAMEWORK

---

### 3.1 NATIONAL ENVIRONMENTAL MANAGEMENT: AIR QUALITY ACT

The overarching piece of legislation that governs air quality management in South Africa is the NEM:AQA, administered and enforced by the DFFE, Metropolitan, District and Local authorities. The NEM:AQA focuses on the protection of the environment by providing reasonable measures for:

- The protection and enhancement of air quality.
- The prevention of air pollution and ecological degradation.
- Securing ecologically sustainable development while promoting justifiable economic and social development.
- Give effect to everyone's right *"to an environment that is not harmful to their health and well-being"*

The NEM:AQA is therefore the key legislative framework for managing and controlling air quality in South Africa, particularly with respect to industrial activities such as coal-fired power stations. The Act plays a critical role in regulating air pollution from these facilities, ensuring that emissions are minimised to protect human health and the environment.

#### 3.1.1 SECTION 21 OF THE NATIONAL ENVIRONMENTAL MANAGEMENT: AIR QUALITY ACT – LISTING OF ACTIVITIES

In terms of Section 21 of the NEM:AQA a list of activities which result in atmospheric emissions and which the Minister or Member of the Executive Council (MEC) reasonably believes, have or may have a significant detrimental effect on the environment, must be promulgated. Sections 22, 36 to 49, 61 and 62 provide additional information regarding the Atmospheric Emissions Licence (AEL) requirements and processes to be followed.

GNR 893 (22 November 2013), as amended, promulgated in terms of the NEM:AQA, contains a list of activities that would require licensing. The activities applicable to Lethabo Power Station include:

- Subcategory 1.1: Solid Fuel Combustion Installations.
- Subcategory 2.4: Storage and handling of Petroleum Products.

Lethabo Power Station was issued with an AEL (ref. FDDM-MET-2011-08-P1), in April 2015 by the Fezile Dabi District Municipality for Subcategory 1.1: Solid fuel combustion installations, and 2.4 Storage and handling of petroleum products. This AEL expired on 31 March 2020, which Eskom advised would be renewed once the Lethabo Power Plant's, MES exemption application has been finalised.

#### 3.1.2 THE MINIMUM EMISSION STANDARDS

In March 2010, the MES was published in terms of the NEM:AQA. The intent is that by setting these emission limits (known as point source limits), overall air quality at the local or ambient level, as defined by the National Ambient Air Quality Standards (NAAQS), will be maintained. In terms of the NEM:AQA, all of Eskom's coal- and liquid fuel-fired power stations are required to meet the MES contained in GNR 893, and as amended in GNR 1207. The MES also provides transitional arrangements in respect of the requirement for existing plants to meet the MES and provided that less stringent limits had to be achieved by existing plants by 1 April 2015, and more stringent "new plant" limits had to be achieved

by existing plants by 1 April 2020. The MES applicable to Lethabo Power Station are listed in Table 3-1 below.

**Table 3-1 - Minimum emission standards for Category 1: Combustion installations, sub 1.1: Solid fuel installations**

SUBCATEGORY 1.1: SOLID FUEL			
Description:		Solid fuels combustion installations used primarily for steam raising or electricity generation.	
Application:		All installations with design capacity equal to or greater than 50 mw heat input per unit, based on the lower calorific value of the fuel used.	
Substance		Plant status	mg/Nm <sup>3</sup> under normal conditions of 10% O <sub>2</sub> , 273 Kelvin and 101,3 kPa.
Common name	Chemical symbol		
Particulate matter	N/A	Existing	100
		New	50
Sulphur dioxide	SO <sub>2</sub>	Existing	2 500
		New	1 000
Nitrogen oxides	NO <sub>x</sub>	Existing	1 100
		New	750

### 3.1.3 POSTPONEMENT OR SUSPENSION OF COMPLIANCE TIMEFRAMES

Section 12 of GNR 893 (as amended by GNR 1207) provides for the postponement or suspension of compliance timeframes with the MES under specific conditions. This means that facilities may apply to the NAQO for a postponement or suspension, for a maximum of 5 years, if they are unable to comply with the set standards by the required date.

The applicant must demonstrate current or future projects aimed at ensuring eventual compliance. They should also include an air quality impact assessment detailing the implications of continued emissions on the environment and health and evidence of consultation with I&APs.

Lethabo Power Station's application for postponement from the MES was rejected by the DFFE in October 2021. This decision was appealed by Eskom in December 2021 and a decision was issued by the Minister in May 2024 which directed Eskom to submit an exemption application in terms of Section 59 of the NEM:AQA.

### 3.1.4 EXEMPTION FROM MINIMUM EMISSION STANDARDS

Section 59 of the NEM:AQA grants any person, or organ of state, the right to apply for exemption from a provision of the NEM:AQA directly to the Minister of DFFE. These exemptions are typically made where compliance with a provision is considered inappropriate often due to requirements being economically or technically unfeasible and are generally time-bound and subject to review by the Minister. The review frequency can vary but often coincides with specific time frames set in the exemption itself.

Section 59 of the NEM:AQA provides Eskom the opportunity to apply for exemption from certain provisions of the NEM:AQA. In terms of Section 59, Eskom is required to advertise the application in

at least two newspapers circulating nationally and give reasons for the application. The approval of an MES exemption application could potentially limit the constitutional rights of South Africans by leading to environmental degradation, posing health risks, and creating economic and social challenges. As such, an approval would likely be issued subject to a range of conditions to limit potential negative impacts.

## **3.2 NATIONAL AMBIENT AIR QUALITY STANDARDS**

In terms of Section 9 of the NEM:AQA the Minister identified substances in the ambient air that are believed to present a threat to the health, well-being or the environment and has in respect of those substances, established national standards for ambient air quality. These standards provide the permissible amount or concentration of each of the substances in ambient air. The standards contain the averaging periods, concentrations, frequencies of exceedance, compliance dates and reference methods for select substances.

In 2004, the National Ambient Air Quality Standards (NAAQS) were promulgated to better regulate local air quality. The NAAQS define the acceptable levels of environmental risk associated with human exposure to air pollutants. If an area meets the NAAQS, it is considered to have an air quality that poses a legally acceptable level of risk to the environment and human health in South Africa.

The NAAQS relevant to Lethabo Power Station and this exemption application are sulphur dioxide (SO<sub>2</sub>), nitrogen dioxide (NO<sub>2</sub>), and particulate matter (PM<sub>10</sub> and PM<sub>2.5</sub>). The NEM:AQA defines ambient air to exclude air regulated by the Occupational Health and Safety Act (No. 85 of 1993).

## **3.3 REGULATION FOR IMPLEMENTING AND ENFORCING PRIORITY AIR QUALITY MANAGEMENT PLANS**

The Regulation for Implementing and Enforcing Priority Air Quality Management Plans of 26 August 2024 (GNR 5153) is a framework established by the South African government to provide for the implementation and enforcement of a priority area air quality management plans, in terms of sections 19(1)(b) and 19(5) of the NEM:AQA, to strengthen air quality management in identified priority areas with high levels of air pollution. It was published for public comment, allowing stakeholders and the public to provide input before it is finalised. These regulations have coincided with The Vaal Triangle Priority Area air quality management plan (AQMP) Implementation Regulations, published under GNR 614 on 29 May 2009, being repealed.

GNR 5153 is aimed at ensuring that designated priority areas meet national ambient air quality standards. The regulations also establish the mandatory steps for implementing emission reduction and management measures, with the government empowered to monitor their effectiveness and enforce compliance where necessary. They apply to various proponents, including those involved in activities like mining, reclamation, or operating controlled emitters such as power stations. These proponents are required to submit emission reduction and management plans, in terms of the regulations, within six months of the publication of a priority area AQMP. Once these emission reduction and management plans are approved, they must be implemented within specified timeframes. Additionally, any existing priority area AQMPs, published prior to the commencement of these regulations, must be reviewed by the DFFE within two years to include updated emission reduction targets. These measures ensure that compliance is regularly evaluated and enforced across sectors.



Lethabo Power Station is in the Vaal Triangle Airshed Priority Area (VTAPA). This region, which includes parts of the Free State and Gauteng Provinces in South Africa, was declared a priority area in 2006 due to high levels of air pollution. The VTAPA includes industrial activities, such as power stations, refineries, and other significant emission sources that contribute to poor air quality in the region. This region is therefore subject to the VTAPA AQMP, published on 28 May 2009, for focussed air quality management interventions aimed at reducing industrial emissions and protecting public health.

The VTAPA AQMP sought to reduce emissions from industries such as power stations and petrochemical plants, with specific focus on reducing SO<sub>2</sub>, NO<sub>x</sub>, and PM. These pollutants are linked to heavy industrial activities and high levels of air pollution within the Vaal Triangle. Specific emission limits, including those tied to MES for industries, are a cornerstone of the VTAPA AQMP. The VTAPA AQMP requires industries to meet strict MES values and incorporate Best Available Technology (BAT) for emission reduction. These measures include continuous monitoring and improvements, such as reducing fugitive emissions (unintended releases of pollutants, such as dust or gases from industrial activities). The VTAPA AQMP also calls for offsets to reduce pollution in other areas as compensation when targets are not immediately achievable. In addition, industries are encouraged to regularly review and update their emission reduction strategies to align with evolving environmental policies. Industries are also expected to take measures to reduce ground-level ozone precursors, such as NO<sub>x</sub> and volatile organic compounds (VOCs), which pose risks to both health and agriculture.

Hotspot Zones within priority areas, where intervention efforts are to be concentrated, are identified based on predicted levels of ambient air pollution from key pollutants and the potential for exposure. Prioritisation of sources are then ranked based on impacts rather than the extent of their emissions. Lethabo Power Station is classified as an emission source within hotspot zone 2, which is an area where PM<sub>10</sub> concentration is the highest within the VTAPA. As a result, interventions for the VTAPA were developed and Lethabo Power Station, falling within the power generation sector, is expected to comply with all the applicable listed activities for the MES and reduce fugitive emission to ensure compliance with the NAAQS. However, the implementation of regulations relevant to priority areas by authorities must also be done under the consideration and indulgence of any MES postponements, suspensions and exemptions granted to emitters.

Adherence to the VTAPA AQMP, as it currently stands, is not a legal requirement. The VTAPA AQMP outlines guidelines and recommended actions for stakeholders in the region to help meet air quality standards. However, while it sets MES and encourages BAT use, its enforcement has been somewhat limited. Non-compliance primarily results in reputational risks or administrative sanctions but is not uniformly enforced across sectors. In terms of the recently published Priority Area Regulations (GNR 5153) the VTAPA AQMP must be reviewed within two years of publication of the regulations to include emission reduction targets. Once VTAPA is reviewed, stakeholders (such as industries, municipalities, and other entities operating within priority areas like the Vaal Triangle) will be required to develop emission reduction and management plans indicating how they will comply with the agreed emission reduction targets. The regulation also provides enforcement mechanisms, including fines or penalties for non-compliance, making adherence to such air quality management plans legally enforceable. Thus, with the new regulation, failure to comply would result in legal consequences, strengthening the overall governance and impact of air quality management in priority areas.

### 3.4 POLICIES AND LEGISLATION REGARDING CLIMATE CHANGE

Table 3-2 and Table 3-3 outlines relevant policy, guidance and legislation (i.e., includes both International and National policy, guidance and legislation) that provides the framework within which the greenhouse gas (GHG) and climate change issues relevant to Lethabo Power Station have been considered.

**Table 3-2 – Applicable climate change related policies, legislation, guidelines and standards - International**

POLICY, LEGISLATION, GUIDELINE OR STANDARD	DESCRIPTION
<p>The Intergovernmental Panel on Climate Change (IPCC) is a panel established in 1988 by the World Meteorological Organisation (WMO) and the United Nations Environment Programme (UNEP) to provide independent scientific advice on climate change.</p> <p>This first assessment report of the IPCC served as the basis for negotiating the United Nations Framework Convention on Climate Change (UNFCCC).</p> <p>Its main role is to provide policymakers with regular assessments of the scientific basis of climate change, its impacts, and possible adaptation and mitigation strategies. While the IPCC does not have direct regulatory authority, its reports and findings play a crucial role in shaping global climate policies and informing decision-makers on how to address climate change.</p>	<p>The IPCC policy guides climate science, adaptation strategies, and emission reduction targets. Developers are encouraged to align with IPCC assessments to mitigate climate risks, manage water resources, and ensure compliance with environmental regulations. Stakeholder engagement and access to climate finance can benefit from this alignment, enhancing project credibility. IPCC data aids in risk assessment and long-term planning, informing decisions on infrastructure design and project sustainability. In summary, the integration of IPCC policies into the operations of developers supports climate resilience and aligns with global climate goals.</p> <p>The IPCC advocates for urgent global actions to mitigate climate change, mainly by reducing GHG emissions.</p>
<p>The Paris Agreement, which was adopted in December 2015, is an international accord within the UNFCCC. Its main objective is to limit global warming to well below 2 degrees Celsius above pre-industrial levels, with efforts to limit it to 1.5 degrees Celsius. To achieve this, the agreement aims to enhance the global response to climate change by strengthening countries' abilities to deal with the impacts of climate change and reducing greenhouse gas emissions (2015)</p>	<p>The Paris Agreement does not single out specific industries, rather it sets a framework for nations to develop and submit their own Nationally Determined Contributions (NDCs). These NDCs are country-specific climate action plans that outline the measures and targets each country will undertake to contribute to the global effort in combating climate change.</p> <p>These targets include reductions in emissions from various sectors, including the energy sector, where coal combustion activities play a role. South Africa's commitments are discussed below.</p> <p>The Paris Agreement also emphasises transparency and accountability. Countries are required to regularly report on their GHG emissions and progress towards their NDCs.</p> <p>The Paris Agreement seeks to limit global temperature increases to below 2°C, striving for 1.5°C, through GHG emission reductions. South Africa's commitments under the Paris Agreement is to reduce national emissions.</p>
<p>Greenhouse Gas Protocol (GHGP)</p>	<p>The GHGP is a joint initiative of the World Resources Institute (WRI) and World Business Council for Sustainable Development (WBCSD), which arose out of the need to help countries and companies account for, report, and mitigate emissions, based on a report that identified an action agenda to address climate change that included the need for standardised measurement of GHG emissions. The GHGP provides accounting and reporting standards, sector guidance, calculation tools</p>

POLICY, LEGISLATION, GUIDELINE OR STANDARD	DESCRIPTION
	<p>and training for businesses and local and national governments. It has created a comprehensive, global, standardised framework for measuring and managing emissions from private and public sector operations, value chains, products, cities and policies to enable GHG reductions across the board.</p> <p>This protocol provides a voluntary global standard for measuring and managing GHG emissions.</p>

**Table 3-3 - Applicable policies, legislation, guidelines and standards - National**

POLICY, LEGISLATION, GUIDELINE OR STANDARD	DESCRIPTION
<b>National Policy and Strategy</b>	
South Africa's National Climate Change Response Policy White Paper (NCCRP) (2011)	<p>The National Climate Change Response Policy is a comprehensive strategy to address both mitigation and adaptation in the short, medium and long term (up to 2050).</p> <p>Strategies are specified for the following areas:</p> <ul style="list-style-type: none"> <li>Carbon Pricing.</li> <li>Water Agriculture and commercial forestry.</li> <li>Health.</li> <li>Biodiversity and ecosystems.</li> <li>Human settlements.</li> <li>Disaster risk reduction and management.</li> </ul> <p>The policy has two main objectives: first, to manage inevitable climate change impacts through interventions that build and sustain social, economic and environmental resilience and emergency response capacity. Secondly, to make a fair contribution to the global effort to stabilise GHG concentrations in the atmosphere.</p> <p>The NCCRP outlines South Africa's vision for transitioning to a low-carbon economy.</p>
National Climate Change Adaptation Strategy (NCCAS) (2020)	<p>The NCCAS provides a common vision of climate change adaptation and climate resilience for South Africa, and outlines priority areas for achieving this vision. It draws on South Africa's National Climate Change Response Policy (NCCRP) (DEA 2011), the National Development Plan (NDP) (NPC 2011), the adaptation commitments included in its NDC, sector adaptation plans, provincial adaptation plans and local government adaptation plans.</p> <p>The main objective of the strategy is to provide guidance across all levels of government, sectors, and stakeholders affected by climate variability and change. It should also serve as the country's National Adaptation Plan and fulfils the commitment to its international obligations under the Paris Agreement.</p> <p>The NCCAS aims to enhance the country's climate resilience and adaptability.</p>
South Africa's Nationally Determined Contributions (NDC) (2021)	<p>South Africa updates and enhances its NDC under the Paris Agreement, meeting its obligation under Article 4.9 to communicate NDCs every five years, and responding to the requests in paragraphs 23 to 25 of decision 1/CP.21. The NDC was updated in 2021 to account for developments and increased ambitions since the first submission.</p> <p>Climate mitigation targets have been updated to:</p>

POLICY, LEGISLATION, GUIDELINE OR STANDARD	DESCRIPTION									
	<table><tr><th>Year</th><th>Target</th><th>Corresponding period of implementation</th></tr><tr><td>2025</td><td>South Africa's annual GHG emissions will be in a range from 398-510 Mt CO<sub>2</sub>-eq.</td><td>2021-2025</td></tr><tr><td>2030</td><td>South Africa's annual GHG emissions will be in a range from 350-420 Mt CO<sub>2</sub>-eq.</td><td>2026-2030</td></tr></table> <p>The NDC outlines adaptation goals and highlights planned mitigation and adaptation efforts and associated costs. The updated NDC highlights the importance of securing access to large-scale international climate finance</p> <p>South Africa's NDC includes emission reduction targets under the Paris Agreement.</p>	Year	Target	Corresponding period of implementation	2025	South Africa's annual GHG emissions will be in a range from 398-510 Mt CO <sub>2</sub> -eq.	2021-2025	2030	South Africa's annual GHG emissions will be in a range from 350-420 Mt CO <sub>2</sub> -eq.	2026-2030
Year	Target	Corresponding period of implementation								
2025	South Africa's annual GHG emissions will be in a range from 398-510 Mt CO <sub>2</sub> -eq.	2021-2025								
2030	South Africa's annual GHG emissions will be in a range from 350-420 Mt CO <sub>2</sub> -eq.	2026-2030								
South African National Greenhouse Gas Emission Reporting (NGER) Regulations (2017)	<p>The Reporting Regulations adheres to the NEM:AQA. The purpose of the National Greenhouse Gas Emissions Reporting Regulations is to introduce a single national reporting system for the transparent reporting of greenhouse gas emissions, which will be used to maintain a National Greenhouse Gas Inventory, allow South Africa to meet its UNFCCC reporting obligations and to inform the formulation and implementation of legislation and policy.</p> <p>The emission sources and data providers who are covered by the regulations are set out in Annexure 1 and Regulation 4. Energy is included as a sector. The Regulations also set out the reporting requirements, calculation methodology, verification procedure (to be carried out by the National Inventory Unit) and penalties (which include fines and imprisonment).</p> <p>These regulations mandate reporting of GHG emissions to ensure transparency and accountability.</p>									
Declaration of Priority Pollutants and Pollution Prevention Plans (2018)	<p>Under Section 29 of the NEM:AQA, Government Notice 710 of 2017 (Government Gazette 40996), GHGs (carbon dioxide (CO<sub>2</sub>), methane (CH<sub>4</sub>), nitrous oxide (N<sub>2</sub>O), hydrofluorocarbons (HFCs), perfluorocarbons (PFCs) and sulphur hexafluoride (SF<sub>6</sub>)) have been declared as priority pollutants. Further, persons falling within the list of production processes, specified in Annexure A, which involves emission of GHGs in excess of 0.1 Mt annually are required to prepare and submit to the Minister pollution prevention plans for approval in line with NEM:AQA, Government Notice 712 of 2017 (Government gazette 40996). On 22 May 2018, in Government Notice 513 in Government Gazette 41642, the Minster of Environmental Affairs amended the National Pollution Prevention Plan Regulations (published in Notice 712 on 21 July 2017). In terms of this amendment, the first pollution prevention plan was due on or before 21 June 2018.</p> <p>A first pollution prevention plan must cover a period from the date of promulgation of these regulations up to 31 December 2020 and the subsequent pollution prevention plans must cover periods of five calendar years each.</p> <p>This policy focuses on reducing priority pollutants, including GHGs.</p>									
South African Carbon Tax Act (2019)	<p>The Act imposes a tax on carbon dioxide equivalent (CO<sub>2</sub>e) GHG emissions. The tax follows the polluter pays principle to ensure that high emitting companies are accountable for their contribution to climate change.</p> <p>The South African Carbon Tax Act, 2019 establishes a framework for calculating and applying carbon tax, but the actual tax liability for an emitter would depend on various elements, including:</p> <ul style="list-style-type: none"><li>■ Emission Levels</li><li>■ Allowances and Thresholds</li><li>■ Carbon Budgets</li><li>■ Renewable Energy Tax Incentives</li><li>■ Sector-Specific Factors</li><li>■ Compliance and Reporting</li></ul>									



POLICY, LEGISLATION, GUIDELINE OR STANDARD	DESCRIPTION
	<p>The specific tax amount paid by the station would be determined through calculations based on these factors and the applicable tax rates specified in the Carbon Tax Act. The Act provides a structure for progressively increasing carbon tax rates over time.</p> <p>The Carbon Tax Act imposes a tax on GHG emissions to encourage reductions and are applicable to Eskom Power Stations.</p>
Draft National Guideline for the Consideration of Climate Change Implications in Applications for Environmental Authorisation, AEL and WML (2021)	<p>On 25 June 2021, the Minister of Forestry, Fisheries and the Environment published a Notice under the National Environmental Management Act (No. 107 of 1998) (NEMA) seeking public comment on a draft National Guideline for the consideration of climate change implications in applications for environmental authorisation, atmospheric emission licences and waste management licences.</p> <p>The draft National Guideline aims to create a consistent approach for the incorporation of climate change considerations in EIAs, WMLs and AELs. The guidelines outline a methodological approach for minimum requirements for consideration when conducting climate change assessments has been considered in compiling this report.</p> <p>This guideline advises integrating climate change considerations into environmental decisions, aiming to ensure that projects minimise their climate impacts.</p>
South African Climate Change Act (2024)	<p>The Climate Change Bill was signed into law on 18 July 2024 and published as Climate Change Act, 2022 (Act) on 23 July 2024. However, as per Section 35 of the Act, it will only come into operation on a fixed date by the President proclamation in the Government Gazette. The Act provides a comprehensive South African legal framework for regulating the climate change impacts with the goal of achieving net-zero by 2050.</p> <p>The Act aims to enable effective development of climate change responses through a long-term transition to a climate-resilient and low-carbon society and economy while considering sustainable development. The Act aims to contribute fairly to global GHG stabilisation and conforms to South African international climate change obligations and commitments to protect and preserve our planet for current and future generations.</p> <p>The Act provides two main mechanisms to reduce the country's GHG emissions:</p> <ul style="list-style-type: none"> <li>Section 24 (under Chapter 5) of the Act obliges the Minister to determine a national GHG emissions trajectory. This trajectory must be set in consultation with the Cabinet. The trajectory must specify a national GHG emission reduction objective. This objective must be informed by South Africa's current and projected greenhouse gas emissions and be consistent with South Africa's international obligations.</li> </ul> <p>Section 25 (under Chapter 5) of the Act deals with sectoral emissions targets. According to Section 25, the Minister must identify GHG-emitting sectors and sub-sectors that should be subject to sectoral emissions targets. The Minister must then set sectoral emissions targets for each sector, in consultation with the relevant Minister responsible for that sector. These targets must align with the national GHG emissions trajectory. The Minister responsible for each sector must then implement each sectoral target through a range of planning instruments, policies, measures, and programmes.</p>

## **4 JUST ENERGY TRANSITION AND REPURPOSING PLANS**

---

### **4.1 INTRODUCTION**

South Africa is grappling with the energy trilemma: how to simultaneously ensure energy security, affordability and access, and sustainability. At the same time, South Africa's national context of high unemployment and inequality, unreliable performance of the current power generation fleet, and reliance on coal-fired generation in the electricity sector make the energy trilemma uniquely complex.

It was with this context in mind that Eskom's JET Strategy was developed, which is focussed on resolving all components of the energy trilemma, by delivering on the 5 "E"s: Energy, Economy, Employment, Equity, and Environment.

As Eskom's existing power plants gradually reach their end of life, the standard of living, quality of life and state of surrounding communities are at risk of decline if no mitigation actions are taken. While developing new energy capacity to resolve the energy trilemma is critical, a considered approach that ensures power station communities share in the benefits of the transition is of equal importance.

For Eskom's JET Strategy, a clear link is seen between the need to build new energy capacity and the importance of ensuring the transition offers a second life to power station communities. The combination of these aims, are not mutually exclusive, form the core of Eskom's JET ambition.

### **4.2 JET STRATEGY AND ENERGY BROADER POLICY LANDSCAPE**

The purpose of the JET Strategy is to provide a consolidated view of the approach that will be taken to build Eskom's future portfolio, optimising for economic growth and development, the reduction of emissions, the creation of jobs, and equitable socio-economic development. These objectives necessitate the gradual, but decisive, development of renewable energy generation, aligned to the 5 Es of Eskom's JET.

Transitioning in a socially and economically responsible manner is aligned to South Africa's broader policy goals in the context of the global effort to mitigate climate change. Given the country's vulnerability to climate change and its commitment to an inclusive energy transition, South Africa chose to be part of the transition to a low-carbon, socially inclusive future, by announcing a revised NDC of ~350-420 megatonnes (Mt) of carbon dioxide equivalent (CO<sub>2</sub>e) per annum at COP26 in 2021. The country's stated objectives are in line with the global direction of travel, including for other developing countries.

The revised Eskom JET Strategy is an updated version of the original JET Strategy approved in 2021. The revised JET Strategy adjusts the positioning of the original JET Strategy slightly by acknowledging the context of the ongoing energy crisis and the national Generation Strategy, as well as the debt relief conditions subsequently announced by National Treasury. The revised strategy details financing and partnership options that are available to support the execution of JET and the socio-economic impact of JET. The original JET Strategy assumed that Eskom would largely execute on JET projects through debt financing. Given the debt relief conditions, the revised strategy indicates that Eskom will not be able to execute on all the projects on the balance sheet and thus external collaboration models must be explored.


The JET Strategy, Generation Strategy and Energy Crisis Management Strategy are interdependent, together contributing to address all components of the energy trilemma. The Energy Crisis

Management Programme emanates predominantly from new generation capacity not coming online as anticipated in the Integrated Resource Plan (IRP) 2010 and IRP 2019 and Eskom's lower than expected plant energy availability factors (EAF). However, it should be noted that since the IRP was last updated in 2019, the EAF has improved with the latest state of system briefing held on 26 August 2024 indicating an EAF of 67.02% (July MTD).

A review of the coal plant shutdown schedules, as part of the Generation Strategy was prompted due to low plant EAFs. As these schedules are subject to change going forward, the JET Strategy has been decoupled from the shutdown of coal-fired power stations. Recognising the JET Strategy as separate from shutdown is important, as the focus of the JET on new capacity additions and socio-economic projects for power station communities should proceed regardless of specific shutdown timelines. The JET Strategy, which focuses on Repurposing and Repowering existing power stations and developing new renewable energy capacity, will proceed regardless of any specific shutdown schedule.

The Energy Crisis Strategy and the Eskom JET Strategy overlap on grid access, since a key factor limiting new build is Transmission's current constraints in evacuating additional generating capacity in prime wind and solar regions. The JET Strategy promotes build in Mpumalanga, where there is established grid infrastructure, and where repowering of coal power stations is possible while they are still operational.

The Generation Strategy and JET Strategy overlap where repowering and repurposing (R&R) and other socio-economic initiatives provide a second life to coal power plants and their surrounding communities. In the nexus of all three strategies lies a low-carbon future that contributes to solving all components of the energy trilemma (Figure 4-1).



**Figure 4-1 - The Energy Crisis Management, Generation and JET strategies are interdependent, but have different areas of focus (Eskom JET, 2023)**


The Energy Crisis Management Strategy, amongst other factors, focuses on assessing the potential for the continued operation of coal plants, management of energy demand and sourcing additional

generation through Independent Power Producers (IPPs) and/or National Energy Crisis Committee of Ministers (NECOM). The Generation Strategy has different, but overlapping, focal areas: running existing generation efficiently and effectively, improving the maintenance and EAFs of power stations, and preparing for power stations that are reaching the end of their useful lives.

The JET Strategy focuses on offering a second life for coal power stations and the communities that depend on existing generation, figuring a pathway for new build Eskom capacity in alignment with the IRP to enhance energy security, and defining Eskom's planned socio-economic interventions to ensure the energy transition is truly Just.

The main purpose of the IRP is stated as: *"to ensure security of electricity supply necessary by balancing supply with demand, while considering the environment and cost of supply"*. With this in mind, Eskom's JET Strategy is in alignment with the IRP and seeks to balance its commitments of electricity demand, environmental obligations and cost of electricity supply to customers.

#### 4.2.1 REPOWERING AND REPURPOSING PLANS



**Figure 4-2 - Location and expected R&R for coal power stations with a focus on Mpumalanga**

As discussed above, the development of a renewables-dominant power system aims to create jobs and stimulate economic growth. To ensure that communities currently reliant on coal power plants benefit from this transition specifically, Eskom has further identified repowering and repurposing projects to create economic opportunities in these communities. These projects will be a key component of the JET as Eskom seeks to repower and repurpose existing coal plants to preserve jobs and utilise existing grid capacity. Power stations in Mpumalanga, depicted in Figure 4-2, will be prioritised.

As per the plan, coal plants will be repowered by leveraging the existing infrastructure to build new generation capacity including solar, wind, batteries and/or synchronous condensers. The plants will also be repurposed into new centres of economic activity with training centres, water treatment facilities, manufacturing plants, microgrid assemblies and modern aquaponic farms as potential initiatives. Therefore, a Just transition for local communities, through these Repurposing and Repowering activities which will help to retain economic activity, create jobs, and create new economic opportunities.

Eskom has already commenced with the implementation of the largest repowering and repurposing project in emerging markets at the Komati Power Station. The Komati repowering and repurposing projects are expected to have a significant impact by 2030, including the following:

- ~660 estimated direct full-time jobs and ~8700 additional temporary jobs created.

- ~370 MW of renewable generation capacity, replacing remaining ~100 MW of operational capacity at Komati when it was shut down in 2022.
- ~200 people are expected to be trained in different vocations annually.

Approximately \$497 million dollars has been secured in funding from the World Bank for this project. Some examples of projects currently underway at Komati that are contributing to the stated impact include a renewable technical training facility, agrivoltaics plants and a containerised microgrid assembly. Komati is the pilot project for the repurposing of a shutdown power plant, with the total cost of repurposing projects estimated at ~R434,5 million.

Potential repowering and repurposing projects were identified through socio-economic impact analyses employed to identify opportunities to offer a second life to power station communities. These initiatives are shortlisted through three filters to ensure the prioritised initiatives have maximum positive impact:

1. **Viability filter** uses on-site resources and findings of socio-economic impact analyses to understand which projects are implementable.
2. **Relevance filter** removes projects that are duplicated or do not have goals aligned with the JET Strategy.
3. **Prioritisation filter** places greatest focus on initiatives that have a meaningful impact on job creation and local economies, unlock other initiatives, and are cost-effective. This process also ensures that projects that are infeasible due to lack of funding, capabilities or regulatory compliance are deprioritised, as well as projects that lack demand for initiative outcomes or have low technological maturity.

The prioritisation filter leverages four stages to identify the optimal socio-economic initiative portfolio for Eskom to implement by itself, partner to implement, or support implementation. The four stages are:

1. **Project attractiveness** considers the sustainable and quality jobs the initiative creates, the capital expenditure (CAPEX) required to implement the initiative, the broader contribution the initiative will have on the economy, and the catalytic effect of the initiative on other initiatives in the area. The outcome of this stage is a ranked list of initiatives based on their attractiveness and relevance to the JET objectives.
2. **Feasibility assessment** considers the allocated or available funding for the initiative, the ease of implementation of the initiative, whether there are any regulatory constraints in Eskom pursuing the initiative, the maturity of the technology associated with the initiative, and whether the implementation of the initiative is dependent on another initiative. The outcome of this stage is the initiatives being categorised into initiatives Eskom to implement by itself, partner to implement, or support implementation based on how feasible the initiative is for Eskom to implement. Only initiatives that Eskom chooses to implement by itself, or partner to implement, will move on to the third stage and have business cases developed.
3. **High-level business case development** for the top 5-10 initiatives from stage two. The high-level business case will include aspects such as net present value (NPV) calculation, profitability, and time to deliver.
4. **Full business case and decision on Eskom's role** considering the value for Eskom based on the portfolio value add and strategic importance of the initiative. The outcome of this stage is the initiatives to be funded by Eskom are submitted for approval.

The current longlist of socio-economic initiatives that are being considered in the prioritisation stage has grown to over 130 projects, and this list will continue to grow as Eskom's JET Strategy is



implemented. Socio-economic initiatives are essential in ensuring that communities currently reliant on coal power stations have livelihoods protected and benefit from the energy transition.

Although Lethabo Power Station is not currently part of Eskom's repowering and repurposing plans since its shutdown date is post 2035, a similar approach will be taken as described above in order to identify suitable projects and plans in line with this strategy.

## 5 ESKOM EMISSION REDUCTION PLAN

### 5.1 ESKOM JOURNEY AND OVERVIEW

Coal-fired power stations are subject to strict environmental regulations and monitoring due to their emissions. All coal-fired power stations are required to meet the MES contained in GNR 893 that was issued on 22 November 2013 (as updated by GNR 1207 on 31 October 2018) and promulgated in terms of Section 21 of the NEM: AQA.

Between 2018 and 2020, Eskom submitted applications for postponement, suspension and/or alternative limits to the MES for several of its power stations to the DFFE as the power utility sought more time to implement necessary pollution control technologies for NO<sub>x</sub>, SO<sub>2</sub> and PM emissions.

To address emission reductions, Eskom developed an Emission Reduction Plan (ERP) in 2015, with this being updated in 2019 (EERP 2019), 2020 and 2022. In May 2024, as part of the Minister's decision, Eskom was required to review the 2022 ERP, with this having been revised by Eskom in 2024.

Currently installed emission abatement equipment at each station within the Eskom Fleet are presented in Table 5-1.

**Table 5-1 – Current installed abatement on the Eskom Fleet**

STATION	CURRENT INSTALLED ABATEMENT
Lethabo	Electrostatic precipitators (ESPs), sulphur trioxide (SO <sub>3</sub> ) plant, and high frequency power supplies (HFPS) to mitigate PM emissions.
Medupi	Pulse Jet Fabric Filter (PJFF) to mitigate PM emissions Low NO <sub>x</sub> Burner (LNB) to mitigate NO <sub>x</sub> emissions
Matla	ESPs, HFPS (Unit (U) 1, U2, U4 and U6), and SO <sub>3</sub> plant to mitigate PM emissions
Duvha	ESPs and SO <sub>3</sub> Plants (U4, U5, U6), fabric filters (U1, U2), HFPS (U5) to mitigate PM emissions
Tutuka	ESPs, HFPS (U4, U5, U6) to mitigate PM emissions
Kendal	ESPs, HFPS and SO <sub>3</sub> plant to mitigate PM emissions. Low NO <sub>x</sub> boilers designed to mitigate NO <sub>x</sub> emissions
Majuba	PJFF to mitigate PM emissions
Matimba	ESPs and SO <sub>3</sub> plant to mitigate PM emissions Low NO <sub>x</sub> boilers designed to mitigate NO <sub>x</sub> emissions
Kusile	Wet FGD, PJFFP to mitigate PM emissions Low NO <sub>x</sub> Burner (LNB) to mitigate NO <sub>x</sub> emissions
Arnot	PJFFP to mitigate PM emissions
Kriel	ESP Upgrade, HFPS installation (in progress) and SO <sub>3</sub> plant to mitigate PM emissions
Camden	PJFFP to mitigate PM emissions, LNB to mitigate NO <sub>x</sub> emissions
Hendrina	PJFFP to mitigate PM emissions

STATION	CURRENT INSTALLED ABATEMENT
Grootvlei	PJFFP to mitigate PM emissions, 4-units offline

Eskom's focus on PM emission reduction is aligned with the ambient monitoring data from the various stations located through the Highveld and Vaal; importantly these stations represent cumulative ambient concentrations with Eskom not being the sole contributor to measured concentrations. Of the Highveld and Vaal monitoring stations reviewed for this exemption application, for the period 2021 – 2023, all monitoring stations indicated non-compliance with the PM<sub>10</sub> and PM<sub>2.5</sub> annual average NAAQS at some point, with numerous exceedances of the NAAQS 24-hour standards also recorded.

While PM has been the critical focus, NO<sub>x</sub> and SO<sub>2</sub> emission reduction projects have also been considered. However, unlike PM, ambient NO<sub>2</sub> and SO<sub>2</sub> concentrations in the Vaal Triangle for 2021 – 2023 remain below the annual SO<sub>2</sub> and NO<sub>2</sub> NAAQS; although exceedances of the short-term averaging periods (10-minute, hourly, 24-hour, as applicable) of the NAAQS were measured, their frequency of occurrence remained below the permitted frequency of exceedance, remaining compliant with relevant standards.

Following Eskom's review of the 2022 ERP, and to ensure continued focus on emission reductions, Eskom developed the 2024 ERP. In addition to the various abatement equipment upgrades and refurbishments currently being undertaken at each station, predominantly addressing PM emissions through ESP refurbishments, HFPS upgrades, SO<sub>3</sub> plant upgrades, and Dust Handling Plant (DHP) upgrades, many of which are already complete, Eskom is also planning and/or evaluating the following to reduce emissions:


- Wet flue gas desulphurisation (FGD) at Medupi (included in previous ERPs)
- Kendal (semi-dry FGD) and Majuba (Duct Sorbent Injection (DSI FGD)) SO<sub>2</sub> reduction projects have been identified as potential alternatives, although are being evaluated as part of this process.
- Low NO<sub>x</sub> Burner (LNB) technology at Majuba, Tutuka and Lethabo to mitigate NO<sub>x</sub> emissions.
- Despatch Prioritisation Strategy at specific power stations, initiated to reduce SO<sub>2</sub> emissions, however also positively impacting PM and NO<sub>x</sub> emissions.
- Efficiency improvement projects under the Generation Recovery Programme to optimise the air-to-fuel ratio which should abate some SO<sub>2</sub> emissions and maximise combustion efficiency.
- The progressive shutdown of coal-fired stations will reduce overall Eskom Fleet emissions.
- Although not a method of reducing emissions at source (i.e. the power stations), the cumulative impact on neighbouring communities is reduced through the air quality offset (addressing emission sources within the community) projects already implemented by Eskom, therefore Eskom are looking to expand this beyond the 35,000 households originally planned.

Figure 5-1 illustrates Eskom's planned or estimated installation dates, linked to the 2024 ERP, for abatement equipment upgrades, retrofits, and new installations. This installation schedule considers:

- Time required to secure funding for each project.
- Lead time required to procure, design, manufacture, and begin installations.
- The outage schedule to allow generating units to be taken offline for upgrades / retrofitting while not impacting grid supply i.e. ensuring sufficient generating capacity remains across the stations to avoid loadshedding.



- To ensure sufficient capacity remains in the grid, generally only a single generating unit at a station can be taken offline at a time, particularly with regards to the long installation timelines of the equipment.



**Figure 5-1 - Eskom's abatement equipment installation schedule**

Coal beneficiation as a method of reducing SO<sub>2</sub> emissions has been investigated by Eskom and research continues. Investigations to date illustrate the potential for sulphur reduction but various complexities in terms of implementation need to be confirmed and managed such as the energy intensive nature of the process, increased coal mined, and the generation of additional wastewater and coal discards/solid waste. The financial and contractual implications of beneficiation also need to be assessed and shown to be positive for Eskom. Given these uncertainties Eskom has not included any benefit associated with coal beneficiation in the ERP and emission reduction calculations. Any emission reduction identified in this area in future will be considered additional to the 5% improvement in emissions associated with efficiency improvement projects.

Similarly, investigations completed to assess emission reductions using coal with a lower sulphur content confirm that for Eskom to obtain coal with low(er) sulphur content will, in most cases, require sourcing a washed product. This will result in Eskom acquiring coal from the same source pool that services the export market. Purchasing export market coal will result in a significant cost increase for Eskom and this filter though as an increase in electricity prices.

### 5.1.1 DESPATCH PRIORITISATION STRATEGY

With the addition of alternate energy sources (wind and solar) on to the national grid planned in the draft IRP, the existing coal fired power stations are expected to provide additional flexibility to the system through increased variability in a load following mode of operation, as well as providing back-up to the variable intermittent non-dispatchable renewable technologies, as well as providing ancillary services, inertia etc. which are not provided by the inverter-based renewable technologies. This essentially results in lower running load factors for these stations as the renewable energy sources will be given priority dispatch over the fossil fuelled stations. Furthermore, South Africa's commitments under the Paris Agreement (with the upcoming revision of the NDC) is expected to result in a new GHG emissions target for 2035. Considering an indicative limit of 125-140 Mt CO<sub>2</sub> per annum from fossil fuel generation from 2031, this equates to average load factors of 40-45% for stations operating in 2031 and between 48% to 55% for stations operating beyond 2035, i.e. after Matla and Duvha shutdown. While the MES and climate change regulatory process are legally separate it is useful to

note both ERP 2024 A and the security of supply projection are aligned with Eskom's current pollution prevention plan running to December 2025. Future CO<sub>2</sub> trajectories will be based on the updated pollution prevention plan and IRP, NDC, and Sectorial Emission Targets (SET).

Despatch Prioritisation of renewables reduces SO<sub>2</sub> emissions given the costs associated with SO<sub>2</sub> abatement equipment, complexities of installation, and the age of most stations within the Eskom fleet where return on investment may not be realised. The recent improvement in the reliability of the fleet, allowing Eskom to adopt increased use of Despatch Prioritisation to reduce emissions, is due to a variety of reasons, although most critically the successful implementation of the Generation Recovery Programme. This programme was initiated in March 2023 focusing on specific projects targeting major and minor breakdowns and has improved the generating capacity at stations, allowing improved load management.

To limit emission loads Eskom will not run coal stations at maximum loads but will rather aim to limit the loads to only what is required for system adequacy making maximum use of other available energy sources for generation, resulting in less coal burnt. This reduction in load will result in a reduction in the levels of total emissions from Eskom into the atmosphere. Although the objective is to reduce SO<sub>2</sub> emissions, given the reduced coal burnt, NO<sub>x</sub> and PM emissions will also be positively impacted.

Although Despatch Prioritisation will lead to reduced emissions, it is noted this is based on other power generation sources being added to the grid, allowing Eskom to reduce loads overtime. The addition of these alternative generation sources is outside of Eskom's control, and therefore should these not materialise within anticipated timeframes or there is an increase in economic growth, to avoid constraining the economy and ensure continued grid stability and security of supply, in terms of national energy planning Eskom may be required to operate stations at higher loads with increased emissions.

## **5.2 LETHABO POWER STATION**

Eskom's predominant power generation technology is through using pulverised coal with approximately 90% of its current generating capacity coming in this form of power stations. One of the 14 coal-fired power stations is the Lethabo Power Station.

In terms of the IRP and the Eskom Consistent Data Set, coal-fired power stations are generally planned for decommissioning after 50 years of operation, although this can be subject to review based on plant conditions, financial requirements and security of supply requirements, although for the purposes of this application, a 50-year life is assumed. Lethabo's last generating unit was commissioned in 1990, with intended shutdown between FY2037 and FY2042, although this will require NERSA approval. Lethabo plays an important role in meeting Eskom's 2024 ERP, with various projects planned.

### **5.2.1 CURRENT STATION PERFORMANCE AND EMISSION LEVELS**

#### **Sulphur Dioxide**

Daily average SO<sub>2</sub> emissions between 2019 and 2024 was 1,856mg/Nm<sup>3</sup> (over-estimation as this includes upset conditions) remaining below the existing limit of 2,600mg/Nm<sup>3</sup>, with no exceedances of the daily average limit occurring in FY2023/24 during normal operations. Although the recorded average is compliant with the existing limit, this exceeds the new plant MES (1,000mg/Nm<sup>3</sup>). To achieve compliance with the MES, Lethabo will require FGD technology to abate SO<sub>2</sub>.

Variation in SO<sub>2</sub> emissions is mainly attributable to the quality of the coal received; a low sulphur content combined with the high ash content and low calorific value requires high coal throughput which exacerbates SO<sub>2</sub> emissions. Low grade coal means lower heating value and consequently more coal burnt to generate the same energy, higher ash content and consequently reducing combustion efficiency. Since the furnace was designed for a longer residence time, it increases SO<sub>2</sub> formation, resulting in increased emissions. Further, although Lethabo was designed to burn low grade coal, the design did not anticipate the requirement to reduce SO<sub>2</sub> emissions to the new plant MES limits due to the age of the plant (last unit commissioned in 1991) increasing the complexity and risk of any SO<sub>2</sub> reduction implementation.

### **Nitrogen Oxides**

During the period 2019 to 2024, Lethabo had managed a daily average concentration of 837mg/Nm<sup>3</sup> (over-estimation as this includes upset conditions) complying with the existing plant limit of 1,100mg/Nm<sup>3</sup>, although two exceedances of the daily average did occur in FY2023/24. While the average complied with the existing plant limit, complying with the new plant limit (750 mg/Nm<sup>3</sup>) can only be achieved through a NO<sub>x</sub> upgrade retrofit [(LNB, LNB and Over Fire Air (OFA), Selective Catalytic Reduction (SCR) or Selective Non-Catalytic Reduction (SNCR)].

### **Particulate Matter**

During the period 2019 to 2024, Lethabo had managed a daily average concentration of 101mg/Nm<sup>3</sup>, exceeding the existing plant limit of 100mg/Nm<sup>3</sup>, although it is noted this daily average includes upset conditions which are not regulated by the limit, so is therefore an over-estimation of the average. Further, 39 daily average exceedances of the existing limit were recorded between 1 April 2022 – 31 March 2024 (FY2023/24), with a further 29 exceedances of the daily limit (during normal operating conditions) occurring since 1 April 2024.

Elevated emissions on most generating units were due to various breakdowns and the need to execute the planned abatement projects is critical. Breakdowns during this period, impacting emissions, related to the DHP, SO<sub>3</sub> plant issues, and ESP optimisation challenges.

Further, planned maintenance according to the outage philosophy were disrupted by the unfortunate low energy availability in the grid, with Lethabo being one of the stations required to supplement the shortfall on the grid. This disruption delayed the required remedial actions to improve the abatement plant performance, thereby impacting emissions further. Fortunately, the context has changed because the capacity outlook has changed following the successful implementation of the Generation Recovery Programme. The improved reliability of the fleet has enabled the execution of the maintenance strategy, which will result in an improvement in abatement performance, positively impacting emissions.

## 5.2.2 EMISSION REDUCTION PROJECTS AND TIMELINES

### Sulphur Dioxide

Various investigations were undertaken of the different SO<sub>2</sub> reduction technologies that are operating successfully in the field, all of which were taken through a qualitative technology evaluation undertaken by Eskom. The criteria selected for the evaluation facilitated a process of screening which of the technologies are feasible for recommendation for the Eskom Fleet. The basis of the evaluation considered reagent availability in South Africa, the maturity of the technology, technology performance (removal efficiency), and complexity of the retrofit.

Of the technologies investigated, the semi-dry FGD was identified as the most appropriate for Lethabo. However, Eskom has consistently indicated in its postponement applications that given the age of the Lethabo plant and reaching end of life, cost and complexity of implementation, and the general compliance of ambient SO<sub>2</sub> concentrations in the area, that implementation of any SO<sub>2</sub> reduction technology is not feasible and therefore has not undertaken further detailed planning to install SO<sub>2</sub> reduction technology.

Assuming Eskom was required now to implement SO<sub>2</sub> semi-dry FGD, construction and installation of this could only start in 2031 as concept and design have not commenced, with execution taking five to six years to complete on all generating units. A best-case completion date of 2035 would be achieved considering the project milestones, with Lethabo entering shutdown phase from 2036. Given the costs to install and operate FGD (discussed further in Section 5.6) and considering this would only be fully complete one to two years before shutdown phase commences (Lethabo reaching end of life), and therefore well before return on investment (ROI) is realised, Eskom considers it not practically feasible or beneficial to South Africa.

Lethabo cannot reach the new plant SO<sub>2</sub> MES without FGD or similar SO<sub>2</sub> abatement, therefore, to reduce SO<sub>2</sub> emissions, although not to MES compliance, Lethabo is planning:

- Despatch Prioritisation, based on future anticipated loads considering the current IRP and Eskom production plans. Despatch Prioritisation will also positively impact PM and NO<sub>x</sub> emissions.
- Efficiency improvements to optimise the air-to-fuel ratio which should abate some SO<sub>2</sub> emissions and maximise combustion efficiency. This requires in part, ensuring optimal mill firing configuration and design level pulverised fuel (PF) particle size distribution.

Should the anticipated additional capacity projections of the IRP be delayed, on which Eskom has determined future load requirements, resulting in the need for higher loads to meet electricity demand, Eskom's planned Despatch Prioritisation may not have the anticipated impact on emissions.

### Nitrogen Oxides

Regarding NO<sub>x</sub>, various options were investigated to abate NO<sub>x</sub> from which LNB was selected as the preferred option. From the simulation models, it was identified that retrofitting the LNB has inherent complications like flame stability and managing the temperature profile inside the furnace, potentially impacting emissions. The simulation modelling that was done will aid Eskom in mitigating these risks and designing the burners to overcome these drawbacks.

Lethabo have initiated the NO<sub>x</sub> reduction project, with this currently in Concept Release Approval (CRA) phase and is considering the retrofitting of LNB with or without OFA. The project execution will

commence in FY2027, with completion by FY2031. Following completion of the NO<sub>x</sub> reduction project, Lethabo will comply with the new plant NO<sub>x</sub> MES.

### **Particulate Matter**

Various abatement technology upgrades and/or improvements are proposed for Lethabo to address PM emissions comprising the new HFPS, ESP upgrades, refurbishment of the SO<sub>3</sub> plant and to return the DHP to its designed operating levels.

The Lethabo ESP was designed to cater for the significant ash burden from the inherently low-grade coal supplied by Seriti's New Vaal Colliery; despite this design, low-grade coal with high ash content still leads to high gas volumes and increased emissions. ESP performance has deteriorated due to various reasons, such as:

- The high ash resistivity that inhibits collection efficiency. SO<sub>3</sub> is injected into the flue gas stream to reduce the high fly ash resistivity.
- Coupled with the high gas volume is the higher-than-normal gas outlet temperatures, impacting ESP performance. The secondary air heater is part of the efficiency improvement projects covered in the generation recovery projects.

Extensive downtime is required to address the ESP deterioration. Eskom has initiated projects to restore the electric field performance and enhance the collection efficiency of the internal components through the ESP upgrade. To comply with the new plant PM limits (50 mg/Nm<sup>3</sup>), the following projects are in execution at Lethabo: the ESPs are being refurbished and are also retrofitted with HFPS to increase the level of collection of dust particles and sustain a longer charge in the ESP. The HFPS was introduced after numerous pilot tests, both internationally and locally, which provided results to support the implementation of this technology. Lethabo has commenced with a project to replace the SO<sub>3</sub> plant to improve the fly ash resistivity considering the high ash loading, the high back-end flue gas temperatures and to improve the reliability of the SO<sub>3</sub> plant. PM emission reduction projects are progressing; however, several units will only be completed after March 2025. The status of the projects are as follows:

- ESP Upgrades:
  - Unit 6 is complete. Unit (U) 3 has commenced in September 2024 and U2 is planned to start in February 2025. U1, U4 and U5 will only have the upgrade completed beyond March 2025 (U5 in August 2025, U4 in January 2026, and U1 in August 2026), with the delay due to commercial and procurement processes and the outage schedules.
- HFPS installations:
  - All six units have been installed, with the last unit completed in July 2024 (U6).
- SO<sub>3</sub> Plant upgrades
  - Upgrades on U1, U4 and U6 are complete. U3 is currently on outage and should be complete by February 2025. U2 will commence when U3 returns to service, while U5 will be completed during the outage starting August 2025.
- Through the execution of the generation recovery projects, and the focus on improvement of process components of the generating units, various projects are planned:
  - Improving combustion through improvements of the milling plant, ensuring that the pulverised fuel fineness is within the required specifications.
  - The DHP performance is restored to its design levels, which plays a significant role in removing dust particles collected by the ESP. The DHP removal rate is critical; if the hoppers are not



emptied at the optimum rate, the station will be negatively impacted by the re-entrainment of dust, caused by the dust hoppers filling to capacity and the draught returning the collected dust back into the stream, which is counterproductive.

With the upgrade of the ESP, the installation of the HFPS, the DHP restoration, and the upgrade of the SO<sub>3</sub> Plant, it is envisaged that the intermittent breakdowns experienced at Lethabo will be resolved which will improve plant performance leading to reduced PM emissions.

Completion of individual projects does not guarantee compliance to the new plant emission limits until all the upgrade interventions are completed on each unit. This is primarily due to the age of Lethabo, the high ash content in the coal, and the rate at which optimum levels of the new technology will be achieved. The new technology is reliant on Maintenance and Operating to execute all the first line activities at the highest levels. These first line activities include conducting regular plant checks as per the preventative maintenance schedules, monitoring and timeously reporting irregular conditions to the relevant department.

Following the implementation of the above-mentioned interventions and subsequent optimisation, Lethabo would be able to achieve compliance with the new plant PM MES. Despatch Prioritisation, initiated to address SO<sub>2</sub> emissions, also presents further opportunity to reduce PM emissions.

### **5.2.3 EMISSION REDUCTION TRAJECTORY**

As discussed previously, various initiatives are underway and/or planned to further mitigate emissions at Lethabo. While these initiatives will impact Lethabo emissions positively, they cannot be considered in isolation from the total Eskom Fleet emissions. Given this, and the intent of Eskom to make a fleet exemption application, Eskom considered various emission reduction scenarios (ERP alternatives) based on present planning assumptions considering the various abatement initiatives undertaken, planned or being evaluated, energy demand, station shutdowns, and the positive impact of Despatch Prioritisation. No detailed stochastic energy systems analysis, such as is done for the Integrated Resource Plan (IRP), was completed for this exemption application process given time constraints. The energy projections used for the ERP alternatives were based on presently available planning assumptions and Eskom internal projections. Considering security of supply, a fourth emission projection was included, representing an upper emission limit projection based on more conservative assumptions than the original ERP alternatives with the aim to ensure security of electricity supply in the absence of any stochastic energy system analysis is provided. The trajectories considered comprised:

- ERP 2024 A (PM and NO<sub>x</sub> reduction, Despatch Prioritisation strategy, efficiency improvements, and SO<sub>2</sub> abatement at Medupi and Kusile), representing Eskom's planned projection.
- ERP 2024 B (As per ERP 2024 A plus SO<sub>2</sub> reduction technology installed at Majuba and Kendal), representing a projection, that with additional guarantees and strategic decisions, could be achieved.
- ERP 2024 C (As per ERP 2024 A and B, plus SO<sub>2</sub> reduction technology at Lethabo and Tutuka), representing a projection that would require substantial guarantees and considerations of the significant financial impacts, such as on electricity tariffs.
- Eskom's Security of Supply Projection developed using conservative assumptions such as higher electricity demands due to a growing economy, a delay in IPP projects, and a delay in Kusile U6 generating unit coming online.



Each ERP alternative emission trajectory considered, as well as the Security of Supply trajectory, and abatement projects linked to each are illustrated and discussed in the following sections. These sections consider a 2025 baseline for comparative purposes which better represents Eskom's current performance in meeting national demand as opposed to 2019, when loadshedding was in place, constraining the economy and reducing demand. While the below sections refer to requested exemptions, the motivations for these exemptions are provided in Chapter 7 of this report. For the following sections, it is assumed that the proposed FGD retrofit type (where applicable) on a 'six-pack' power station has proven to be technically feasible, notwithstanding that it would be a world-first.


### 5.2.3.1 Sulphur Dioxide

As noted previously, scenario ERP 2024 A assumed only the FGD installation at Kusile and Medupi (completion in 2032), with no other stations receiving SO<sub>2</sub> abatement technology. Scenario ERP 2024 B assumed SO<sub>2</sub> abatement installations at Kusile, Medupi, Kendal, and Majuba, representing a potentially practical option with certain considerations, if proven to be technically feasible. Scenario ERP 2024 C assumed SO<sub>2</sub> abatement installed at Kusile, Matimba, Medupi, Kendal, Majuba, Lethabo, and Tutuka (Matla and Duvha were not given FGD as it cannot be practically installed given their shutdown before 2035).

As illustrated in Figure 5-2, all three scenarios remain similar until FY2032, when the Majuba DSI FGD takes effect, followed by the Kendal FGD, resulting in ERP 2024 B and ERP 2024 C having lower emissions than ERP 2024 A. In FY2036, ERP 2024 C reduces further due to a combination of SO<sub>2</sub> abatement technology at Matimba, Lethabo and Tutuka, and assumed completion of the Duvha and Matla shutdowns. While actual emissions show a reduction from ERP 2024 A to ERP 2024 B and C, considering the cumulative Highveld and Vaal dispersion modelling predictions at receptors, ERP 2024 A, which only assumes SO<sub>2</sub> abatement at Kusile, still shows full MES compliance, without abatement at Kendal and Majuba. The modelling predictions show ERP 2024 B, which assumes Kendal and Majuba abatement, have slightly lower ambient concentrations than ERP 2024 A, while these reduce further for ERP 2024 C, although crucially all modelling scenarios predict full MES compliance (discussed further in Chapter 6).

Considering ERP 2024 A, by FY2030, compared to FY2025 (actuals), Eskom Fleet SO<sub>2</sub> emissions are anticipated to have reduced by 555kt, representing a 32% reduction in emissions. In FY2035, compared to FY2030, a further reduction of 165kt (14%) is anticipated, and by FY2040 a further 6% reduction is anticipated. Between FY2025 and FY2050, a total SO<sub>2</sub> emissions reduction of 85% (1.45Mt) is estimated.

Regarding Eskom's Security of Supply projection, representing an upper emissions limit, emissions increase to FY2026, remaining above the ERP 2024 A, B, and C projections, although by FY2030 shows a 482kt (27%) reduction and is more closely aligned with the ERP projections. By FY2035, the Security of Supply projection shows a further reduction of 294kt (23%) and aligns more closely with the ERP projections, and from FY2036 shows closer alignment until FY2050. Crucially, although this is an upper emissions projection, the same trend of emission reductions year on year is evident from FY2026.




**Figure 5-2 - Eskom Fleet sulphur dioxide emission trajectories**

### 5.2.3.2 Oxides of Nitrogen

NO<sub>x</sub> emission trajectories associated with ERP 2024 A, ERP 2024 B, ERP 2024 C and the Security of Supply are illustrated in Figure 5-3. All Scenario's ERP 2024 A, ERP 2024 B, and ERP 2024 C assume the same NO<sub>x</sub> abatement installed; that is LNBs at Tutuka, Majuba, and Lethabo, therefore the emission trajectory for each is the same, while the Security of Supply includes this abatement this is based on an increased electricity demand.

From FY2025, emissions are anticipated to reduce in the coming years due to the burner efficiency improvement projects, Despatch Prioritisation initiated to address SO<sub>2</sub> emissions, station shutdowns assumed to be complete by FY2030 (Grootvlei, Camden, Hendrina, Arnot, and Kriel), Duvha and Matla assumed to be entering shutdown phase in FY2031, and the completion of the LNB abatement on Tutuka (FY2029), Majuba (FY2030), and Lethabo (FY2031). By FY2030, compared to FY2025 (actuals), Eskom Fleet NO<sub>x</sub> emissions are anticipated to have reduced by 292kt, representing a 40% reduction. Emissions remain stable until FY2041, after which further reductions will occur due to stations entering shutdown. Between FY2025 and FY2050, a total NO<sub>x</sub> emissions reduction of 78% (574kt) is estimated.

Considering Eskom's Security of Supply projection, representing an upper emissions limit, emissions increase to FY2026, remaining above the ERP 2024 A, B, and C projections, given the conservativeness of the Security of Supply projection, although by FY2030 shows a 256kt (33%) reduction and is more closely aligned with the ERP projections. By FY2035, a further 151kt (29%) reduction is estimated and aligns more closely with the ERP projections and shows closer alignment until FY2041. As noted, although this is an upper emissions projection, the same trend of emission reductions year on year is evident from FY2026.




**Figure 5-3 - Eskom Fleet oxides of nitrogen emission trajectories**

### 5.2.3.3 Particulate Matter

PM emission trajectories associated with ERP 2024 A, ERP 2024 B, ERP 2024 C and the Security of Supply are illustrated in Figure 5-4. As noted, all alternatives considered the same PM abatement installed at Tutuka, Matla, Duvha, Kendal, Lethabo, and Matimba, so have the same trajectories, while the Security of Supply trajectory includes these projects as well as increased generation to meet demand assumptions.

From FY2025, emissions are anticipated to reduce sharply until FY2028 due to the PM abatement projects at Tutuka, Matla, Duvha, Kendal and Lethabo, as well as the progression of the assumed shutdown phases at Grootvlei, Hendrina, Arnot, Kriel, and Camden. From FY2030, PM emissions remain consistently low, showing further reductions from FY2040 due to stations assumed to be entering shutdown phases. By FY2030, compared to FY2025 (actuals), Eskom Fleet PM emissions are anticipated to have reduced by 65kt, representing a 74% reduction, after which emissions will gradually reduce as stations enter shutdown. Between FY2025 and FY2050, a total PM emissions reduction of 94% (82kt) is estimated.

Considering Eskom's Security of Supply projection, representing an upper emissions limit, emissions show a similar trend to the ERP projections, although are marginally higher between FY2026 to FY2030 due to the conservativeness of this projection. By FY2030, a PM reduction of 64kt (71%) is estimated, with a further reduction by FY2035 of 6.5kt (25%). As noted, this is an upper emissions projection, the same trend of emission reductions year on year is evident from FY2026.



**Figure 5-4 - Eskom Fleet particulate matter trajectories**

### 5.2.3.4 Establishment of an Emission Reduction Trajectory

The scenarios described above have referred to emission reduction trajectory in terms of PM, NO<sub>x</sub> and SO<sub>2</sub>. With scenario ERP 2024 A showing emission reductions by FY2030 for PM (65kt), NO<sub>x</sub> (292kt), and SO<sub>2</sub> (555kt), while the Eskom security of supply projection also shows reductions by FY2030 for PM (64kt), NO<sub>x</sub> (256kt) and SO<sub>2</sub> (482kt). While the MES and climate change regulatory process are legally separate it is useful to note both ERP 2024 A and the security of supply projection are aligned with Eskom's current pollution prevention plan running to December 2025. Future CO<sub>2</sub> trajectories will be based on the updated pollution prevention plan and IRP, NDC, and Sectorial Emission Targets (SET).

The Priority Area regulations and priority area plans refer to emission reduction targets, with the draft HPA plan indicating that industry should obtain a 40% reduction in total emissions by 2030 from a 2019 base. The emission reduction projections described above are based on the best available assessment of what Eskom is required to generate from coal stations in terms of the nationally driven IRP process and Eskom planning. Neither of these processes are static and they are influenced by a range of factors including economic growth rates, IPP production and national climate change commitments. If economic growth increases and there are substantive delays in the provision of non-coal-based generation then the Eskom coal fleet may be asked to ensure security of supply which will result in an increase in emissions above the trajectories predicted in this application. As such Eskom believes it would be inappropriate for the setting of specific legally binding emission reduction targets at either a fleet or station level and request exemption from any such requirements where they are enforced through air quality related legal mechanisms.

### 5.2.4 LETHABO PROPOSED EMISSION LIMITS

As contained within Lethabo's AEL (ref. no. FDDM-MET-2011-08-P1), Lethabo is required to meet the following MES concentration limits:

- Particulate matter:
  - As per the AEL 50mg/Nm<sup>3</sup> current, and post 1 April 2025, although as per Lethabo's postponement application the limit requested is 100 mg/Nm<sup>3</sup>.
- Oxides of nitrogen:
  - 1,100mg/Nm<sup>3</sup> current, and 750mg/Nm<sup>3</sup> post 1 April 2025
- Sulphur dioxide:

- 2,600mg/Nm<sup>3</sup> current, and 1,000mg/Nm<sup>3</sup> post 1 April 2025. It is noted the AEL currently indicates 500mg/Nm<sup>3</sup>, however according to the MES amendment (GNR 1207, 2018), existing plants are to comply with a new plant MES of 1,000mg/Nm<sup>3</sup>.

Considering Lethabo's planned abatement project schedule, and that these projects will not be complete before 1 April 2025 (for PM and NO<sub>x</sub>) due to long lead times associated with manufacturing and installations, Lethabo is requesting exemption from the above MES concentration limits until the committed emission abatement projects are completed. Further, since it is not feasible to install FGD at Lethabo, as presented herein, Lethabo is requesting exemption from the new plant SO<sub>2</sub> MES until shutdown.

While Eskom recognise the importance of pollution concentrations in a stack, of equal importance is the total mass of pollutants emitted from a stack which are directly related to environmental impacts. As presented in Section 5.2.3, Eskom's cumulative mass of pollutants emitted show decreases between FY2025 – FY2050. The dispersion model considered Eskom's anticipated loads and associated emissions, on average, so modelled concentrations are lower than the limits requested herein. The limits requested by Eskom will allow for increased loads according to demand, however as indicated in Section 5.2.3. Eskom's total mass of emissions is anticipated to decline year on year.

Table 5-2 presents Lethabo's requested emission limits, applicable to normal operating conditions, so excluding start-up or shutdown, upset conditions and maintenance periods. Key considerations to the requested concentration limits include:

- Particulate matter:
  - Although not solely due to Eskom, Eskom recognises measured ambient PM concentrations in the Highveld/Vaal are non-compliant with the NAAQS, requiring specific focus, Eskom is requesting exemption from immediately complying with the MES. Eskom will reach MES compliance once the PM abatement upgrades are complete.
  - Cumulatively, the Eskom Fleet shows substantial reductions in PM emissions, as presented previously.
  - Although ambient measured concentrations show non-compliance with the NAAQS in the Highveld/Vaal, according to the cumulative dispersion modelling results (discussed in Section 6.1 of this report), the Eskom Fleet's contributions to the PM<sub>10</sub> annual averages are below the NAAQS at receptors, although annual average PM<sub>2.5</sub> contributions exceed the annual NAAQS. While non-compliant 24-hour concentrations are predicted, these are predominantly related to the fugitive sources (ash dumps), rather than the stack emissions themselves, as noted in the cumulative AIR. Further, the conservative assumptions made in the modelling simulations also need to be considered.
- Oxides of nitrogen:
  - As noted previously, ambient NO<sub>2</sub> concentrations in the Highveld/Vaal are low, below the NO<sub>2</sub> NAAQS.
  - Cumulatively, the Eskom Fleet shows substantial reductions in NO<sub>x</sub> emissions, as presented previously.
  - According to the cumulative dispersion modelling (Section 6.1), ground-level NO<sub>2</sub> concentrations due to the Eskom Fleet emissions, under all modelling scenarios, were extremely low for both the annual and hourly averages, remaining well below the NAAQS, with no hourly exceedances predicted.

- Although existing measured ambient NO<sub>2</sub> concentrations are low, and predicted contributions from the Eskom Fleet are also low, Eskom still recognises the importance to reduce NO<sub>2</sub> emissions at Lethabo and will therefore be installing LNBs.
- Sulphur dioxide:
  - Measured ambient SO<sub>2</sub> concentrations comply with the NAAQS in the Highveld/Vaal area.
  - Cumulatively, the Eskom Fleet shows substantial reductions in SO<sub>2</sub> emissions, as presented previously.
  - According to the dispersion modelling (Section 6.1), ground-level SO<sub>2</sub> concentrations due to the Eskom Fleet emissions, under all modelling scenarios, were low for both the annual, 24-hour and hourly averages, remaining below the NAAQS at all receptors.
  - Existing ambient SO<sub>2</sub> concentrations and the ground-level concentration contributions from the Eskom Fleet comply with the NAAQS, and since it is not economically feasible to install SO<sub>2</sub> abatement at Lethabo, Lethabo will manage SO<sub>2</sub> emissions through Despatch Prioritisation and efficiency improvements.

This exemption application, and emission limits requested herein, are accepted as the emission targets for Eskom in terms of the Priority Area Plans.

**Table 5-2 - Emission limits requested for Lethabo**

POINT SOURCE CODE	POLLUTANT	MAXIMUM RELEASE RATE*			DURATION OF EMISSIONS
		mg/Nm <sup>3</sup>	Average Period	Date To Be Achieved	
U1, U2, U3, U4, U5, U6	SO <sub>2</sub>	2,600 mg/Nm <sup>3</sup>	Daily	Immediate - shutdown	Continuous
	NO <sub>x</sub>	1,100 mg/Nm <sup>3</sup>	Daily	Immediate	Continuous
		750 mg/Nm <sup>3</sup>	Daily	1 April 2031	Continuous
U6	PM	100 mg/Nm <sup>3</sup>	Daily	Immediate	Continuous
		50 mg/Nm <sup>3</sup>	Daily	1 April 2025	Continuous
U2, U3	PM	100 mg/Nm <sup>3</sup>	Daily	Immediate	Continuous
		50 mg/Nm <sup>3</sup>	Daily	1 April 2026	Continuous
U5	PM	100 mg/Nm <sup>3</sup>	Daily	Immediate	Continuous
		50 mg/Nm <sup>3</sup>	Daily	1 October 2026	Continuous
U4	PM	100 mg/Nm <sup>3</sup>	Daily	Immediate	Continuous
		50 mg/Nm <sup>3</sup>	Daily	1 April 2027	Continuous
U1	PM	100 mg/Nm <sup>3</sup>	Daily	Immediate	Continuous
		50 mg/Nm <sup>3</sup>	Daily	1 October 2027	Continuous

\*Emission limits requested are for normal operations, so excludes upset, startup, shutdown, or maintenance conditions.



### 5.2.5 COSTS TO REACH MES COMPLIANCE

As noted previously, Semi-dry FGD is the most suitable technology for Lethabo, but Eskom finds it unfeasible due to the plant's age, costs, and compliance with ambient SO<sub>2</sub> levels. If required to implement it now, construction could start in 2031, with completion by 2035 and assumed shutdown by 2036. Certainty around cost is only reached once the contract has been awarded and will be accurate to within 90%.

Currently, and based on FY2023/24, the projects already approved for Lethabo comprise:

- Low NO<sub>x</sub> Burners (NO<sub>x</sub> compliance):
  - Capex ≈ R4.4 billion
- ESP/HFPS/DHP/SO<sub>3</sub> (PM compliance):
  - Capex ≈ R2.6 billion

In the Lethabo case, currently in the CRA approval stage, the costs for the LNB are based on averages benchmarked against international project data for similar technologies and are based on a Class 5 cost estimate which is accurate to a factor of two.

Should SO<sub>2</sub> MES compliance be enforced at Lethabo, the semi-dry FGD costing is based on Medupi costing. However, critically, Medupi is FGD ready, and all due consideration was taken when its costing was conducted. With a brownfield project like Lethabo, a site characterisation would be required which could potentially increase estimated costs. Compliance with the SO<sub>2</sub> MES at Lethabo would require an FGD retrofit, at an estimated Capex of R40 billion and Opex of R1,04 billion.

## 5.3 ESKOM AIR QUALITY OFFSETS

According to the *Air Quality Offsets Guideline (Government Gazette No. 39833 of March 2016)* (hereafter referred to as 'the Air Quality Offsets Guideline'): "In the air quality context, an offset is an intervention, or interventions, specifically implemented to counterbalance the adverse and residual environmental impact of atmospheric emissions in order to deliver a net ambient air quality benefit within, but not limited to, the affected airshed where ambient air quality standards are being or have the potential to be exceeded and whereby opportunities and need for offsetting exist." (Republic of South Africa, National Environmental Management: Air Quality Act, 2004 9Act No.39 of 2004), Air Quality Offsets Guideline., Air Quality Offsets Guideline, 2016)

Whilst Eskom continues to persevere in improving ambient air quality through the reduction of emissions in the existing coal-fired fleet, retrofitting abatement technology and diversifying the energy fleet is extremely costly. This can potentially impact all of South Africa, while also taking a long time to implement. Air quality offsets (AQOs) afford the opportunity to address emission sources directly within vulnerable communities, and to target greater improvement in community-experienced air quality than is achievable from other approaches. Such offsets are more cost-effective and can result in meaningful improvements in air quality within a shorter period.

Eskom embarked on their first AQO programme in 2016, following the National Air Quality Officer's decision that each power station must develop and implement an offset programme targeting particulate matter (PM<sub>10</sub> and PM<sub>2.5</sub>) concentration reduction in the ambient environment. Eskom's first AQO Plans, initially submitted for the Nkangala District Municipality, Gert Sibande District Municipality, and Lethabo Power Station, were approved by the National Air Quality Officer, together with the relevant Atmospheric Emission Licensing authorities, in September 2016. These were later updated and resubmitted in April 2021, with updates provided annually. Eskom's AQO Plans cover the period April 2016 to March 2025.

### 5.3.1 ESKOM'S AIR QUALITY OFFSET JOURNEY

Eskom initiated their first AQO initiative in 2011 with a pre-feasibility study to identify potential strategies to best meet the offset requirements of their Atmospheric Emissions Licenses (AELs). Several initiative implementation trials took place in Kwazamokuhle (a township near Hendrina Power Station, Mpumalanga) from 2013 to 2017, before Eskom's 2016/2017 Offset Implementation Programme was finally formulated. Interventions within the programme target domestic fuel burning for heating and cooking in the Highveld region, particularly Kwazamokuhle and Ezamokuhle, whilst interventions target both domestic fuel burning and domestic waste burning in the Vaal. Presently, the AQO Plans are being executed in stages across various communities in proximity to Eskom coal-fired power stations in both the Highveld and Vaal regions.

Table 5-3 outlines the main interventions completed and planned as part of Eskom's AQO Programme (Eskom, 2024).

**Table 5-3 - Implemented Air Quality Offset Interventions**


Phase	Power station	Settlement	No of Houses	Start	End	Comments
Phase 1	Hendrina	Kwazamokuhle	3700	2021	2024	Completed
	Majuba	Ezamokuhle	2100	2021	2024	Completed
	Lethabo	Sharpeville		2021	2024	Completed
Phase 2a	Tutuka	Sivukile	1160	April 2024	Dec 2025	Contract terminated. Tender to be reissued
	Kendal	Phola	66073	Nov 2024	Oct 2029	In the procurement phase – Contract being negotiated.
Phase 2b	Matla	Emzimnoni	3440	April 2025	Mar 2030	Budget secured. In the procurement phase.
	Duvha	Masakhane	886	April 2025	Mar 2030	Budget secured. In the procurement phase.
	Kriel	Thubelihle	2390	April 2025	Mar 2030	Budget secured. In the procurement phase.
	Arnot	Silobela	2003	April 2025	Mar 2030	Budget secured. In the procurement phase.
	Lethabo	Refengkotso	500	April 2025	Mar 2030	Budget secured. In the procurement phase.
	Lethabo	Boitshepiville	N/A	April 2025	Mar 2030	Budget secured. In the procurement phase.
Phase 2c	Camden	New Ermelo	935	Sept 2025	Aug 2030	Budget approval outstanding
	Grootvlei	Grootvlei village/Ntorwane	2000	Sept 2025	Aug 2030	Budget approval outstanding
	Camden	Nederland	1660	Sept 2025	Aug 2030	Budget approval outstanding
	Duvha	eMalahleni	2000	Sept 2025	Aug 2030	Budget approval outstanding

### 5.3.2 AIR QUALITY OFFSET IMPACT ASSESSMENT

The effectiveness of Eskom's AQO Plans depend on how well the interventions are planned, monitored and verified. Eskom has a Planning, Monitoring and Verification (PMV) contractor, to provide PMV services for Phase 1 of Eskom's AQO Plan at Kwazamokuhle, Ezamokuhle and

Sharpeville. Three key indicators will be monitored before, during and after offset implementation, namely the state of ambient air, emissions and quality of life (Air Resource Management (ARM), 2024). Over every monitoring period, the AQO project scenario (as it took place) will be compared to a credible baseline scenario (i.e., the situation that would have been the case if the project were not implemented). The principal indicator of success of the intervention will be related to a change in exposure to air pollution and nett emissions avoided because of Eskom's AQO interventions. For the case of Eskom's Lethabo AQO Plan, this will be expressed as a reduction in ambient concentrations of particulate matter, which is aligned with the "Outcome Based" Air Quality Offset Principal required under the *Air Quality Offset Guideline*. Various project effectiveness surveys have been completed in Ezamokuhle and Kwazamokuhle to assess the impact of Eskom's AQO interventions, as summarised below.

The calculated the net reduction in emissions associated with the AQO rollout in Kwazamokuhle and Ezamokuhle (approximately 4,255 households), which shows a notable reduction in annual PM<sub>10</sub> (132 tons), PM<sub>2.5</sub> (123 tons) annually, as well as CO, SO<sub>2</sub>, NO<sub>2</sub>, VOCs and methane emissions to air (Figure 5-5).



**Figure 5-5 - Total net reduction in emissions attributable to Eskom's Phase 1 AQO project (tonnes) for Ezamokuhle and Kwazamokuhle (Air Resource Management, 2024)**

Indoor PM<sub>10</sub> and PM<sub>2.5</sub> monitoring in participating households in Ezamokuhle showed a notable decrease in indoor pollution concentrations following the AQO interventions. Furthermore, data collected from questionnaires distributed to Kwazamokuhle's and Ezamokuhle's participating households showed that 84% and 85%, respectively, of respondents were completely satisfied with the intervention, as it improved their quality of life (Eskom, Progress Report, March 2024). Although post-intervention monitoring and surveys have not yet been completed for Sharpeville, this is planned to commence in 2025. One of the key short-term activities is to quantify the air quality impact of Eskom's AQO waste intervention at Sharpeville. Eskom have quantified the air quality impact of AQO waste interventions at Sharpeville by calculating the nett emissions avoided and developing an air

dispersion model. The net emissions avoided associated with the first three clean-up campaigns show the greatest potential reduction is of PM<sub>10</sub> (16,01 tons) and PM<sub>2.5</sub> (15,96 tons), with notable reductions in potential NO<sub>2</sub> (3,32 tons) and SO<sub>2</sub> (0,33 tons) emissions also observed. Results of the dispersion modelling exercise show the potential air quality improvement due to emissions reduction, with the predicted short-term maximum ambient air quality improvements provided in Table 5-4.

**Table 5-4 - Potential improvement in ambient air quality due to Eskom's Sharpeville AQO Project (Air Resource Management (ARM), 2024)**

MODEL POLLUTANT MAXIMUM CONCENTRATION (µG/M <sup>3</sup> )							
Pollutant	PM <sub>10</sub>		PM <sub>2.5</sub>		SO <sub>2</sub>		NO <sub>2</sub>
Averaging Period	1-hour	24-hour	1-hour	24-hour	1-hour	24-hour	1-hour
Campaign 1	19.1	2.4	19.1	2.3	0.4	0.1	2.1
Campaign 2	33.9	4.4	33.8	4.4	0.6	0.1	3.5
Campaign 3	278	28.9	277.5	28.8	5.6	0.6	28.6

Further PMV activities and studies are needed to understand the improvement in ambient air quality as a result of the AQO interventions. These studies are in the pipeline for completion over short-term (0-3 months), medium-term (3-6 months) and long-term (>6 months) as per *the Eskom AQO Plans: Progress Report March 2024* (Air Resource Management (ARM), 2024).

### 5.3.3 LETHABO'S AIR QUALITY OFFSETS PROGRAMME

To date, much of Eskom's offset interventions have focused on local communities within the Mpumalanga Highveld, where domestic fuel burning is still prevalent, and therefore household fuel burning emission offsets offer the greatest potential for air quality improvement. However, over the past decade, domestic coal burning in the Vaal is much less prominent, and it is estimated that approximately 35% of households in lower income areas use coal for cooking and heating (compared to 50-70% of households in lower income areas in Mpumalanga). As such, Eskom has identified waste burning as another AQO opportunity for emissions reduction, given that it is a significant source of local emissions in many settlements in the Vaal. Presently, interventions are being planned and implemented as part of Eskom's Lethabo AQO plan to reduce domestic fuel and waste burning emissions, and ultimately, the contribution to ambient particulate concentrations in the Vaal. A summary of works completed and works proposed is provided below based on data provided in Eskom's *Air Quality Offset Implementation Plans for Lethabo Power Station: March 2021 Update* (Eskom, 2021), and ARM's *Offsets Research: Proposal for the expansion of Eskom's AQO Program in the Highveld and Vaal* (October 2024).

As part of Eskom's 2016/2017 OIP, Lethabo's AQO Programme began with a phased approach to rolling out initiatives in settlements near the power station (Table 5-5). The primary target of Phase 1 is to remove illegal waste dumps and conduct cleanup campaigns to prevent emissions to air from uncontrolled domestic waste burning. The first phase was piloted in Sharpeville, with plans to extend AQO interventions to Tshepiso and Boipatong in Phase 2, and Refengkotso in Phase 3 (Eskom, ENV21-R053, 2021). Targeting domestic waste burning remains the key intervention strategy for Tshepiso and Boipatong in Phase 2, however, preliminary investigations show that targeting both domestic fuel burning, and domestic waste burning would be the most effective approach for

emissions reduction at Refengkotso (Phase 3). Following ARM's offset research, it is estimated that an additional waste removal volume of 9,035m<sup>3</sup> could be achieved within the selected communities, as part of Eskom's potential expansion of their AQO programme.

**Table 5-5 - Selected Areas and associated Air Quality Offset Interventions (Air Resource Management (ARM), 2024)**

Area	Implementation Phase	Timescales	Eskom 2016/2017 OIP	Potential Expansion of Eskom's AQO Programme
Sharpeville	Phase 1 & Phase 2	April 2022 – September 2024 & January 2023 – March 2028	Six cleanup campaigns completed	9,035m <sup>3</sup> of waste to be removed
Tshepiso	Phase 2	January 2023 – March 2028	Proposed cleanup campaigns	9,035m <sup>3</sup> of waste to be removed
Boipatong	Phase 2	January 2023 – March 2028	Proposed cleanup campaigns	9,035m <sup>3</sup> of waste to be removed
Refengkotso	Phase 2 & Phase 3	By 2030	Proposed cleanup campaigns and household interventions	9,035m <sup>3</sup> of waste to be removed

**Projects in development:** Given the potential role that offset play in improving air quality Eskom has undertaken a review of its present interventions with the objective of optimising for increased air quality improvements and impact. The recent literature reviews and high-level desktop feasibility analyses conducted by ARM, there is evidence to support the current suite of AQO interventions currently proposed and being rolled out by Eskom. As such, it was recommended that Eskom continue with the current AQO interventions for both domestic fuel burning and domestic waste burning, although a few improvements to the current rollout were which will be evaluated by Eskom.

Furthermore, additional AQO opportunities for Eskom to consider, should the outcomes of the relevant feasibility studies show that they can be effectively and affordably realised in practice were identified, this includes:

- “Implementing dust suppression/solutions of unpaved roads in low-income settlements;
- Implementing veld fire management solutions;
- Eskom evaluates the feasibility of mini and micro grids in appropriate locations; and
- Eskom in conjunction with local municipalities assess the potential for biogas generation from Waste and Sewage treatment plants”

Since this AQO Plan extends over multiple years, the proposed interventions cannot remain static but should evolve with changing technologies and community circumstances. A critical aspect of the AQO Plan is that offsets should address ambient air quality non-compliance, particularly non-compliance of the same pollutant that is emitted by the targeted opportunity for offset intervention. Several settlements identified based on Power Station impact are in semi-rural to rural areas. Eskom's existing AQO interventions have not been shown as practical for such areas and further investigation on options is underway (Eskom, 2021).



## 5.4 NATIONAL ELECTRICITY SUPPLY ISSUES

South Africa's electricity system has been strained over the past 10-12 years and was not able to provide sufficient power to meet demand due to breakdowns causing reduced capacity, and recurrent loadshedding had to be implemented to protect the system. The electricity crisis has been severely damaging to the South African economy, with no sectors untouched by these impacts. Mining and industry were severely impacted, with outputs reduced, resulting in a loss in investor confidence leading to postponed or cancelled investments into South Africa. Further, power outages led to impacts on quality of medical care, cold food chain storage facilities, failure of equipment in sanitation, bulk water, and sewerage facilities, to name a few. Outside of this, South African citizens experienced day to day difficulties, such as extended commutes to work due to power failures, increased crime due to lighting outages and lack of communications, and difficulties to prepare food.

The eventual objective of the energy policy is to reduce reliance on coal and to expand electricity generation through renewable and/or lower emission options, the reality of this unfortunately, is that the roll-out of these projects is not at the desired rate, with the South African power generation system remaining insecure. Importantly, and adding to the challenges of transitioning to renewables, is that 1GW of coal produces far more energy than 1GW of wind or solar PV. Therefore, much more solar or wind capacity is needed to produce the same amount of energy as coal combustion. To ensure adequate energy margin in the grid, to either start reducing the amount of coal burnt and/or allowing for the upgrading and retrofitting of abatement technologies, various initiatives will be required to ensure energy security is not jeopardised.

Eskom intends to align with the National Energy Crisis Committee (NECOM) Energy Action Plan of combining immediate solutions to address the energy gap, such as demand reduction, accelerating the building of generation and storage capacity, expanding and improving infrastructure, and 'fixing' Eskom. The sourcing of power (Independent Power Producers-IPP), an externality that Eskom has no control over but certainly welcomes, is a longer-term strategy that will aid in fast tracking the decommissioning of power plants reaching end of life. Since these processes are complex, involving multiple parties and stakeholders, the time for them to take effect is difficult to determine and plan.

The amount of electricity Eskom is required to supply is defined through the Integrated Resource Plan (IRP). A draft IRP was published on 4 January 2024 and an update of this plan is expected. For the modelling work undertaken for this application Eskom was informed by the draft IRP 2023 and its own production plan projections over the periods until 2030 and then beyond. Due to time constraints no specific energy system modelling exercise was completed for this application.

As indicated above there are a range of factors which impact on energy demand and security of supply nationally and in terms of what Eskom is required to deliver. Changes in these factors and the assumptions they create will impact on the requirement for Eskom generation and some of the impacts and assessments presented in this application. A review of this application in light of the revision of the IRP is recommended.



## 6 HEALTH & ENVIRONMENTAL IMPACTS

### 6.1 AIR QUALITY IMPACTS

#### 6.1.1 BASELINE AMBIENT AIR QUALITY MONITORING DATA


Ambient air quality monitoring stations in the Highveld and Vaal areas considered in this exemption application comprised Eskom owned stations and South African Weather Services (SAWS) stations, for the period 2021 - 2023. Although a minimum data recovery of 90% is required, as stipulated by the SANAS TR 07-03 (SANAS, 2012), for the purposes of this report, data recovery of 50% and greater were considered. Given the great distance that Eskom stack emissions are likely to disperse, and the cumulative impact this will have across the selected monitoring stations, all stations selected for the Highveld and Vaal areas are discussed, although station selection was based on proximity to each power station, as follows:

- Duvha – Masakhane (Eskom) and eMalahleni (SAWS)
- Kendal – Kendal K2 (research station) and Chicken Farm (both Eskom)
- Lethabo – Rand Water (Eskom), Sharpeville and Three Rivers (SAWS)
- Matla – Kriel Village (Eskom)
- Majuba – Majuba 1 (Eskom)
- Tutuka – Sivukile and Grootdraai Dam (both Eskom).


Figure 6-1 illustrates annual average  $PM_{10}$  concentrations and exceedances of the 24-hour average NAAQS measured in 2021 – 2023; no data was recovered at the Grootdraai Dam and Rand Water monitoring stations. As is evident, except for the annual average at Chicken Farm which remained compliant, ambient  $PM_{10}$  concentrations are non-compliant at all stations with both the annual and 24-hour NAAQS, with the frequency of 24-hour exceedances exceeding the permitted frequency of exceedances per calendar year (four exceedances are permitted per calendar year). Highest concentrations were measured at Kendal K2 (research station located at maximum point of impact for Kendal emissions), Three Rivers, Sharpeville and Kriel Village, with the highest occurrence of 24-hour average exceedances at Kendal K2.

Considering  $PM_{2.5}$  concentrations, as illustrated in Figure 6-2, similar to  $PM_{10}$ , non-compliance with the annual NAAQS is evident at the Kriel Village, Majuba 1, Masakhane, eMalahleni, Sharpeville and Three Rivers stations, with Kendal K2, Chicken Farm, and Rand Water showing compliance with the annual  $PM_{2.5}$  NAAQS. All stations measured frequent exceedances of the 24-hour NAAQS, while Rand Water, which was compliant with the annual NAAQS, showed non-compliance with the 24-hour NAAQS given the frequency of exceedances. Highest  $PM_{2.5}$  concentrations were measured at Three Rivers and Sharpeville, with no data recorded at Grootdraai Dam and Sivukile.

Given the elevated  $PM_{10}$  and  $PM_{2.5}$  concentrations throughout the Highveld and Vaal Triangle areas, the  $PM_{10}$  and  $PM_{2.5}$  NAAQS should be considered saturated, with these contributing emission sources requiring focus. Key sources of emissions in the area comprise mining, industrial activities, the Eskom power stations, vehicle emissions, uncontrolled waste burning, and domestic fuel burning.




**Figure 6-1 - Highveld and Vaal Triangle ambient PM<sub>10</sub> concentrations, 2021 – 2023**




**Figure 6-2 - Highveld and Vaal Triangle ambient PM<sub>2.5</sub> concentrations, 2021 – 2023**

SO<sub>2</sub> measured concentrations in the Highveld and Vaal Triangle for the period 2021 – 2023 are presented in Figure 6-3. Annual average concentrations across the ambient monitoring network indicate compliance with the annual NAAQS, with no stations exceeding the NAAQS in any year. Highest concentrations were typically measured at Sivukile, Kendal K2, and eMalahleni. Although not presented in Figure 6-3, exceedances of the short-term NAAQS (10-minute, hourly and 24-hour) were recorded at most stations, although importantly these remained below the permitted frequency of exceedances. Of these, Kendal K2 recorded the most short-term exceedances, with 199 10-minute, 49 hourly, and three 24-hour exceedances recorded in 2023. Importantly, these exceedances remain below the permitted exceedances, with 526 10-minute, 88 hourly, and four 24-hour average exceedances permitted per calendar year.



**Figure 6-3 - Highveld and Vaal Triangle ambient SO<sub>2</sub> concentrations, 2021 – 2023**

Nitrogen dioxide (NO<sub>2</sub>) measured concentrations in the Highveld and Vaal Triangle for the period 2021 – 2023 are presented in Figure 6-4. Annual average concentrations across the ambient monitoring network indicate compliance with the annual NAAQS, with no stations exceeding the NAAQS in any year. Highest concentrations were typically measured at Sharpeville, Chicken Farm, Kendal K2, and eMalahleni. Although not presented in Figure 6-4, exceedances of the hourly NAAQS were recorded at Chicken Farm, although importantly these remained well below the permitted frequency of exceedances, with 15 exceedances recorded and 88 permitted.



**Figure 6-4 - Highveld and Vaal Triangle ambient NO<sub>2</sub> concentrations, 2021 – 2023**

## 6.1.2 HIGHVELD AND VAAL TRIANGLE CUMULATIVE AIR QUALITY IMPACTS

CALPUFF dispersion modelling was undertaken by uMoya-NILU Consulting (Pty) Ltd, as contained within the Cumulative Highveld and Vaal AIR (report uMN220-24, 2024) to assess various operational scenarios anticipated by Eskom for the Highveld and Vaal Fleet, comprising Komati, Arnot, Camden, Kriel, Grootvlei, Hendrina, Duvha, Matla, Kendal, Lethabo, Tutuka, Majuba, and Kusile in the coming years for SO<sub>2</sub>, NO<sub>x</sub>, and PM (PM<sub>10</sub> and PM<sub>2.5</sub>), namely:

- **Scenario 1 (Current):** The baseline scenario using actual monthly stack emissions for 2021-2023 and fugitive emissions from the ash dump.
- **Scenario A (2025):** Eskom's planned 2025 stack emissions, representing anticipated station performance between 2025 – 2030, including fugitive emissions from the ash dumps and stockpiles. This includes the shutdown of Komati; the completion of PM abatement projects at Kendal, Lethabo, Tutuka, Duvha, and Matla; and the FGD at Kusile.
- **Scenario B (2031) / ERP 2024 A:** Eskom's planned 2031 stack emissions, representing anticipated station performance between 2031 – 2035, including fugitive emissions from the ash dumps and stockpiles. This includes completion of shutdowns at Arnot, Kriel, Hendrina, Camden, and Grootvlei, including their fugitive sources, with Matla and Duvha also entering shutdown phase; FGD at Kusile and reduced SO<sub>2</sub> emissions achieved through Despatch Prioritisation and efficiency improvement projects; and NO<sub>x</sub> abatement (LNB) at Majuba, Lethabo, and Tutuka.
- **Scenario C (2036) / ERP 2024 B:** Representing an alternative scenario for anticipated station performance from 2036 onwards, including fugitive emissions from the ash dumps and stockpiles. This includes the complete shutdown of Matla and Duvha; shutdowns of Tutuka, Lethabo, and Kendal, including their fugitive sources, with Majuba entering shutdown phase in FY2047; SO<sub>2</sub> abatement installed at Kusile (Wet FGD), Majuba (DSI FGD), and Kendal (Semi-dry FGD); as well as reduced SO<sub>2</sub> emissions achieved through Despatch Prioritisation and efficiency improvement projects.
- **Scenario D (MES) / ERP 2024 C:** MES compliance, inclusive of the ash dumps and stockpiles, where relevant (i.e. not for the stations shutdown), and in addition to the abatement included in above scenarios, FGD installations at Tutuka and Lethabo. (Additional NO<sub>x</sub> and FGD technology not installed at Duvha and Matla given the shutdown of these stations by 2035).

Table 6-1 presents maximum ground level concentrations predicted at sensitive receptors and monitoring stations (only the highest concentration and predicted exceedances presented) associated with each operational scenario. While the focus of the assessment is on stack emissions, and SO<sub>2</sub> particularly, the inclusion of fugitive PM emissions provides a holistic understanding of the Highveld/ Vaal Fleet contributions to ambient PM<sub>10</sub> and PM<sub>2.5</sub> concentrations. Key findings from this AIR comprised:

- For SO<sub>2</sub>:
  - Predicted concentrations are attributed only to the stack emissions.
  - Maximum predicted annual concentrations at all receptors remain below the annual NAAQS in all scenarios.
  - No exceedances of the short-term NAAQS (24-hour and hourly) are predicted at receptors in all scenarios.
  - Considering Scenario D (full MES compliance) and Scenario C (Eskom planned), concentration predictions show an improvement in Scenario D. However, critically, Scenario C and B, inclusive of the abatement planned by Eskom, does not show any exceedances of the NAAQS. This is also evident in Eskom's current operational scenarios (Scenario 1 and A) where abatement has not yet taken effect, although improvements in emissions due to Despatch Prioritisation and efficiency improvements are considered.
- For NO<sub>2</sub>:
  - Predicted concentrations are attributed only to the stack emissions.

- Maximum predicted concentrations remain well below all averaging periods of the NAAQS at all receptors for the five scenarios.
- No short-term exceedances (hourly) are predicted to occur.
- For PM<sub>10</sub> and PM<sub>2.5</sub>:
  - Predicted concentrations are attributed to stack emissions and low-level fugitive sources (ash dumps and stockpiles).
    - The inclusion of the fugitive sources was done assuming most the area is exposed and available for entrainment, while in reality only a small portion of the modelled area would be exposed to entrainment due to the vegetated sides and wet areas of the dumps. This approach should be considered an over-estimate.
  - The PM emissions from stacks and fugitive sources are not speciated into PM<sub>10</sub> and PM<sub>2.5</sub>, rather all PM emitted is assumed to be PM<sub>10</sub>, and all PM emitted is assumed to be PM<sub>2.5</sub>, considered environmentally conservative.
  - Maximum PM<sub>10</sub> annual concentrations predicted at sensitive receptors, inclusive of the ambient monitoring stations, are predicted to remain below the annual NAAQS in all scenarios, with a maximum annual average concentration of 28.1µg/m<sup>3</sup> predicted to occur at a receptor.
    - Exceedances of the 24-hour PM<sub>10</sub> NAAQS are predicted in Scenarios 1, A, and B, exceeding the permitted frequency of exceedance in a three-year period (12 in a three-year period, as modelled). Predicted concentrations decrease in Scenario's C and D, with no 24-hour exceedances predicted, predominantly due to station shutdowns, inclusive of their fugitive sources which are assumed to be rehabilitated, which are the main contributing sources.
  - Maximum annual average PM<sub>2.5</sub> concentrations are predicted to exceed the annual NAAQS in Scenario's 1, A, and B, while 24-hour exceedances are also predicted, exceeding the permitted frequency of exceedance. While the annual averages in Scenario C and D are below the more stringent PM<sub>2.5</sub> standard coming into effect in 2030, 24-hour exceedances are still predicted, above the permitted frequency.
    - PM<sub>2.5</sub> predictions must be viewed in light of the conservative assumptions (over-estimate) applied in the dispersion models, as discussed previously.
  - Further, considering the areas of predicted non-compliances and their proximity to each power station, as noted in the uMoya-Nilu AIR (report uMN220-24, 2024), the elevated PM can mostly be attributed to the low-level fugitive sources, which have poor buoyancy and disperse poorly, as opposed to the stack emissions which are released at a much higher height above ground-level, with considerable buoyancy, and so disperse well.
  - Given the conservative approach to the fugitive emission source simulations, and that this provided an absolute worst-case emission scenario, and based on recommendations received from uMoya-Nilu, Eskom undertook an additional cumulative modelling scenario, assessing only PM, SO<sub>2</sub>, and NO<sub>x</sub> stack emissions from the Highveld and Vaal Triangle Fleet. NO<sub>x</sub> and SO<sub>2</sub> emissions were included to ensure secondary particulate formation is accounted for. Key findings from this include:
    - Predicted PM<sub>10</sub> and PM<sub>2.5</sub> concentrations, including secondary particulate formation, indicated full compliance with the NAAQS, with no 24-hour exceedances predicted within the modelling domain.
    - The maximum PM<sub>10</sub> annual and 24-hour average predicted was 4.7µg/m<sup>3</sup> and 36.5µg/m<sup>3</sup>, respectively, predicted in Scenario A, remaining well below the NAAQS.

- The maximum PM<sub>2.5</sub> annual and 24-hour average predicted was 4.2µg/m<sup>3</sup> and 31.3µg/m<sup>3</sup>, respectively, predicted in Scenario A, remaining well below the NAAQS.
- This additional modelling confirms ground-level concentrations due to Eskom stack emissions remain well below the NAAQS, with the elevated concentrations originally predicted being influenced by the low-level fugitive sources, rather than the stack emissions.
- In comparison to measured ambient annual average SO<sub>2</sub>, NO<sub>x</sub>, PM<sub>10</sub> and PM<sub>2.5</sub> concentrations, the modelling scenario representing Eskom current emissions (Scenario 1) predicted lower annual averages compared to the measured data, to be expected as Eskom is not the sole contributor to measured ambient concentrations.

**Table 6-1 - Predicted maximum annual and short-term ground level concentrations occurring at selected receptors and ambient monitoring stations for each operational scenario (uMoya-NILU, report uMN220-24, 2024)**

Pollutant			
Predicted maximum SO <sub>2</sub>	Annual	24-hour (P99)	1-hour (P99)
Scenario 1 (Current)	11.4	81.3 (0)	150.8 (0)
Scenario A (2025)	23.0	121.1 (0)	344.0 (0)
Scenario B (2031)	17.2	95.8 (0)	289.2 (0)
Scenario C (2036)	13.3	79.7 (0)	241.0 (0)
Scenario D (MES)	5.4	31.8 (0)	105.2 (0)
<b>NAAQS limit value</b>	<b>50</b>	<b>125 (12)*</b>	<b>350 (264)*</b>
Predicted maximum NO <sub>2</sub>	Annual	-	1-hour (P99)
Scenario 1 (Current)	5.1	-	89.4 (0)
Scenario A (2025)	6.7	-	107.8 (0)
Scenario B (2031)	3.9	-	75.3 (0)
Scenario C (2036)	3.9	-	79.0 (0)
Scenario D (MES)	3.9	-	79 (0)
<b>NAAQS limit value</b>	<b>40</b>	<b>-</b>	<b>200 (264)*</b>
Predicted maximum PM <sub>10</sub>	Annual	24-hour (P99)	-
Scenario 1 (Current)	27.7	205.8 (96)	-
Scenario A (2025)	28.1	209.4 (95)	-
Scenario B (2031)	18.7	135.3 (27)	-
Scenario C (2036)	10.4	62.3 (0)	-
Scenario D (MES)	10.2	59.9 (0)	-
<b>NAAQS limit value</b>	<b>40</b>	<b>75 (12)*</b>	<b>-</b>
Predicted maximum PM <sub>2.5</sub>	Annual	24-hour (P99)	-
Scenario 1 (Current)	27.7	205.8 (222)	-
Scenario A (2025)	28.1	209.4 (218)	-
Scenario B (2031)	18.7	135.3 (278)	-
Scenario C (2036)	10.4	62.3 (98)	-
Scenario D (MES)	10.2	59.9 (98)	-
<b>NAAQS limit value</b>	<b>20</b>	<b>40 (12)*</b>	<b>Up to 31 Dec 2029</b>
	<b>15</b>	<b>25 (12)*</b>	<b>From 01 Jan 2030</b>

Note: Red represent non-compliances, with exceedance counts in brackets

\*Regulations provide for permitted frequency of exceedance per calendar year; 4 exceedances per year of a 24-hour standard, and 88 exceedances per year of an hourly standard. Since the model simulated three years, these permissible exceedance counts represent a three-year period.



## 6.2 HEALTH IMPACTS

A coal-fired power station releases impurities into the air during coal combustion in the boiler. These pollutants are released through stacks, where they are diluted and endure chemical transformations before ultimately reaching the surface. Here, they may be inhaled or impact the physical environment. The pollutants include SO<sub>2</sub>, NO<sub>x</sub>, polycyclic aromatic hydrocarbons, and trace substances such as mercury.

The effects of coal combustion-associated air pollution on health are recognised worldwide. The sensitive receptors mainly consist of schools, hospitals, and other locations where children, the elderly, and the infirm might reside. While many factors impact air quality, air pollution exposure in communities near coal-fired power stations is significantly higher than areas without these facilities.

Air emissions are responsible for a variety of detrimental health effects. Examples of these effects include respiratory diseases, lung cancer, cardiovascular diseases, and neurodevelopmental disorders. Potential health impacts associated with power station emissions are outlined below:

- SO<sub>2</sub> that potentially contributes to respiratory illnesses (chronic bronchitis, nasal, throat and lung irritations, asthma attacks) and cardiovascular disease.
- PM<sub>2.5</sub> is the air pollutant responsible for the most significant health issues and premature mortality. PM<sub>2.5</sub> is more likely to penetrate and accumulate on the surface of the deeper lung regions. Furthermore:
  - Short-term exposure to PM<sub>2.5</sub> is linked to premature mortality, acute and chronic bronchitis, asthma attacks, and other respiratory symptoms, as well as heart or lung distress. Infants, children, and older individuals who have preexisting cardiac or lung diseases are more likely to experience these adverse health effects.
  - Long-term exposure to PM<sub>2.5</sub> (months to years) has been associated with reduced lung function growth in children and premature death, particularly in those with chronic heart or lung diseases.
- PM<sub>10</sub> contributes to adverse health effects as it is more likely to deposit on the surfaces of the larger airways of the upper lung region, inducing tissue damage and lung inflammation.
  - There is evidence of the adverse effects of short-term exposure on respiratory health.
  - The consequences of prolonged exposure to PM<sub>10</sub> are less certain, although studies indicate a correlation between respiratory mortality and long-term PM<sub>10</sub> exposure.
- Nitrogen oxides contribute to respiratory illnesses (e.g., respiratory infection, asthma, chronic bronchitis) and smog.
- Mercury and other heavy metals have been associated with neurological and developmental impairment in humans.

Noting the above issues, the NAAQS described in section 3.2 above were established to protect air quality and public health. Compliance with the standard in an area implies that the area is exposed to an acceptable level of risk from air quality impacts and air quality related health issues. This does not imply that there is no risk associated with lower levels of pollutants in the atmosphere but there is arguably no acceptable risk to some pollutants and the NAAQS thus represent what is considered acceptable in the South African context. The benefit-cost analysis discussed below attempts to put a financial cost on these health impacts.

Considering the existing activities in each airshed impacting air quality, ensuring improvement in air quality in the area and public health requires a targeted, practical and integrated approach to emissions management in the area.

It can also be noted that unplanned electricity outages through load shedding can also result in health impacts due to challenges with the availability of medical facilities, water provision and food storage challenges for example.

## **6.3 WATER**

### **6.3.1 WATER DEMAND OF FGD SYSTEMS**

FGD systems are used to remove SO<sub>2</sub> from exhaust flue gases of fossil fuel power plants and other industrial processes. FGD technology includes wet, dry and semi-dry processes. Wet FGD technology is planned at Medupi, with semi-dry FGD technology proposed for Kendal and DSI FGD is proposed for Majuba. Should the MES be enforced on the remaining Eskom power stations, Matimba, Lethabo, and Tutuka would receive semi-dry FGDs.

Wet FGD, while having higher efficiency in SO<sub>2</sub> removal (up to 98%), has higher operational complexity and environmental impact due to its high-water usage. Semi-dry processes have a lower water requirement than wet FGD and a smaller footprint, with no wastewater production, simplifying water management, however there will still be an increase in water usage from current operations. However, SO<sub>2</sub> removal has a slightly lower efficiency than wet FGD.

Dry FGD processes produce less waste and use less water, reducing the need for extensive water treatment facilities. However, it may produce more solid waste, requiring adequate disposal solutions. The dry FGD process has a slightly lower efficiency (up to 90%) but simpler operation and lower environmental impact in terms of water usage. The lower water usage makes dry FGD systems more suitable for regions with limited water resources (such as South Africa).

The Eskom ERP includes the implementation of wet and semi-dry FGD technology options due to the higher efficiencies that would be required to reduce SO<sub>2</sub> emissions to levels compliant with the MES. This will result in an increase in water demand across the fleet. This additional water demand is not necessarily available over the short-term specifically in the catchments of operation of the power stations, such as the Integrated Vaal River System (IVRS). Very limited water supply development potential exists, which requires that any water increases be addressed by an appropriate mix of supply and demand side measures. While power generation is a strategic water use in terms of the National Water Act (No. 36 of 1998) (NWA), and as such receives water at an assurance level of supply of 99.5% due to the importance of electricity for the socio-economic growth of this country, water supply is not necessarily available to meet an increase in water requirements. Water security is thus at risk.

### **6.3.2 WATER SUPPLY**

The raw water supply to the Eskom power stations is sourced directly from two water resource supply systems, *namely*:

- Mokolo River system for supply to the Medupi and Matimba Power Stations; and
- IVRS (Vaal, Thukela and Usutu catchments) for supply to Matla, Majuba, Duvha, Tutuka, Kendal and Lethabo Power Stations.

Power generation is identified as a strategic water use in terms of the NWA and is provided with the highest assurance of supply (99.5 %) in the operation of all water resource systems in the country

(National Water Resources Strategy -3 (NWRS-3), DWS 2023). However, a key goal of the NWRS-3 is reducing water demand, and while water supply for electricity generation is afforded priority it is not unlimited and has to be balanced with other strategic objectives of the NWRS-3. The NWRS-3 does refer to the disadvantage of the proposed FGD technology with its high-water usage, and due to water scarcity in the country, recommends further research on alternative technologies and options to meet the future Eskom water demand (DWS, NWRS-3, 2023). Future allocations to meet the increased water supply, should FGD's be installed, to Eskom can thus not be guaranteed, if it is not aligned with the strategic goals of the NWRS-3 and imperatives to reduce water demand, increase water conservation and improve water use efficiency.

### 6.3.3 LETHABO POWER STATION

Lethabo Power Station is in the Vaal River catchment (C22F) approximately 25 km downstream of the Vaal Dam in the Upper Vaal catchment area. Water requirements to the station is supplied from the Integrated Vaal River System, with direct abstraction from the Vaal River. Water uses have been authorised until 2030 in terms of the NWA for power generation activity and potable water use. Lethabo is authorised to abstract 54.38 million m<sup>3</sup>/a from the Vaal River. Wastewater is stored in associated dams on site and recovered to the station to be used as cooling water. Ash generated through the operation are disposed at the ash disposal facility on site.

While Eskom is not proposing to install FGD at Lethabo, should full MES compliance for SO<sub>2</sub> be enforced, a semi-dry FGD would be the preferred option for Lethabo. The summary of the current allocation and potential changes to the water requirements at Lethabo due to a semi-dry FGD are shown in Table 6-2. Achieving full MES compliance will require an approximate 13% (5.2 million m<sup>3</sup>/a) increase in water supply, although this increase in water usage is not expected to have any significant impact on the water balance of Lethabo Power Station as the water use is consumptive with minimal wastewater generation. It is expected that the additional water requirement for Lethabo Power Station will be met through the current allocation from the IVRS, as the station has shown a decline in its water usage due to low load factors (Eskom, 2024) and has thus not utilised its full allocation.

**Table 6-2 – Summary of water changes with a semi-dry FGD**

VARIABLE	UNIT	
Water allocation (VRESS, 2023)	million m <sup>3</sup> /a	39.84
Additional water requirement	million m <sup>3</sup> /a	5.224
	%	13

As FGD implementation is only expected beyond 2030, the risk to the water supply from the IVRS will be alleviated/low with the LHWP-Phase 2 expected to be online at that stage to meet the projected water requirements of the users within the Vaal River System and associated catchments. The cost of water will however be higher, and the DWS may need to balance water allocations with competing users. Water security will however be a risk should the LHWP-Phase 2 be delayed. If this is the case, restrictions to users will be implemented, impacting the allocated supply to Lethabo, and therefore impacting electricity generation, as well as the implementation of the FGD.

The implications of the semi-dry FGD technology at Lethabo will impact the longer-term sustainability of the water resources and the receiving environment. As opposed to Eskom's commitment to Environmental, Social, Governance (ESG) principles of reducing water consumption, increasing

WCWDM, and reducing waste generation thereby alleviating the strain on water availability and usage, the FGD will necessitate increased water usage and more waste generation.

## 6.4 WASTE

FGD is a process used to reduce SO<sub>2</sub> emissions from coal-fired power plants by capturing sulphur compounds in the flue gas. While FGD significantly improves air quality and helps meet environmental regulations, it also introduces new waste management challenges. The FGD process typically produces a byproduct known as calcium sulphates (gypsum in the case of wet FGDs), which, based on DFFE waste management requirements, must be managed and stored separately from existing waste streams like ash. Implementing FGD increases both the volume of waste generated and the complexity of waste handling infrastructure. Since co-disposal is not permitted by DFFE, stations will be required to design and construct new facilities to accommodate the gypsum, which requires additional approvals, water management, operational adjustments, and new handling infrastructure. This added waste stream, combined with the increased water use needed for the FGD process, can substantially impact the overall environmental footprint of the facility, making waste management a critical aspect of FGD implementation.

While Eskom does not intend to install FGD technology at Lethabo Power Station, should compliance with the SO<sub>2</sub> MES be enforced, requiring FGD technology, the process will result in the production of gypsum (byproduct) that could require storage/disposal in a waste facility, depending on the materials waste classification.

At Lethabo Power Station, due to FGD, approximately 840kt per annum (ktpa) of gypsum will be produced in addition to the ash production of approximately 7.4 Mtpa. Starting in 2031, and considering the gradual rollout of FGD installations, the first year will see 140 kt of gypsum produced, followed by 280 kt in the second year, continuing to increase annually until the full 840 ktpa is reached.

The existing ash disposal facility was originally designed to handle ash residue and particulate matter collected through current abatement processes. The introduction of gypsum from the FGD process, however, will significantly affect the way waste streams are managed. Ash and gypsum differ in particle size, and density, which could challenge the existing infrastructure. Since DFFE does not permit co-disposal, Eskom will need to specifically construct a disposal facility for gypsum. Water management, specifically, will be impacted, as gypsum handling introduces different moisture retention and drainage requirements compared to ash. Currently, water from ash disposal is managed with established runoff and containment systems, but the addition of gypsum will necessitate more rigorous water controls to prevent contamination, requiring additional infrastructure and permitting. Addressing water impacts will be critical, as water management often presents the greatest challenge in waste handling.

As noted previously, existing disposal facilities will not be used for storage (co-disposal) of gypsum that will be produced. As such, the need for design, approval and construction of new disposal facilities will be triggered, unless suitable downstream applications for the material can be found. The design and regulatory approvals for new facilities will require extensive planning and budget allocations. Based on WSP's high-level review and assessment of the information provided by Eskom, the following concluding remarks are made:

- The implementation of semi-dry FGD technology at Lethabo Power Station will be a challenging exercise for waste management, particularly the safe and effective disposal of the gypsum byproduct.
- Should co-disposal, albeit not recommended by WSP, not be applicable, safe handling of the gypsum byproduct will necessitate the constructing a new (lined) disposal facility.
- Design, regulatory approvals and permits, construction and start-up safe operation of a new storage facility for gypsum will incur significant capital expenditure and timeframes.
- WSP has not assessed the capacity of the current ash handling equipment (conveyors), and it is not clear whether the increase of waste would be managed by existing infrastructure. This would require a detailed investigation.
- Separating the waste streams to different facilities will necessitate the handling of ash and gypsum on separate conveyors. Installation of an additional conveyor system to handle the gypsum will therefore lead to a substantial increase in Capex and Opex.
- From a high-level assessment, it appears that the Capex and Opex associated with the required waste handling infrastructure may outweigh the potential benefits of implementing FGD. This suggests it might be financially inappropriate for a station with a limited remaining operational life.

## 6.5 CLIMATE CHANGE

Eskom has identified the contribution of their operations on global climate change in terms Greenhouse Gases (GHGs) emitted as carbon dioxide emissions as a significant issue. Due to this, the organisation has identified the need for a Climate Change Policy as well as the Generation Division Adaptation to Climate Change Plan. Both the plan and policy are developed to combat Eskom's vulnerability to acute and chronic effects that climate change may have on Eskom's infrastructure and systems and its plan to reduce its contribution to global climate change.

The Eskom Climate Change Policy applies all of Eskom's Divisions and subsidiaries. This Policy is in line with South Africa's National Policies such as the Climate Change Response (NCCRP) White Paper, 2011; the National Development Plan (NDP), 2030; South Africa's updated Nationally Determined Contribution (NDC), which has been submitted to the secretariat of the UNFCCC; the Paris Agreement; and the recently implemented Climate Change Act (2024), which will provide for a coordinated and integrated national response to climate change and its impacts.

The Eskom Climate Change Policy is supported by the approved Eskom JET Strategy, which demonstrates how Eskom will transition away from coal-fired power to more sustainable, lower emitting electricity sources. Eskom sees the JET as a pivotal point in Eskom's future which supports the national goals to decrease GHG emissions, promote job creation through reskilling and stimulate economic growth. The overall monitoring protocols will also be guided by the Climate Change Act (2024) and all other relevant climate change regulations and strategies.

As emphasised in the Eskom policy, South Africa's revised NDC will significantly impact Eskom, as most mitigation in the updated NDC target needs to come from the electricity sector which now accounts for approximately 41% of South Africa's GHG emissions. Eskom will need to decommission multiple coal-fired power stations over the next decade for South Africa to align to the objectives of international climate agreements. This means that coal-fired power stations would need to be supplemented with generation capacity from renewable and lower carbon technologies to meet South Africa's climate change commitments while maintaining security of supply. Preliminary analysis by the department shows that greenhouse gases from fossil fuel power generation will need to be limited to



125 – 140Mt CO<sub>2</sub> per annum in 2030 for South Africa to remain within the upper end of the NDC for 2030. While a new NDC is still being developed for 2035, the range (125 – 140 Mt CO<sub>2</sub> per annum) is maintained in the modelling from 2031.

GHG emissions from carbon dioxide are presented for the Eskom's Generation Business Unit, inclusive of all coal-fired power stations, in Figure 6-5. While the MES and climate change regulatory process are legally separate it is useful to note both ERP 2024 A and the security of supply projection are aligned with Eskom's current pollution prevention plan running to December 2025. Future CO<sub>2</sub> trajectories will be based on the updated pollution prevention plan and IRP, NDC, and Sectorial Emission Targets (SET).

This illustrates the anticipated CO<sub>2</sub> emissions trajectory, based on Eskom's anticipated loads, for the 2025 to 2050 operational period. Eskom's anticipated coal-fired load, in turn, assumes a time and full roll out of new electricity generation capacity to meet growing demand. Eskom's CO<sub>2</sub> emissions trajectory, without the enforcement of full MES compliance, shows a decreasing trend over time, predominantly driven by stations decommissioning and reduced loads at other stations. CO<sub>2</sub> emissions are anticipated to reduce from approximately 192Mt in 2025 to 63Mt in 2050, representing an approximate decrease of 67%. This is aligned with Eskom's and Government's aspirations in terms of climate change.


Should compliance with the MES be enforced, specifically with the new plant SO<sub>2</sub> MES, requiring the need to install FGDs at Lethabo, Tutuka, and Matimba, in addition to the already planned FGDs at Medupi and Kendal, CO<sub>2</sub> emissions would increase. This increase is predominantly due to the increase in the auxiliary power requirements to supply the FGD, considering Eskom's Scope 1 emissions. Although these are the emissions Eskom would be responsible for (i.e. in accordance with direct accounting and reporting of carbon emissions), other considerations due to the installation of FGDs with regards to CO<sub>2</sub> emissions are manufacturing, transportation, construction, and installation of the FGD itself, potential increase in mining activities due to the additional limestone (sorbent) required, emissions associated with the transport of limestone, most likely from the Northern Cape and emissions due to the end of life decommissioning of the FGD unit.

Figure 6-5 also illustrates the anticipated increase in CO<sub>2</sub> emissions with the addition of the abovementioned FGDs. Although seemingly insignificant, the addition of the FGDs would result in an approximate increase in CO<sub>2</sub> emissions of 25Mt between 2025 and 2050 across the coal-fired fleet, representing a 0,9% increase in Eskom's estimated emissions. This estimate only considers the auxiliary power requirements of the FGD, and although not responsible for Eskom to report, also the estimated CO<sub>2</sub> emissions due to sorbent transport from the Northern Cape. Further, the estimated 25Mt increase represents an approximate annual contribution to South Africa's 2030 Nationally Determined Contributions (NDC) budget of 0.4% (on average from 2030 – 2050), with a peak CO<sub>2</sub> contribution anticipated in 2026/27 of approximately 2Mt due to the FGD installations, representing a 0.6% contribution to SA's 2030 NDC budget<sup>1</sup>.

---

<sup>1</sup> The contribution of the SA NDC lower emissions target is based on CO<sub>2e</sub>, whereas the emissions from the FDG are based only on CO<sub>2</sub>. It is understood that CO<sub>2</sub> is the largest GHG contributor for the project.





**Figure 6-5 – Eskom coal-fired fleet CO<sub>2</sub> emission trajectory and contribution from FGDs**

## 7 FINANCIAL CONSEQUENCES

---

### 7.1 FINANCIAL ANALYSIS

Previous assessments completed as part of the MES and NECA process have shown that attempting to install the technology required to meet new plant SO<sub>2</sub> limits (wet-FGD) at stations by 2025 was unfeasible from a technical, economic and project-implementation perspective, apart from Medupi that was designed for a FGD retrofit, the other plants were not (Eskom 2021). Given the previous analysis and the time and other constraints influencing the present exemption applications only the two most potentially viable SO<sub>2</sub> reduction implementations (Majuba and Kendal) were assessed as part of this exemption application.

The assessments completed previously, included an analysis of the Levelised Cost of Electricity (LCOE) to compare the viability of FGD investments at stations with other options like gas or renewables. They also used stochastic electricity systems modelling to understand the full impact of FGD implementations. The studies indicated that retrofitting the plants with FGD would increase the cost of electricity produced due to the high capital and operating cost of FGD and the limited remaining life of the plants. (Eskom, 2020). Full implementation might have resulted in an increase in the average electricity tariff of around 10%, whereas the partial implementation scenarios would have a lesser impact – depending on the scenario. Studies also showed that the shutdown of multiple stations to enable the rapid implementation of FGD would result in significant security of supply issues which would result in massive levels of load shedding and a resultant destruction of the economy.

With an average age of the coal fleet being almost 40 years old, the long lead time to implement retrofits results in a limited economic life remaining post retrofit of the FGD. Assuming it was technically feasible to retrofit (which is a significant risk), and ignoring the unserved energy and load shedding, even with the increased cost, in the short term the plants would be cost competitive, relative to the comparable alternatives which could be deployed in the same time frames. These alternatives included that of running the OCGTs at 20% p.a. load factor and load shedding of the remaining demand in the earlier years. In the latter years with the increased cost due to the FGD, the plants would need to run at guaranteed higher load factors i.e. have a higher output, to remain competitive with comparable alternatives.

Two years have passed since the last detailed analysis, which now further limits the remaining useful life over which to recover any financial investment.

Eskom has maintained in all previous applications, that the costs associated with retrofitting FGD to any of its plant outweighs the benefits. This has been rejected by the NAQO, and partially by the NECA panel advising the Minister and in the Ministers Appeal decision. Although, in the case of Medupi, the report by the NECA indicated that FGD was very costly and would require Medupi to be offline for 80 additional days per year for six years, increasing load shedding risks. (DFFE, 2024).

From a national strategic and risk perspective, if it is considered necessary for Eskom to implement a SO<sub>2</sub> abatement project at an Eskom station beyond Kusile and Medupi, and if it is proven to be technically feasible, it would be necessary to source funding against the background of guaranteed cost -reflective tariffs. From an economic/financial perspective a defined minimum load factor/take or pay agreement would ensure that the units costs are acceptable compared to known alternatives however if consideration could be given to the extension of the station life the economic/financial viability could improve. Given the quantum of the requirement investment, it is probable that Eskom

would require fiscal support in order to raise funding for additional abatement projects beyond Kusile and Medupi. There might also be implications regarding possible carbon tax and carbon budget allocation target adjustments with the increase in load factor and extended plant life.

With the current uncertainties in the context of the pre-concept phase of planning and not yet having performed the thorough stochastic systems modelling process (based on any updated IRP), factoring in the range of possible outcomes on all the key input variables, it would be reckless for Eskom to make unconditional commitments to any SO<sub>2</sub> reduction implementation. Any commitments must be subject to completion of the mentioned systems modelling process as well as the completion of a detailed technical implementation feasibility study/ pilot. If retrofit proves technically unfeasible, a relief from obligations and commitments should be obtained. This might include SO<sub>2</sub> exemption for relevant stations, depending on the system's alternatives and the potential requirement for the stations to continue operating, as established through the stochastic systems modelling process.

Any Eskom commitments or authority decision should also incorporate an economic viability threshold. The market tendering processes should indicate that if costs exceed the estimates made for purposes of these commitments by a defined degree (which could be linked to budgets, operational cost caps etc), the decision will need to be revisited. Such thresholds should not just be defined in terms of project costs but rather in terms of economic/financial viability, factoring in the likely system alternatives in the event of these power plants not continuing to be operated.

The decision on any SO<sub>2</sub> reduction implementation must consider the benefit of SO<sub>2</sub> reduction from the power stations, against the opportunity cost of such SO<sub>2</sub> reduction. A possible alternative solution is that if funding is available Eskom increases its investments in renewables and grid connection by the same amounts that would have been invested in such SO<sub>2</sub> retrofits, this would result in larger economic value add than FGD retrofits.

### **7.1.1 COST ANALYSIS FOR MES COMPLIANCE AT KENDAL**

Kendal has a lower operating cost and higher load factor than most stations, however it has a relatively short useful life post retrofit to recover the high FGD retrofit cost, resulting in marginal financial and economic viability. Kendal will need to sustain higher load factors than presently planned, to remain competitive with alternative options in an unconstrained power system context, where these alternatives would potentially be the lowest-cost Risk Mitigation Independent Power Producer Program (RMIPPPP) type of projects (The RMIPPPP program called for dispatchable technologies including a combination of wind, solar, gas, diesel etc). Like Majuba, if the power system continues to be highly constrained, where the alternatives include OCGTs and the cost of inadequate supply (load shedding/ unserved energy etc) then Kendal could be much cheaper thus economically and financially very viable even at very low load factors, and with the cost of the retrofit included and assuming technical feasibility is proven

It should however be noted that 9.5 years post retrofit for a significant investment is very short. Kendal will be approximately 40 years old by the time the retrofit is complete and will only operate for a full 5 years with all 6 units running with the retrofit, assuming it is delivered on time. In the context of such a short remaining life, consistently higher load factors of a minimum 40% are required to sustain viability within the future market competing with alternative options of potentially the lowest-cost RMIPPPP type of projects. The assumption of a longer remaining life could improve Kendal's competitiveness and make it viable at lower load factors, from a purely economic/financial perspective.

The capital expenditure (Capex) required to ensure SO<sub>2</sub> compliance at Kendal is estimated at R44,4 billion, while the annual Opex is estimated at R1,04 billion. Additionally, the costs associated with Kendal achieving its proposed maximum daily limits for PM is R1,43 billion.

### **7.1.2 COST ANALYSIS FOR MES COMPLIANCE AT MAJUBA**

Despite Majuba having a longer remaining life than Kendal (17 Years post retrofit) and DSI FGD being lower in cost (and technically less efficient relative to the Wet and Semi-dry FGDs), Majuba's high operating cost, even before considering the additional capex, makes the economic and financial viability of the DSI FGD investment challenging.

At low load factors e.g., below 50%, the LCOE for Majuba will probably not be competitive with alternative options in an unconstrained power system, where these alternatives would potentially be the lowest-cost RMIPPP program type of projects. Under a constrained power system scenario, where the alternatives include OCGTs and the cost of load shedding/unserved energy, then Majuba with DSI FGD could have a lower cost and be economically and financially viable even at low load factors (assuming it is technically feasible).

With the identified implementation risks, a sensitivity was performed assuming the implementation of DSI FGD is delayed by three years. The LCOE increased i.e. the option became more expensive. For it to remain competitive with alternative options, a minimum load factor of approximately 60% is required.

Which technology to deploy and Majuba's likely range of load factors results in uncertainty, which could only be established and quantified through the stochastic systems modelling process. Depending on the outcome of such modelling process it might also be appropriate to justify the continued operation of Majuba (with or without the retrofit) based on strategic risk considerations.

The Capex required to ensure SO<sub>2</sub> compliance at Majuba is estimated at R13,1 billion, while the annual Opex is estimated at R1,04 billion. Additionally, the costs associated with Majuba achieving its proposed maximum daily limits for NO<sub>x</sub> is R1,1 billion.

### **7.1.3 ERP NOMINAL COSTS AND TARIFF IMPACTS**

Table 7-1 presents estimated nominal costs associated with each ERP option. The total nominal cost of all Eskom ERP scenarios has been estimated by Eskom at a Class 2 accuracy, implying a variance between -15% and +20%. Increases in Eskom capital costs impact on the electricity tariff paid by consumers. The extent of any tariff increases is influenced by multiple factors including the extent and timing of funding and projected energy sales. Implementation of the ERP scenarios with additional SO<sub>2</sub> reduction requirements could increase the electricity tariff by between 3 and 10% from current levels. Work to confirm the extent of increases utilising Eskom NERSA applicable methodologies will be undertaken.

**Table 7-1 – Eskom Fleet ERP financial summary**

	ERP 2024 A	ERP 2024 B	ERP 2024 C
	<b>Eskom Fleet (cumulative)</b>		
<b>SO<sub>2</sub> Abatement</b>	Kusile, Medupi FGD	Kusile, Medupi, Kendal (FGD), Majuba (DSI)	Kusile, Matimba, Medupi, Kendal, Tutuka, Lethabo (FGD), and Majuba (DSI)
<b>NO<sub>x</sub> Abatement</b>	Majuba, Lethabo, Tutuka LNB	Majuba, Lethabo, Tutuka LNB	Majuba, Lethabo, Tutuka LNB
<b>PM Abatement</b>	Kendal, Matimba, Lethabo, Tutuka, Duvha, Matla PM Projects	Kendal, Matimba, Lethabo, Tutuka, Duvha, Matla PM Projects	Kendal, Matimba, Lethabo, Tutuka, Duvha, Matla PM Projects
<b>Capex (nominal)</b>	R77.2 billion	R134.6 billion	R256.9 billion
<b>Opex (real, pa)</b>	R2.1 billion	R4.2 billion	R6.3 billion

## 7.2 HEALTH BENEFIT COST ANALYSIS

The combustion of fossil fuels by power stations results in the emission of several atmospheric pollutants, that include PM, NO<sub>2</sub>, and SO<sub>2</sub>. Atmospheric pollutants have numerous negative effects on human health and may increase the risk of premature mortality.


Technologies exist to reduce these emissions and therefore also their negative health effects. Abatement technologies for power stations include FGD and Direct Sorbent Injection (DSI), for SO<sub>2</sub> reduction; installation of HFPS to improve ESP efficiency to reduce PM emissions; and Low NO<sub>x</sub> Burners (LNB) for NO<sub>2</sub> reduction.

A benefit-cost analysis (BCA) allows for trade-offs between different scenarios to be compared to support decision making.

The aim of the cost-benefit study was to estimate the incremental health benefits associated with abatement technology options as well as plant decommissioning, to achieve or move towards compliance with the new MES of the DFFE.

### 7.2.1 METHODOLOGY

An integrated Air Pollution Health Risk Benefit Cost Analysis (APHR-BCA) model was developed to model the impacts of three different abatement scenarios as developed by Eskom. The APHR-BCA was developed following the General Principles of the World Health Organisation, WHO (WHO, 2016a), for performing air pollution health risk assessments (AP-HRA). The detailed methodology and assumptions are set out in Section 2 below. In summary, the methodology proceeded through several steps, as set out in Figure 7-1.



**Figure 7-1 – APHR-BCA Methodology**

## 7.2.2 HEALTH BENEFITS RESULTING FROM AIR POLLUTION ABATEMENT

The WHO (2016a) recommends that the health risk in a population, associated with air pollution, is to be estimated using exposure-response functions (ERFs). ERFs are based on Relative Risk (RR) estimates derived from primary epidemiological studies. These RR functions estimate the likelihood of health outcomes occurring in a population exposed to a higher level of air pollution relative to that in a population with a lower exposure level. RR is usually expressed as the proportional increase in the assessed health outcome risk incidence associated with a given increase in pollutant concentrations, measured in  $\mu\text{g}/\text{m}^3$

The WHO (2016a) notes that *“the RR estimate cannot be assigned to a specific person; it describes risk in a defined population, not individual risk.”*

Ideally, ERF studies and their RRs should be determined based on primary epidemiological studies focussing on the exposed population. In the absence of such studies, as in the case of South Africa, the WHO (2016a) recommends using ERFs from other countries.

The health outcomes were selected based on the latest WHO systematic reviews from 2020 and 2021 that were conducted for the update of the WHO Global Air Quality guidelines. The health outcome that was considered in this study is all-cause mortality. Morbidity was not considered in this study as comprehensive data on morbidity studies is not widely available. Additionally, there are issues relating the transferability of data from one population to another in terms of country and culture as populations have different sensitivities to pollutant exposure (WHO 2000).

Pollution levels, chemical composition and health care systems are typically very different in other settings, and this would affect the accuracy of the ERFs. It is important to understand at what level interval the ERFs would result in significant differences in health outcome incidences. As a result, the WHO (2016a) advises performing an assessment of the uncertainty of the analysis; in this case therefore this requires an assessment related to a lack of knowledge about one or more components of the integrated Health BCA Model. Section 2.5 discusses each source of uncertainty and related limitations. Variation resulting from relevant uncertainty factors was assessed through performing sensitivity analysis in the BCA (refer to Section 2.4).

Interpretation of the risk of premature mortality must be done with care. It is to be noted firstly that these numbers are indicators of health risk at a population level. The relative risk estimate inherent in the ERF is a metric of the likelihood of an adverse health outcome, and it cannot be attributed to an individual person. It can thus be used to quantify risk to a defined population (and not to an individual), (WHO 2016a) and how this risk would vary between various mitigation scenarios.

In this study, the ERFs obtained from the latest WHO systematic reviews, focussed exclusively on mortality and thus a monetary measure of mortality was required in order to perform benefit-cost analyses. In air pollution benefit-cost analyses, the concept of value of a statistical life (VSL) is commonly used to monetise mortality related benefits of air pollution reduction. The concept of a VSL is frequently misunderstood. It does not measure the intrinsic value of a human life, and neither does it value the economic productivity of a human. Rather, VSL is estimated by dividing an individual's willingness to pay (WTP) to reduce health risk, by the likelihood of risk reduction. Robinson and Hammitt (2009) defines VSL to represent the rate at which an individual is willing to exchange their own income for a small reduction in their own mortality risk over a particular time period. VSL is not the value that a person, society or the government would place on reducing mortality rates with certainty, but it is rather a representation of the rate at which a person views a change in the money



available for spending as equivalent to a small change in their own mortality risk (Robinson et al., 2018).

Primary WTP studies for mortality risk reductions have not been done in South Africa. The VSL for South Africa in the BCA was determined by using the methodology as advised by Viscusi and Masterman (2017) and Robinson et al. (2018) with a base VSL from the U.S, GNI per capita for income measures and adjusted by income elasticity. As advised by Robinson et al. (2018), a sensitivity analysis is conducted to explore various VSL estimates.

### 7.2.3 SCENARIO ASSESSMENT

The three scenarios proposed by Eskom and evaluated in the BCA study were:

- Scenario ERP 2024 A (PM and NO<sub>x</sub> reduction, generating load capped, air quality offsets and SO<sub>2</sub> reduction at Kusile).
- Scenario ERP 2024 B (As per ERP 2024 A plus SO<sub>2</sub> reduction technology installed at Majuba and Kendal).
- Scenario ERP 2024 C (Full compliance with MES for PM, NO<sub>x</sub> and SO<sub>2</sub> for Kusile, Majuba, Kendal, Lethabo and Tutuka).

A key difference in the scenarios is the number of stations which are installed with SO<sub>2</sub> reduction technology in the form of wet-FGD, semi-dry FGD, or Direct Sorbent Injection (DSI). The focus on SO<sub>2</sub> reduction is important given the extent which it is anticipated to impact on air quality and public health and the very significant cost of SO<sub>2</sub> reduction cost.

Health benefits associated with each scenario were calculated against the baseline that took into account the anticipated changes in loads in the coming years from 2025 and assumed no additional abatement technologies installed, and all stations would continue to emit air pollution at their current rates until decommissioning. The baseline also includes the health benefits derived from subsequent decrease in load as stations shutdown as new alternate energy source capacity becomes available.

- The health benefits of ERP 2024 A deliver immediate impact from 2024. The benefits associated with this scenario start tapering off from 2030 onwards as Duvha and Matla decommission between 2031 and 2036, and the associated health benefits from the HFPS and LNB technologies reduces accordingly. Tutuka, Lethabo and Kendal decommission from 2036, 2037 and 2040 respectively. The Electrostatic Precipitators (ESP) plus High Frequency Power Supplies (ESP+HFPS) and Low NO<sub>x</sub> Burners (LNB) technologies at these stations continue to provide health benefits until 2045. Majuba decommissioning starts in 2047 and the health benefits from the LNG technology continue until final closure. ERP 2024 A includes wet FGD at Kusile but the costs and benefits of this fall outside of the scope of this scenario assessment.
- The health benefits of ERP 2024 B include those as discussed for ERP 2024 A above. In addition, efficiency and coal improvement projects reduce total sulphur and carbon emissions by 5% for Kendal, Lethabo, Tutuka and Majuba contributing to the increase in health benefits in ERP 2024 B. In addition to the Kusile wet FGD (but the costs and benefits of this fall outside of the scope of this scenario assessment), at Majuba DSI is commissioned from 2029 – 2033. Kendal is equipped with semi-dry FGD which is implemented from 2036, and this increases health benefits for a short period to 2040 whereafter Kendal decommissioning starts.

- The health benefits of ERP 2024 C include those as discussed for ERP 2024 A and B above. All planned PM emission reduction projects are completed (by 2028), and stations operate at  $PM=50 \text{ mg/Nm}^3$ .  $NO_x$  projects are completed at all stations (completed by 2032), and stations operate at  $NO_x = 750 \text{ mg/Nm}^3$ . In addition to the  $SO_2$  reduction at Kendal and Majuba (and Kusile – however these effects are not part of the scenario assessment), semi-dry FGDs are installed at Tutuka and Lethabo by 2035, however, these stations start decommissioning from 2036 and 2037 respectively, thus effectively negating the health benefits from the FGD technologies.

With respect to the abatement costs associated with each scenario:

- The total Capex and Opex costs of abatement are identical to 2025.
- ERP 2024 B implementation starts in 2026 and 2027 with Majuba and Lethabo's LNB technology. From 2029 DSI installation starts at Majuba and in 2031 FGD starts at Kendal.
- ERP 2024 C builds on ERP 2024 B with implementation of  $SO_2$  reduction technology starting in 2031 for both Lethabo and Tutuka.

The BCA ratios need to be interpreted with care. They are meant only to provide a perspective on and inform the decision-making process underlying the scenarios. They are not meant to be interpreted as a definitive answer to making abatement decisions. Decisions involving human health have to be informed by non-economic criteria as well. In addition, with uncertainty inherent in the analysis, the benefit cost ratio should thus not be viewed as absolute, but rather as a relative value from which to compare scenarios.

Benefits from station closure are included within the baseline so are not visible in the BCA directly. The shutdown of stations does however generally result in less pollution being emitted with increased health benefits compared to the baseline.

The BCA results are provided in Table 7-2. In the upper estimates the lower costs and higher VSL are used and in the lower estimates the higher costs and lower VSL are used as recommended by Robinson et al. 2018.

- The BCA central ratio in ERP 2024 A is more than 1 (1.74), showing a very clear benefit and the health benefits exceed the costs of abatement, implying that this is a sound abatement option for Eskom to pursue. This scenario has a total nominal cost of R18,500 million.
- The central BCA ratio of ERP 2024 B ( $SO_2$  reduction at Majuba and Kendal) is less than 1 although it approaches 1 in the most optimistic (upper) parameters of the sensitivity analysis. The key reason for this is the implementation of the Kendal semi-dry FGD which is implemented from 2036, but only increases health benefits for a brief period to 2040 whereafter Kendal decommissioning starts. In this scenario the total nominal cost increases to R75,970 million (which adds to ERP A the additional cost of  $SO_2$  reduction at Majuba and Kendal).
- The BCA central ratio of ERP 2024 C ( $SO_2$  reduction at Majuba, Kendal, Lethabo and Tutuka) is less than 1 (0.33) and remains below 1 even in the most optimistic (upper) parameters of the sensitivity analysis. The key reason for this is the implementation of FGDs at Tutuka and Lethabo by 2035, followed by immediate decommissioning from 2036 and 2037 respectively, thus effectively negating the health benefits from the FGD technologies. In this scenario the total nominal cost increases to R155,320 million (which adds to the ERP 2024 A and B costs the additional costs of  $SO_2$  reduction at Lethabo and Tutuka).

- Evaluation of the BCA ratios at a social discount rate of 2% delivers similar results, with ERP 2024 A above 1 and ERP 2024 B and C both less than 1. This is because of the limited health benefits achieved post 2036.

**Table 7-2 - BCA ratios (lower and upper ranges) for each scenario (discounted at Eskom WACC)**

	ERP 2024 A		ERP 2024 B		ERP 2024 C	
Million Rands	Lower	Upper	Lower	Upper	Lower	Upper
NPV of Costs	-10,479	-7,423	-33,909	-24,019	-56,964	-40,349
NPV of Benefits	3,575	23,341	3,651	23,831	3,732	24,357
NPV of Benefits minus Costs	-6,904	15,918	-30,258	-188	-53,232	-15,993
Benefit:Cost Ratio (range)	0.34	3.14	0.11	0.99	0.07	0.60
Benefit:Cost Ratio (central)	1.74		0.55		0.33	

In the analyses above the benefits from station closure form part of the baseline.

The power stations planned shutdown schedule results in health benefits without associated abatement costs. These benefits are dependent on timing of the shutdown schedule. These benefits have been assumed to form part of the BCA baseline and have therefore not been quantified directly in the BCA.

## 7.3 SOCIO-ECONOMIC IMPACTS

The following section of the report discusses the importance of Lethabo Power Station to the local economy of the region and the potential socio-economic impacts of not obtaining MES exemption for Lethabo Power Station. Such a scenario may result in a shutdown or load-shedding.

### 7.3.1 IMPACT ON THE ECONOMY

The current Gross Domestic Product (GDP) in Metsimaholo Local Municipality (MLM) is R57.2bn, and the significant contributing sector is fuel, petroleum, chemical and rubber products manufacturing, contributing approximately 30% of the GDP. Coal and lignite mining contributes 9% towards the GDP. According to the IDP, an economic decline caused by a slight decline in mining activity will significantly impact the populace's social status and ability to achieve social betterment (Metsimaholo Local Municipality, 2024).

MLM's Gross Value Added (GVA) was valued at R46,6 billion in 2023 (constant prices), accounting for around 51,1% of the district economy's GVA and 10,7% of the Free State's. The manufacturing sector currently contributes 52,8% to the local economy. This GVA can be attributed to the large manufacturing hubs of Vereeniging and Vanderbijlpark, located within the municipality and close to Lethabo.

The finance and business sector (10,6%) and the mining sector (7,0%) are the next most significant economic contributors to the local economy. The reliance of the local economy on the manufacturing sector is substantial, and any impact on the manufacturing sector's performance will be detrimental to the local economy. Considering that the manufacturing sector relies on a sustainable and constant electricity supply, the availability of electricity is critical to the local economy's success.

The utility sector (electricity, gas and water) contributes roughly R2,2 billion to the local economy. However, the reliance of the mining, manufacturing, and other economic sectors on the utility sector makes it a vital sector within the regional and local economy.

If the station is required to shut down due to a negative MES decision this would lead to a variety of economic impacts.

Lethabo Power Station supplies electricity to the national grid. Should the station be required to shut down and there is no adequate alternative supply, the loss of this generation capacity on the national grid could result in the reintroduction of load-shedding. Maintaining a stable energy supply ensures the economy remains robust and productive.

Maintaining a stable national energy supply supports the national and local economy, including employment and associated livelihood requirements. The operation of Lethabo Power Station contributes to this. Goods and services providers, among others, benefit from the power station's consistent supply and operational stability. Amongst others, the agriculture sector feeds into the agro-processing industry, which utilises electricity for manufacturing. Both these sectors contribute significantly to job creation and economic growth.

Maintaining a reliable power supply is crucial for economic growth. Avoiding load-shedding helps prevent economic downturns and supports growth trajectories. Reliable operations also bolster investor confidence, attracting investment to the area and the country.

### **7.3.2 IMPACT ON EMPLOYMENT**

The MLM population increased to 158,391 between 2011 and 2022, which represents an increase of 6.23 % over 11 years (Stats SA, 2022). The population increase rate of 6.23 % is estimated to increase the municipality's population to 168,259 in 2030, 178,742 in 2040, and 189,878 in 2050. People between 15 and 64 years old represent 68.4% of the population. Young people constitute 25.3% of the population, and the elderly 6.3% (Metsimaholo Local Municipality). The youthfulness of the population and the fact that the population is growing indicates the need for employment in the municipality.

In 2023, the unemployment rate of MLM was 35,7% (Quantec Easydata, 2024). The municipality has 49,659 employed people, while 27,527 are unemployed. The non-economically active population amounts to 32,486 people. Discouraged work seekers were recorded at 2%, and those who were not economically active were recorded at 22.2%. Youth unemployment was 41.6% (Metsimaholo Local Municipality, 2024). The relatively high unemployment rate needs to be addressed to alleviate poverty and improve the living conditions of the local communities. Eskom, its contractors and the New Vaal mine, which provides coal to Lethabo Power Station, are significant employers in the municipality.

Lethabo Power Station currently employs 743 direct employees. There are also an additional 2000 to 3000 contractors who work at the station, depending on when there are major outages. The local municipality has an unemployment rate of over 35%. Therefore, sustaining these employment opportunities at Lethabo Power Station is crucial. Other Key employment opportunities rely on the power station's operations, including off-site suppliers, original equipment manufacturers (OEMs), and indirect employment opportunities. The 1,275 employees at New Vaal mine will also be vulnerable to unemployment should the power station be forced to shut down due to the high costs of the FGD abatement project as they are the main coal supplier to the Lethabo Power Station (Seriti, 2020).

Granting Lethabo Power Station the exemption requested in this application will allow the facility to be operational at the current staffing levels. Maintaining staffing levels will secure the income of the surrounding communities, and local businesses and services will be able to continue operating.

Social impacts of potential job losses as a result of changed operations due an adverse MES decision can include:

- Increase in the unemployment rate within the area. The loss of jobs at the power station will increase the amount of people of working age who are unemployed.
- A sudden loss of income can result in drastic changes in lifestyle and the inability to meet necessities.
- Unemployment creates additional stress in families, resulting in tensions and possible disintegration.
- Being unemployed can result in alienation, shame and stigma.
- Increase in crime, including Gender Based Violence (GBV). The impacts associated with job losses can result in social disintegration, which may increase crime and GBV levels.
- Skilled workers are more likely to seek and find employment outside the area, resulting in an exodus of skills.
- With a decrease in disposable income, the standard of living is often reduced.
- Eskom has also committed itself to a JET Strategy. The JET Strategy focuses on repowering and repurposing plans to lessen potential job losses as a result of having to shut down power stations due to them reaching the end of life. The JET Strategy could also be applied to stations which might need to shut down due to not meeting the MES.

### **7.3.3 IMPACT ON THE STANDARD OF LIVING**

As discussed, Lethabo Power Station is responsible for many employment opportunities within the local communities and municipalities and supports off-site suppliers, OEMs, and indirect employment opportunities. All these employees earn a salary to support their families and increase direct spending in these areas.

The household earnings are used for housing, transportation, food, medical expenses, school fees, etc. With these earnings, the families continue their standard of living. However, should the power station shut down, the standard of living of some individuals in the local communities will be reduced due to lost employment.

Should security of supply be impacted and load-shedding return, the standard of living will be impacted as access to electricity is reduced, and households will have to rely on other energy sources such as solar or burning carbon fuels. These energy sources have financial and health impacts, lowering the standard of living.

### **7.3.4 IMPACT ON GOVERNMENT REVENUE**

The Lethabo Power Station is responsible for water revenues to the municipality and the Department of Water Affairs. Lethabo Power Station pays Rand Water approximately R80,000,000 a year. The operation of the Lethabo Power Plant will allow for the continuing collection of these revenues.

### **7.3.5 IMPACT ON ELECTRICITY SUPPLY TO THE NATIONAL GRID**

The nominal capacity of the power station is an estimated 3,558 MW, according to Eskom (Eskom, 2024). An EAF above 70% consistently makes Lethabo Power Station one of the best-performing



power stations in Eskom's fleet while contributing an estimated 7.6% to the national energy grid. Grid security is crucial for economic growth and investor confidence. The loss of this generation capacity on the national grid without the availability of replacement capacity would be significant and could impact on the national security of supply result in the reintroduction of load-shedding, resulting in a decline in economic activity and growth in the local and regional economies. The impact on capacity if the station is removed from the grid is discussed in more detail in the introduction and Section 5.2 of this report.

The socio-economic impacts should be considered in the context of the impact of compliance on security of energy supply. As was shown through scenario modelling in 2021/22, full compliance (whether immediate or even over a period of several years) could potentially limit the constitutional rights of South Africans by leading to severe energy deficits, at minimum constraining GDP growth and economic recovery, at worst causing total catastrophic economic collapse. Even at the minimum impact it would increase unemployment, reduce job creation, reduce government tax revenue, increase poverty and the associated malnutrition and health implications, with (even at this minimum impact level) a far greater health consequence than a delayed and more prolonged phase-out of carbon emissions.

## **8 STAKEHOLDER ENGAGEMENT**

---

The Ministers Decision issued in May 2024 requires that: “Eskom must ensure that all relevant organs of state, I&APs are notified of its applications for exemption and provided with an opportunity to comment thereon.”

Based on this requirement, a public participation process based on the requirements of the EIA Regulations have been undertaken. Public participation is understood to be a series of inclusive and culturally appropriate interactions aimed at providing stakeholders with opportunities to express their views, so that these can be considered and incorporated into the decision-making process.

### **8.1 PUBLIC PARTICIPATION**

#### **8.1.1 IDENTIFICATION OF KEY STAKEHOLDERS**

The stakeholder engagement commenced with the compilation of a stakeholder database to include relevant stakeholders, such as Commenting Authorities, State Owned Enterprises, business landowners/users, and Ward Councillors, as well as any other I&APs who may be interested or affected by the project.

Relevant authorities (organs of state) have been automatically registered as I&APs. In accordance with the EIA Regulations, 2014 all other persons must request in writing to be placed on the register, submit written comments, or attend meetings to be registered as stakeholders and included in future communication regarding the application.

Section 41 of the EIA Regulations, 2014 states that written notices must be given to identified stakeholders as outlined in the table below.



**Table 8-1 - I&AP Identification**

NEMA REQUIREMENT	DISCUSSION
(i) the owner or person in control of that land if the applicant is not the owner or person in control of the land	The applicant is the landowner.
(ii) the occupiers of the site where the activity is or is to be undertaken or to any alternative site where the activity is to be undertaken	The applicant is the landowner and occupant.
(iii) owners and occupiers of land adjacent to the site where the activity is or is to be undertaken or to any alternative site where the activity is to be undertaken	The landowners and occupant of adjacent properties will be notified of the proposed application by newspaper advert, site notices placed around the proposed site and also emails and SMS for those already registered in the database.
(iv) the municipal councillor of the ward in which the site or alternative site is situated and any organisation of ratepayers that represent the community in the area	The Ward Councillor from Wards 18 of the MLM has been included in the stakeholder database and will be notified by newspaper, received personal email and SMS notifications.
(v) the municipality which has jurisdiction in the area	The Fezile Dabi District Municipality (FDDM) as well as the Metsimaholo Local Municipality have been included in the stakeholder database and will be notified by newspaper, received email and SMS notifications.
(vi) any organ of state having jurisdiction in respect of any aspect of the activity	The FDDM will be notified by newspaper, email and SMS notifications.
(vii) any other party as required by the competent authority	All tiers of government, namely, national, provincial, local government and parastatals have been included on the stakeholder database and were notified by newspaper, received email and SMS notifications. Inclusive of: <ul style="list-style-type: none"> <li>▪ DESTEA</li> <li>▪ DFFE</li> <li>▪ Department of Energy</li> <li>▪ Department of Water and Sanitation</li> </ul>

## 8.1.2 MES EXEMPTION APPLICATIONS ANNOUNCEMENT

The exemption application process will be announced for public comment for a period of 30 days from **6 November 2024 – 6 December 2024**. Additionally, the technical report along with an electronic version of the comment sheet will be placed on the WSP Group Africa (Pty) Ltd (WSP) website as well as the WSP Datafree website to be accessed by the public at the following links: <https://www.wsp.com/en-ZA/services/public-documents> and <https://wsp-engage.com/>.

## 8.1.3 DIRECT NOTIFICATION

### 8.1.3.1 Email notifications

Notification of the exemption application will be issued to registered I&APs and stakeholders, via email on **06 November 2024**. The purpose of the notification was to offer registered I&APs and stakeholders

the opportunity to comment on the application process. A total of 830 registered stakeholders were notified via email.

#### 8.1.3.2 SMS

Notification of the exemption application will be issued to registered I&APs and stakeholders, via SMS on **06 November 2024**. The purpose of the notification was to offer registered I&APs and stakeholders the opportunity to comment on the application process. A total of 1,321 registered stakeholders were notified via sms.

#### 8.1.3.3 Site notices

The EIA Regulations, 2014 require that site notices be fixed at places conspicuous to the public at the boundary or on the fence of the site where the activity (to which the application relates) is to be undertaken, as well as at any alternative sites. Posters (in English, Afrikaans and Sesotho), conforming to the size specifications as per the EIA Regulations, 2014 will be placed on **06 November 2024**. Six posters in each language (where relevant) were placed for each power station.

### 8.1.4 AVAILABILITY OF TECHNICAL REPORTS

The exemption reports were made available for public comment at the public places outlined in Table 8-2.

**Table 8-2 - Public Availability of Exemption Report**

LOCATION	ADDRESS
Lethabo Power Station	Klasie Havenga Street, Vanderbijlpark
Bophelong Library	Corner Ncuma and Matthews Street, Bophelong
Vereeniging Library	Lesley Street, Vereeniging
Sharpeville Library	Seeiso Street, Sharpeville
WSP Website	<a href="https://www.wsp.com/en-ZA/services/public-documents">https://www.wsp.com/en-ZA/services/public-documents</a>
Data-free Website	<a href="https://wsp-engage.com/">https://wsp-engage.com/</a>

#### 8.1.5 ADVERTISEMENT

Notification of the exemption application as well as opportunity to comment on the application process was issued to the general public via advertisements published in the newspapers outlined in Table 8-3, in **November 2024**, in English in all national newspapers and one other language in local newspapers,. As mentioned above, the purpose of the advertisement was to notify the general public of the application, inform the public about the public meetings, and provide an opportunity to register on the project database and provide input into the process.

**Table 8-3 - Placement of Adverts**

LOCATION	DATE OF PUBLICATION
City Press (Regional Newspaper)	Sunday 3 November 2024
Sunday Times (National Newspaper)	Sunday 3 November 2024
Beeld (National Newspaper)	Sunday 3 November 2024
Star (National Newspaper)	Sunday 3 November 2024
Daily Sun (National Newspaper)	6 November 2024
Vaal Weekblad (Local Newspaper)	Thursday 31 October 2024

### 8.1.6 PUBLIC MEETINGS

Public meetings will be convened for the project team to present the application to stakeholders as well as gather feedback from them. These meetings offer the stakeholders an opportunity to participate in the decision-making process and ensures that their voices are heard. Meetings will be convened at the locations outlined in Table 8-4 translation services will be available at the meetings and hard copy summaries of key documents will be made available at the physical meetings.

**Table 8-4 - Date, venue and time of public meeting**

VENUE	ADDRESS	DATE	TIME
Buitepos Saal	6 Carlyle Ct, Vanderbijlpark	13 November 2024	10:00
Eskom Academy of Learning	Dale Road, Midrand	29 November 2024	10:00
Online Meeting	Microsoft Teams Meeting Meeting ID: 334 202 077 604 Passcode: 8PwGGQ	25 November 2024	13:00

### 8.1.7 COMMENTS AND RESPONSES

Following the receipt of comments from I&APs, a Comments and Response Report (“CRR”) will be prepared and submitted to the Minister.

Proof of stakeholder engagement undertaken will be included in the submission to the Minister.

## 9 ASSUMPTIONS AND LIMITATIONS

---

The following assumptions, limitations and exclusions are applicable to this application:

- A 50-year operational life for the power stations has been assumed for this application.
- It is assumed the emission trajectories for scenario options of ERP 2024 A, ERP 2024 B, and ERP 2024 C, as provided by Eskom, are accurate and representative of reality and future anticipated plans.
- It is assumed current emissions data, as provided by Eskom, used to assess compliance to emission limits, and used as input to the dispersion models, are accurate and representative of existing operations.
- It is assumed abatement projects, as proposed by Eskom, will be undertaken as presented within the timeframe commitments, to the best of Eskom's ability i.e. should outage schedules and grid capacity allow.
- Operational challenges identified at the stations, and confirmed by Eskom, are assumed to be accurate of current operational conditions at the stations.
- Results from the dispersion modelling, discussed herein, are assumed to accurately represent emissions data provided.
- Due to time constraints, the Security of Supply emission projection could not be assessed in the dispersion modelling.
- Ambient monitoring data, as contained herein, is assumed to accurately represent existing ambient air quality within the various airsheds.
- Qualitative technology evaluations, particularly relating to SO<sub>2</sub> abatement technologies, were undertaken by Eskom. This application assumes these evaluations, and the preferred technologies from these, accurately reflect the most appropriate technology for a particular station. WSP's involvement in this application, and high-level understanding of Eskom stations, does indicate the technologies selected are most suitable, considering all aspects, such as costs, timeframes to commission, water requirements, retrofitting complexities, waste management, and emission reduction efficiencies. Despite this, WSP cannot be held responsible should more appropriate technologies be identified in the future.
- Shutdown dates provided by Eskom are not within Eskom's legal mandate to decide, but require prior approval from NERSA, which may not necessarily be granted should security of supply be jeopardised.

## 10 REFERENCES

---

- Air Resource Management (ARM). (2024). *Offsets Research: Proposal for the expansion of Eskom's AQO Programme in the Highveld and Vaal, Rev: 02*[ESK-A16-AQOE-02].
- Air Resource Management. (2024). *Offsets Research: Proposal for the expansion of Eskom's AQO Program in the Highveld and Vaal, Rev: 00* [ESK-A16-AQOE-00].
- BizNews. (n.d.). *The devastating impact of power cuts on South Africa's economy*. Retrieved from BizNews: <https://www.biznews.com/energy/2023/02/01/devastating-impacts-power-cuts-sa-economy>
- CarbonBrief. (2020). *Global coal power*. Retrieved from CarbonBrief: <https://www.carbonbrief.org/mapped-worlds-coal-power-plants/>
- Department of Environmental Affairs. (2018, October 26). The 2017 National Framework for Air Quality Management in the Republic of South Africa, Government Gazette No. 41996. Pretoria, Gauteng Province, South Africa: Government Printing Works. Retrieved from [www.gpwonline.co.za](http://www.gpwonline.co.za)
- Department of Forestry, Fisheries and the Environment. (2024). *Report of the NECA Forum to the Minister of Forestry Fisheries and the Environment on the Appeals Relating to Eskom's Power Stations*.
- DFFE. (2024). *Report of the National Environmental Consultative and Advisory Forum pertaining to the Appeals relating to Eskom's Power Stations*.
- Eskom. (2020). *APPLICATION AND MOTIVATION FOR EXEMPTION, POSTPONEMENT AND SUSPENSION FROM THE MINIMUM EMISSIONS STANDARDS COMPLIANCE TIMEFRAMES FOR ESKOM'S COAL-FIRED POWER STATIONS IN THE HIGHVELD*.
- Eskom. (2020). *Application for alternative limits and postponement or exemption of the minimum emissions standards compliance timeframes for the Medupi power station*.
- Eskom. (2021, MArch). *Air Quality Offset Implementation Plans for Lethabo Power Station: March 2021 Update* [ENV21-R053]. Retrieved from Eskom: <https://www.eskom.co.za/wp-content/uploads/2021/08/AQoffsetplanFezileDabiMarch2021update.pdf>
- Eskom. (2021). *ASH MANAGEMENT IN ESKOM*. Retrieved from <https://www.eskom.co.za/wp-content/uploads/2021/08/CO-0004-Ash-Management-Rev-15.pdf>
- Eskom. (2021). *Initial Financial Analysis of MES policy option*.
- Eskom. (2023). *Eskom*. Retrieved October 17 , 2024, from <https://www.eskom.co.za/eskom-releases-its-results-for-the-2022-23-financial-year/>
- Eskom. (2024).
- Eskom. (2024). *Comment made during the review of an exemption report by Eskom, 2024*.
- Eskom. (2024). *Eskom Air Quality Offset Plans: Progress Report March 2024* [GEM24-DOC015].
- Eskom. (2024). *Generation Division Business Plan FY 2025*. Eskom Generation Division.


- Eskom. (2024). *Quarterly Update on the Implementation of Eskom's Minimum Emission Standards Postponement Commitment: June 2024 [GEM24-L266]*.
- Eskom. (2024). *Quarterly update on the implementation of minimum emission standards postponement commitment*.
- Eskom. (Air Quality Offset Project, 2024). *Air Quality Offset Project – Steering Committee*.
- Eskom. (August 2024 ). *Eskom Licensing Authority – NAQO Meeting, Eskom Input (23 August 2024 rev 1.1)*.
- Eskom. (ENV21-R053, 2021). *Air Quality Offset Implementation Plans for Lethabo Power Station: March 2021 Update*. Retrieved from <https://www.eskom.co.za/wp-content/uploads/2021/08/AQoffsetplanFezileDabiMarch2021update.pdf>
- Eskom Licensing Authority. (2024). *NAQO Meeting, Eskom Input* .
- Eskom. (Progress Report, March 2024). *Eskom Air Quality Offset Plans: Progress Report March 2024 [GEM24-DOC015]*.
- Eskom. (Quarterly Update, June 2024). *Quarterly Update on the Implementation of Eskom's Minimum Emission Standards Postponement Commitment: June 2024 [GEM24-L266]*.
- Metsimaholo Local Municipality. (2024). *Draft 2024/2025 Reviewed Integrated Development Plan: Metsimaholo LM*. Retrieved from <https://www.metsimaholo.gov.za/download/idp-5-year-plan-2022-23-2026-27/>
- Moolman, S. (2022). *Power Optimal*. Retrieved October 18, 2024, from <https://poweroptimal.com/2021-update-eskom-tariff-increases-vs-inflation-since-1988/>
- Municipalities of South Africa. (2024). *Fezile Dabi District Municipality (DC20)*. Retrieved from Municipalities of South Africa: <https://municipalities.co.za/overview/107/fezile-dabi-district-municipality>
- North-West University. (2024). *Pre-feasibility study for potential offset opportunities for Marapong Township*.
- North-West University. (2024). *Pre-feasibility study for potential offset opportunities for Marapong Township*.
- Prime Africa Consult. (2024). *Air Pollution Health Risk Benefit Cost Analysis for exemption power stations in the Highveld Priority Area*.
- Quantec Easydata. (2024, September). *Quantec Standardised Regional*. Retrieved from <https://www.easydata.co.za/>
- Republic of South Africa. (1996). *Constitution of the Republic of South Africa (Act No. 108 of 1996)*. Cape Town, Western Cape Province, South Africa: Government Printing Works. Retrieved from [www.gpwonline.co.za](http://www.gpwonline.co.za)
- Republic of South Africa. (2005, February 24). *National Environmental Management: Air Quality Act, 2004 (Act No. 39 of 2004)*. Government Gazette No. 27318, Notice No. 163. Cape Town, Western Cape Province, South Africa: Government Printing Works. Retrieved from [www.gpwonline.co.za](http://www.gpwonline.co.za)



- Republic of South Africa. (Government Gazette 43418, 2020). *Government Notice 655 (2020) Government Gazette 43418: National Environmental Management: Air Quality Act, 2004 (Act No. 39 of 2004), Draft Second Generation Air Quality* .
- Republic of South Africa, G. N. (2016). *National Environmental Management: Air Quality Act, 2004 9Act No.39 of 2004), Air Quality Offsets Guideline*. Government Gazette 39833.
- Republic of South Africa, G. N. (Air Quality Offsets Guideline, 2016). *National Environmental Management: Air Quality Act, 2004 9Act No.39 of 2004), Air Quality Offsets Guideline*. Government Gazette 39833.
- Republic of South Africa, Government Notice 533 (2014) Government Gazette 37804. (2004). *National Environmental Management: Air Quality Act, 2004 (Act No. 39 of 2004), Regulations Regarding Air Dispersion Modelling*.
- Seriti. (2020). *New Vaal Social and Labour Plan 2020/21 - 2024/25*.
- South African Police Service. (2024). *First Quarter Crime Statistics 2024/2025*. Retrieved from <https://www.saps.gov.za/services/crimestats.php>
- Stats SA. (n.d.). *Dataset: Descriptive by Municipality*. Retrieved from SuperWEB2: <https://superweb.statssa.gov.za/webapi/jsf/tableView/tableView.xhtml>
- Stats SA. (n.d.). *Govan Mbeki*. Retrieved from Stats SA: [https://www.statssa.gov.za/?page\\_id=993&id=govan-mbeki-municipality](https://www.statssa.gov.za/?page_id=993&id=govan-mbeki-municipality)
- uMoya-NILU. (2024). *Atmospheric Impact Report in Support of the Application for Exemption from the Minimum Emission Standards for Lethabo Power Station, Report No.: uMN215-24*.
- United States Environmental Protection Agency. (2024, August). *Clinical Outcomes Related to Particulate Matter Exposure and Cardiovascular Disease*. Retrieved from <https://www.epa.gov/air-research/clinical-outcomes-related-particulate-matter-exposure-and-cardiovascular-disease>
- Van Horen, C. (1996): Counting the social costs: electricity and externalities in South Africa. University of Cape Town Press, 1996.
- World Health Organisation (2009): Environmental Burden of Disease. South Africa. [http://www.who.int/quantifying\\_ehimpacts/national/countryprofile/en/](http://www.who.int/quantifying_ehimpacts/national/countryprofile/en/).
- World Health Organisation. (2014): WHO Expert Meeting: Methods and tools for assessing the health risks of air pollution at local, national and international level. Meeting report Bonn, Germany, 12-13 May 2014. Available: <http://www.euro.who.int/pubrequest>.
- World Health Organisation (2016a): Health risk assessment of air pollution – general principles. Copenhagen: WHO Regional Office for Europe; 2016.
- World Health Organisation (2016b): International Statistical Classification of Diseases and Related Health Problems 10th Revision. <http://apps.who.int/classifications/icd10/browse/2016/en>.
- World Health Organisation (2021): WHO global air quality guidelines. Particulate matter (PM<sub>2.5</sub> and PM<sub>10</sub>), ozone, nitrogen dioxide, sulfur dioxide and carbon monoxide. Geneva: World Health Organization; 2021. License: CC BY-NC-SA 3.0 IGO.

# Appendix A

## **POWER STATION SPECIFIC ATMOSPHERIC IMPACT REPORT**



# **ATMOSPHERIC IMPACT REPORT IN SUPPORT OF THE APPLICATION FOR EXEMPTION FROM THE MINIMUM EMISSION STANDARDS FOR LETHABO POWER STATION**



**Final  
04 November 2024**



**Report issued by:**

**uMoya-NILU Consulting (Pty) Ltd  
P O Box 20622  
Durban North, 4016  
South Africa**

**Report issued to:**

**WSP Group Africa (Pty) Ltd  
Building 1, Maxwell Office Park  
Magwa Crescent West, Waterfall City  
Midrand, 1685  
South Africa**

## Report Details

Client:	WSP Group Africa (Pty) Ltd
Report title:	Atmospheric Impact Report in Support of the Application for Exemption from the Minimum Emission Standards for Lethabo Power Station
Project:	uMN920-24
Report number:	uMN215-24
Version:	Final 04 November 2024
Prepared by:	uMoya-NILU Consulting (Pty) Ltd, P O Box 20622, Durban North 4016, South Africa
Authors:	Mark Zunckel, Atham Raghunandan and Nopasika Xulu

This report has been produced for WSP Group Africa (Pty) Ltd, representing Eskom Holdings SOC Ltd, by uMoya-NILU Consulting (Pty) Ltd. The intellectual property contained in this report remains vested in uMoya-NILU Consulting (Pty) Ltd. No part of the report may be reproduced in any manner without written permission from uMoya-NILU Consulting (Pty) Ltd, WSP Group Africa (Pty) Ltd and Eskom Holdings SOC Ltd.

When used in a reference this document should be cited as follows:  
uMoya-NILU (2024): Atmospheric Impact Report in Support of the Application for Exemption from the Minimum Emission Standards for Lethabo Power Station, Report No.: uMN215-24, November 2024.

Front page picture credit: <https://www.eskom.co.za/eskom-divisions/gx/coal-fired-power-stations/>

## EXECUTIVE SUMMARY

Eskom operates a fleet of 14 coal-fired power stations, collectively generating more than 39 000 MW of electricity. The combustion of coal to generate steam for the generation of electricity is a Listed Activity in terms of the National Environmental Management: Air Quality Act (Act No. 39 of 2004). Eskom holds Atmospheric Emission Licenses (AELs) for the respective power plants and is obligated to operate these plants according to conditions specified in the respective AELs. Minimum Emission Standards (MES) for Listed Activities were published in 2010 (DEA, 2010) including compliance timeframes for existing and new plants, however existing activities had to comply with the MES for new plants by 30 April 2020.

Between 2018 and 2020, Eskom submitted applications to the Department of Forestry, Fisheries and the Environment (DFFE) based on an internally approved Emission Reduction Plan, which defined which power stations would have emission reduction technology installed and when. The National Air Quality Officer (NAQO) made decisions on these applications in 2019, which were not in favour of Eskom. Eskom appealed the NAQO's decision, and the Minister established the National Environmental Consultative and Advisory (NECA) Forum to advise her on the issue. The Minister ruled on the Eskom appeals on 22 May 2024 and granted the suspension of the Minimum Emission Standards (MES) at five (5) power stations up to 31 March 2030, namely Arnot, Camden, Grootvlei, Hendrina and Kriel. The Minister further directed Eskom to submit an application in terms of Section 59 of the National Environmental Management: Air Quality Act for the exemption of the MES for eight (8) power stations that will continue to operate post 2030. These are Duvha, Kendal, Lethabo, Majuba, Matimba, Matla, Medupi and Tutuka.

In terms of the Minister's ruling, Eskom Holdings SOC Ltd appointed WSP Group Africa (Pty) Ltd to prepare the necessary applications. WSP Group Africa (Pty) Ltd sub-contracted uMoya-NILU Consulting (Pty) Ltd to prepare the associated Atmospheric Impact Reports (AIRs) (DEA, 2013a) to support these applications.

Lethabo Power Station (hereafter referred to as Lethabo) is located in the Vaal Triangle Air-Shed Priority Area, 14 km northeast of Sasolburg, and southeast of Vereeniging and Vanderbijlpark. It has a base load generation capacity of 3 810 MW. Lethabo operates three Listed Activities in terms of the AEL issued in April 2015 (Fezile Dabi District Municipality, 2015). These are listed in Table E-2. The emission limits that apply to Lethabo are listed in Table E-2. The AEL expired on 31 March 2020. The renewal process is on hold until an exemption decision has been made. Eskom is currently applying for exemption from aspects of the MES for Lethabo until decommissioning.

**Table E-1: Current authorisations related to air quality**

<b>Atmospheric Emission License</b>	<b>Dates</b>	<b>Listed Activity Category</b>	<b>Sub-category</b>	<b>Listed Activity Process Description</b>
FDDM-MET-2011-08-P1	Issued: 01 April 2015	1	1.1	Solid Fuel Combustion Installations Storage and Handling of Petroleum Products
	Expired: 31 March 2020	2	2.4	

**Table E-2: Minimum Emission Standards in mg/Nm<sup>3</sup>**

Substance or mixture of substances		Subcategory 1.1
		MES under normal conditions of 10% O <sub>2</sub> , 273 Kelvin and 101.3 kPa.
Common name	Chemical symbol	
Particulate matter	N/A	50
Oxides of nitrogen <sup>a</sup>	NO <sub>x</sub>	750
Sulphur dioxide	SO <sub>2</sub>	1 000 <sup>b</sup>

(a): Expressed as NO<sub>2</sub>

(b): Gazette 43174, GN421 of 27 March 2020

Decommissioning of Lethabo is planned from 2037 to 2042. In the meantime, particulate emissions are controlled by operating and maintaining Electrostatic Precipitators on Units 1 to 5, and SO<sub>3</sub> Injection Plants on Units 2, 3 and 5. The installation of Low NO<sub>x</sub> burners are planned from 2027.

Five scenarios that capture the emission reduction strategy are assessed to support Eskom's application for exemption from the MES at Lethabo. These are:

Scenario 1 (Current): The baseline scenario using actual monthly stack emissions for 2021-2023 and fugitive emissions from the ash dump.

Scenario A (2025): Eskom's planned 2025 stack emissions, representing anticipated station performance between 2025 – 2030, including fugitive emissions from the ash dump.

Scenario B (2031): Eskom's planned 2031 stack emissions, representing anticipated station performance between 2031 – 2035, including fugitive emissions from the ash dump.

Scenario C (2036): Eskom's planned 2036 stack emissions, representing anticipated station performance from 2036 onwards, including fugitive emissions from the ash dump.

Scenario D (MES): Full compliance with the MES, including fugitive emissions from the ash dump.

The annual average emissions for the five scenarios are presented in Table E-3.

**Table E-3: Stack emission rates and equivalent concentrations for this assessment**

Scenario	Stack	Emission rate (tons/annum)			Emission concentration @ 10% O <sub>2</sub> and average load (mg/Nm <sup>3</sup> )		
		NO <sub>x</sub>	SO <sub>2</sub>	PM	NO <sub>x</sub>	SO <sub>2</sub>	PM
1 <sup>a</sup>	Stack 1	51 234	100 147	5 740	696	1 360	78
	Stack 2	51 234	100 147	5 740	696	1 360	78
A	Stack 1	46 808	99 197	3 720	755	1 600	60
	Stack 2	46 808	99 197	3 720	755	1 600	60
B	Stack 1	28 583	56 370	1 393	718	1 416	35
	Stack 2	28 583	56 370	1 393	718	1 416	35
C	Stack 1	22 246	59 258	1 542	505	1 345	35
	Stack 2	22 246	59 258	1 542	505	1 345	35
D	Stack 1	22 246	17 777	1 542	505	404	35
	Stack 2	22 246	17 777	1 542	505	404	35
MES					750	1 000	50

(a): Average from actual monthly emissions



The CALPUFF dispersion model is used to predict ambient concentrations of SO<sub>2</sub>, NO<sub>2</sub>, PM<sub>10</sub> and PM<sub>2.5</sub> resulting from Lethabo stack emissions and fugitive emissions of PM from the ash dump for the five scenarios. While the focus of the assessment is on stack emissions, the inclusion of fugitive PM emissions provides a holistic understanding of Lethabo's contribution to ambient PM<sub>10</sub> and PM<sub>2.5</sub> concentrations. Modelling is done according to the modelling regulations using 3-years of hourly surface and upper air meteorological data.

In the body of the report the predicted ambient SO<sub>2</sub>, NO<sub>2</sub>, PM<sub>10</sub> and PM<sub>2.5</sub> concentrations are presented as isopleth maps over the modelling domain. In this executive summary the maximum predicted annual SO<sub>2</sub>, NO<sub>2</sub>, PM<sub>10</sub> and PM<sub>2.5</sub> concentrations and the 99<sup>th</sup> percentile concentration of the 24-hour and 1-hour predicted concentrations are presented in Table E-4.

For SO<sub>2</sub> and NO<sub>2</sub>, the predicted concentrations are attributed only to the stack emissions. The maximum predicted concentrations for the 5 scenarios are low relative to the limit values of the respective NAAQS. The highest of these predictions occurs for Scenario A (2025), and then systematically decrease in progressive years with the corresponding stack emission reductions.

For PM<sub>10</sub> and PM<sub>2.5</sub>, the predicted concentrations are attributed to stack emissions and low-level fugitive sources (ash dump). The PM emissions are not speciated into PM<sub>10</sub> and PM<sub>2.5</sub>, rather all PM emitted is assumed to be PM<sub>10</sub>, and all PM emitted is assumed to be PM<sub>2.5</sub>. Included in the predicted concentrations is the formation of secondary particulates from SO<sub>2</sub> and NO<sub>2</sub> stack emissions. Together, this represents a worse-case emission scenario for PM<sub>10</sub> and PM<sub>2.5</sub>.

**Table E-4: Maximum predicted ambient annual SO<sub>2</sub>, NO<sub>2</sub>, PM<sub>10</sub> and PM<sub>2.5</sub> concentrations in µg/m<sup>3</sup> and the predicted 99<sup>th</sup> percentile concentrations for 24-hour and 1-hour averaging periods, with the South African NAAQS**

<b>Pollutant</b>			
<b>Predicted maximum SO<sub>2</sub></b>	<b>Annual</b>	<b>24-hour</b>	<b>1-hour</b>
Scenario 1 (Current)	5.2	99.3	155.0
Scenario A (2025)	6.0	113.4	175.3
Scenario B (2031)	5.0	79.5	143.3
Scenario C (2036)	4.8	76.6	140.1
Scenario D (MES)	1.4	23.0	42.0
<b>NAAQS limit value</b>	<b>50</b>	<b>125</b>	<b>350</b>
<b>Predicted maximum NO<sub>2</sub></b>	<b>Annual</b>		<b>1-hour</b>
Scenario 1 (Current)	2.0		61.5
Scenario A (2025)	2.1		64.3
Scenario B (2031)	1.9		56.2
Scenario C (2036)	1.3		40.1
Scenario D (MES)	1.3		40.1
<b>NAAQS limit value</b>	<b>40</b>		<b>200</b>
<b>Predicted maximum PM<sub>10</sub></b>	<b>Annual</b>	<b>24-hour</b>	
Scenario 1 (Current)	<b>174.6</b>	<b>513.3</b>	
Scenario A (2025)	<b>174.6</b>	<b>513.2</b>	
Scenario B (2031)	<b>174.5</b>	<b>511.9</b>	
Scenario C (2036)	<b>174.5</b>	<b>511.9</b>	
Scenario D (MES)	<b>174.4</b>	<b>510.5</b>	
<b>NAAQS limit value</b>	<b>40</b>	<b>75</b>	

Predicted maximum PM <sub>2.5</sub>	Annual	24-hour	
Scenario 1 (Current)	174.6	513.3	
Scenario A (2025)	174.6	513.2	
Scenario B (2031)	174.5	511.9	
Scenario C (2036)	174.5	511.9	
Scenario D (MES)	174.4	510.5	
NAAQS limit value	20	40	Up to 31 Dec 2029
	15	25	From 01 Jan 2030

At all of the sensitive receptors, predicted ambient SO<sub>2</sub> and NO<sub>2</sub> concentrations are well below the limit values of the respective NAAQS. As discussed for the predicted maximum concentrations, the highest predicted concentrations occur in Scenario A (2025) at all receptor points, and then systematically decrease in progressive years with the corresponding stack emission reductions.

For PM<sub>10</sub> and PM<sub>2.5</sub>, it must be remembered that the predicted concentrations are attributed to stack emissions and the low-level fugitive sources (ash dump). Furthermore, the particulate emissions are not speciated into PM<sub>10</sub> and PM<sub>2.5</sub>, but rather all PM emitted is assumed to be PM<sub>10</sub>, and all PM emitted is assumed to be PM<sub>2.5</sub>. In addition, included in the predicted PM<sub>10</sub> and PM<sub>2.5</sub> concentrations is the formation of secondary particulates from SO<sub>2</sub> and NO<sub>2</sub> stack emissions. This is a very conservative approach.

For PM<sub>10</sub>, the predicted annual average and 24-hour ambient concentrations are below the limit values of the NAAQS at all sensitive receptor points in all five scenarios. The predicted 24-concentration however exceeds the NAAQS limit value at the Rand Water AQMS in all five scenarios. Little change in the predicted concentration across the scenarios indicates the influence of the fugitive sources at this receptor point.

For PM<sub>2.5</sub>, the predicted annual average ambient concentrations are below the limit values of the NAAQS at all sensitive receptor points. The predicted 24-hour concentration is generally below the limit value of the NAAQS. However, exceedances of the limit value of 40 µg/m<sup>3</sup> are predicted at 6 sensitive receptors in Scenario 1 (Current) and Scenario A (2025). From 01 January 2030 the stricter limit value of 25 µg/m<sup>3</sup> is exceeded at 24 sensitive receptor points in Scenario B (2031) Scenario C (2036) and Scenario D (MES).

Noteworthy findings from the modelling results may be summarised as follows:

- For SO<sub>2</sub> and NO<sub>x</sub> actual emissions and Eskom's proposed emissions in 2025, 2031 and 2036, there is general compliance with the NAAQS.
- Predicted exceedances of the NAAQS for PM<sub>2.5</sub> at sensitive receptors increase after 2030 when the limit value decreases from 40 µg/m<sup>3</sup> to 25 µg/m<sup>3</sup>.
- For PM<sub>10</sub> and PM<sub>2.5</sub>, exceedances of the NAAQS are predicted close to the power station as a result of the low-level fugitive sources from the ash dump. The associated impacts can be reduced through dust management. Beyond this there is general compliance with the NAAQS.
- There is no discernible difference between the effects of Eskom's proposed emission in 2036 and full compliance with the MES.

The AIR for Eskom's MES exemption application for Lethabo (uMoya-NILU, 2018) considered stack emissions only, i.e. fugitive sources were excluded. This AIR therefore provides insights into the contribution of stack emission to ground-level concentrations.

In that AIR, the actual PM emissions of 4 718 tonnes/annum from each of the two stacks was simulated. The maximum predicted ambient PM<sub>10</sub> concentration was 0.3 µg/m<sup>3</sup>, approximately 6 km southeast of Lethabo. The 99<sup>th</sup> percentile of the 24-hour predicted PM<sub>10</sub> concentrations was 4.3 µg/m<sup>3</sup> and occurred approximately 4 km to the east of Lethabo.

In this AIR, the PM emission for Scenario 1 (Current) are 22% higher than the 2018 AIR, i.e. 5 740 tonnes/annum for each stack. By comparison, the predicted annual PM<sub>10</sub> concentrations 6 km southeast of Lethabo are between 5 and 10 µg/m<sup>3</sup>. The predicted 24-hour PM<sub>10</sub> concentrations 4 km east of Lethabo are between 50 and 75 µg/m<sup>3</sup>. The difference in predicted ambient PM<sub>10</sub> concentrations between the 2018 AIR and the current AIR may partly be attributed to the higher stack emission, but also emphasizes the contribution of the low-level fugitive sources.

Given the conservative approach to the fugitive emission source simulations, and that this has provided an absolute worst-case emission scenario, and based on recommendations received from uMoya-Nilu, Eskom will be undertaking an additional modelling scenario, assessing only PM, SO<sub>2</sub>, and NO<sub>x</sub> stack emissions. NO<sub>x</sub> and SO<sub>2</sub> emissions will be included in this scenario to ensure secondary particulate formation is accounted for. This will provide improved insight to impacts directly related to stack emissions, which are the focus of this exemption application.

## ACKNOWLEDGEMENTS

Jared Lodder, Yakeen Kowlas and Lehlohonolo Sello from WSP Group Africa (Pty) Ltd are acknowledged for processing the ambient air quality and wind data for the baseline assessment.

## GLOSSARY OF TERMS AND ACRONYMS

AEI	Atmospheric Emission Licence
AIR	Atmospheric Impact Report
DEA	Department of Environmental Affairs
DFFE	Department of Forestry, Fisheries and the Environment
EIA	Environmental Impact Assessment
FGD	Flue-gas desulfurisation
g/s	Grams per second
HFPS	High-frequency power supply
kPa	Kilo Pascal
MES	Minimum Emission Standards
mg/Nm <sup>3</sup>	Milligrams per normal cubic meter refers to emission concentration, i.e. mass per volume at normal temperature and pressure, defined as air at 20°C (293.15 K) and 1 atm (101.325 kPa)
NAAQS	National Ambient Air Quality Standards
NAQO	National Air Quality Officer
NECA	National Environmental Consultative and Advisory
NEM-AQA	National Environment Management: Air Quality Act, 2004 (Act No. 39 of 2004)
NEMA	National Environmental Management Act, 1998 (Act No. 107 of 1998)
USEPA	United States Environmental Protection Agency
µm	Micro meter (1 µm = 10 <sup>-6</sup> m)

# TABLE OF CONTENTS

<b>EXECUTIVE SUMMARY .....</b>	<b>ii</b>
<b>ACKNOWLEDGEMENTS .....</b>	<b>vii</b>
<b>GLOSSARY OF TERMS AND ACRONYMS .....</b>	<b>vii</b>
<b>TABLE OF CONTENTS .....</b>	<b>viii</b>
<b>LIST OF TABLES .....</b>	<b>x</b>
<b>LIST OF FIGURES .....</b>	<b>xi</b>
<b>1. INTRODUCTION.....</b>	<b>1</b>
<b>2. ENTERPRISE DETAILS .....</b>	<b>2</b>
2.1 <i>Enterprise Details .....</i>	2
2.2 <i>Location and extent of the power station .....</i>	2
2.3 <i>Description of surrounding land use .....</i>	3
2.4 <i>Emission Control Officer .....</i>	6
2.5 <i>Atmospheric Emission License (AEL) and other Authorisations.....</i>	6
2.6 <i>Modelling contractor .....</i>	7
2.7 <i>Terms of Reference.....</i>	7
2.8 <i>Assumptions .....</i>	8
<b>3. NATURE OF THE PROCESS .....</b>	<b>9</b>
3.1 <i>Listed Activity or Activities.....</i>	9
3.2 <i>Process Description.....</i>	9
3.3 <i>Air pollutants resulting from the process .....</i>	10
3.3.1 <i>Air pollutants .....</i>	10
3.3.2 <i>National Ambient Air Quality Standards .....</i>	10
3.4 <i>Unit Processes.....</i>	11
<b>4. TECHNICAL INFORMATION.....</b>	<b>12</b>
4.1 <i>Raw materials used .....</i>	12
4.2 <i>Appliances and Abatement Equipment Control Technology.....</i>	12
<b>5. ATMOSPHERIC EMISSIONS .....</b>	<b>14</b>
5.1 <i>Point Source Parameters .....</i>	14
5.2 <i>Point Source Emission Rates (Emission scenarios) .....</i>	14
5.3 <i>Point Source Maximum Emission Rates (Start Up, Shut-Down, Upset and         Maintenance Conditions).....</i>	15
5.4 <i>Fugitive Emissions .....</i>	16
5.5 <i>Emergency Incidents .....</i>	17
<b>6. BASELINE CONDITIONS .....</b>	<b>20</b>
6.1 <i>Climate and meteorology.....</i>	20
6.1.1 <i>Temperature and rainfall .....</i>	20
6.1.2 <i>Wind.....</i>	21
6.1.3 <i>Air Pollution Dispersion Potential .....</i>	22
6.2 <i>Ambient Air Quality.....</i>	23
6.2.1 <i>Data recovery .....</i>	23
6.2.2 <i>Sulphur Dioxide (SO<sub>2</sub>) .....</i>	24
6.2.3 <i>Nitrogen Dioxide (NO<sub>2</sub>).....</i>	25
6.2.4 <i>Particulates (PM<sub>10</sub> and PM<sub>2.5</sub>) .....</i>	28

6.2.5	Ambient pollutant summary .....	30
<b>7.</b>	<b>IMPACT OF ENTERPRISE ON THE RECEIVING ENVIRONMENT.....</b>	<b>31</b>
7.1	<i>Dispersion Modelling</i> .....	31
7.1.1	Models used.....	31
7.1.2	TAPM and CALPUFF parameterisation .....	31
7.1.3	Model accuracy .....	34
7.1.4	Assessment scenarios .....	35
7.2	<i>Dispersion Modelling Results</i> .....	35
7.2.1	Maximum predicted ambient concentrations .....	36
7.2.2	Predicted concentrations at AQMS and sensitive receptors .....	37
7.2.4	Isopleth maps .....	50
7.2.3.1	Sulphur dioxide (SO <sub>2</sub> ).....	50
7.2.3.2	Nitrogen dioxide (NO <sub>2</sub> ).....	66
7.2.3.3	Particulates (PM <sub>10</sub> ) .....	77
7.2.3.4	Particulates (PM <sub>2.5</sub> ).....	88
7.5	<i>Analysis of Emissions' Impact on the Environment</i> .....	99
<b>8.</b>	<b>COMPLAINTS .....</b>	<b>99</b>
<b>9.</b>	<b>CURRENT OR PLANNED AIR QUALITY MANAGEMENT INTERVENTIONS .....</b>	<b>99</b>
<b>10.</b>	<b>COMPLIANCE AND ENFORCEMENT ACTIONS.....</b>	<b>99</b>
<b>11.</b>	<b>SUMMARY AND CONCLUSION .....</b>	<b>99</b>
<b>12.</b>	<b>REFERENCES.....</b>	<b>101</b>
<b>13.</b>	<b>FORMAL DECLARATIONS .....</b>	<b>103</b>
<b>ANNEXURE 1:</b>	<b>NEMA REGULATION – APPENDIX 6 .....</b>	<b>106</b>
<b>ANNEXURE 2:</b>	<b>CURRICULUM VITAE.....</b>	<b>109</b>



## LIST OF TABLES

Table 2-1: Enterprise details.....	2
Table 2-2: Site information.....	3
Table 2-3: Land types, use and structures and vegetation cover .....	3
Table 2-4: Sensitive receptors and AQMS within 30 km of Lethabo .....	5
Table 2-5: Current authorisations related to air quality .....	7
Table 3-1: Details of the Listed Activity for Lethabo Power Station according to GN 248 (DEA, 2010) and its amendments (DEA, 2013b, 2019, 2020).....	9
Table 3-2: NAAQS for pollutants relevant to Lethabo .....	10
Table 3-3: Unit processes at Lethabo.....	11
Table 4-1: Raw Materials Used.....	12
Table 4-2: Production and by-product rates at Lethabo .....	12
Table 4-3: Materials used in energy sources.....	12
Table 4-4: Appliance and abatement equipment control technology currently used at Lethabo Power Station .....	13
Table 5-1: Lethabo physical stack parameters .....	14
Table 5-2: Lethabo stack emission parameters .....	14
Table 5-3: Stack emission rates and equivalent concentrations for this assessment .....	15
Table 5-4: Characteristics of the ash dump at the Power Station .....	16
Table 5-5: Fugitive sources at Lethabo Power Station .....	17
Table 5-6: Emergency incidents at Lethabo Power Station.....	18
Table 6-1: Data recovery at the Rand Water, Three Rivers AQMS and Sharpeville AQMS from 2021 to 2023 .....	24
Table 6-2: Pollutant exceedance summary at the Rand Water and Three Rivers AQMS from 2021 to 2023 .....	30
Table 7-1: Parameterisation of key variables for CALMET .....	34
Table 7-2: Parameterisation of key variables for CALPUFF .....	34
Table 7-3: Maximum predicted ambient annual SO <sub>2</sub> , NO <sub>2</sub> , PM <sub>10</sub> and PM <sub>2.5</sub> concentrations in µg/m <sup>3</sup> and the predicted 99 <sup>th</sup> percentile concentrations for 24-hour and 1- hour averaging periods, with the South African NAAQS .....	37
Table 7-4: Measured annual average concentration the Rand Water and Three Rivers AQMS compared with predicted concentrations in µg/m <sup>3</sup> .....	38
Table 7-5: Predicted concentrations in µg/m <sup>3</sup> and number of exceedance (NoE) at the sensitive receptors for Scenario 1 (Current) (NAAQS limit values in brackets) .....	40
Table 7-6: Predicted concentrations in µg/m <sup>3</sup> and number of exceedance (NoE) at the sensitive receptors for Scenario A (2025) (NAAQS limit values in brackets)	42
Table 7-7: Predicted concentrations in µg/m <sup>3</sup> and number of exceedance (NoE) at the sensitive receptors for Scenario B (2031)(NAAQS limit values in brackets) .	44
Table 7-8: Predicted concentrations in µg/m <sup>3</sup> and number of exceedance (NoE) at the sensitive receptors for Scenario C (2036) (NAAQS limit values in brackets)	46
Table 7-9: Predicted concentrations in µg/m <sup>3</sup> and number of exceedance (NoE) at the sensitive receptors for Scenario D (MES) (NAAQS limit values in brackets) .	48

## LIST OF FIGURES

Figure 2-1: Relative location of Lethabo showing a 5 km radius from the centre of the site (Google Earth, 2024) .....	4
Figure 3-1: Relative location of the different process units at Lethabo .....	11
Figure 6-1: Average monthly maximum and minimum temperature, and average monthly rainfall at Vereeniging <a href="https://www.meteoblue.com/en/weather/historyclimate/climatemodelled/vereeniging_south-africa_944385">https://www.meteoblue.com/en/weather/historyclimate/climatemodelled/vereeniging_south-africa_944385</a> .....	20
Figure 6-2: Annual windrose at the Rand Water AQMS .....	21
Figure 6-3: Seasonal (top) and diurnal (bottom) windroses at the Rand Water AQMS ..	22
Figure 6-4: 10-minute average SO <sub>2</sub> concentrations at Rand Water AQMS from 2021 to 2023 .....	26
Figure 6-5: 1-hour average SO <sub>2</sub> concentrations at Rand Water, Three Rivers and Sharpeville AQMS from 2021 to 2023 .....	26
Figure 6-6: 24-hour average SO <sub>2</sub> concentrations at Rand Water, Three Rivers and Sharpeville AQMS from 2021 to 2023 .....	27
Figure 6-7: 1-hour average NO <sub>2</sub> concentrations at Rand Water, Three Rivers and Sharpeville AQMS from 2021 to 2023 .....	27
Figure 6-8: 24-hour average PM <sub>10</sub> concentrations at Three Rivers and Sharpeville AQMS for 2021 to 2023 .....	29
Figure 6-9: 24-hour average PM <sub>2.5</sub> concentrations at Rand Water, Three Rivers and Sharpeville AQMS for 2021 to 2023 .....	29
Figure 7-1: TAPM and CALPUFF modelling domains for Lethabo .....	33
Figure 7-2: Predicted annual average SO <sub>2</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario 1 (Current)(NAAQS limit 50 ug/m <sup>3</sup> ) ...	51
Figure 7-3: Predicted 99 <sup>th</sup> percentile 24-hour SO <sub>2</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario 1 (Current) (NAAQS limit 125 ug/m <sup>3</sup> )	52
Figure 7-4: Predicted 99 <sup>th</sup> percentile 1-hour SO <sub>2</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario 1 (Current) (NAAQS limit 350 ug/m <sup>3</sup> )	53
Figure 7-5: Predicted annual average SO <sub>2</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario A (2025) (NAAQS limit 50 ug/m <sup>3</sup> ) .....	54
Figure 7-6: Predicted 99 <sup>th</sup> percentile 24-hour SO <sub>2</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario A (2025) (NAAQS limit 125 ug/m <sup>3</sup> ) ...	55
Figure 7-7: Predicted 99 <sup>th</sup> percentile 1-hour SO <sub>2</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario A (2025) (NAAQS limit 300 ug/m <sup>3</sup> ) ...	56
Figure 7-8: Predicted annual average SO <sub>2</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario B (2031) (NAAQS limit 50 ug/m <sup>3</sup> ) .....	57
Figure 7-9: Predicted 99 <sup>th</sup> percentile 24-hour SO <sub>2</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario B (2031) (NAAQS limit 125 ug/m <sup>3</sup> ) ...	58
Figure 7-10: Predicted 99 <sup>th</sup> percentile 1-hour SO <sub>2</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario B (2031) (NAAQS limit 350 ug/m <sup>3</sup> ) ...	59
Figure 7-11: Predicted annual average SO <sub>2</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario C (2036) (NAAQS limit 50 ug/m <sup>3</sup> ) .....	60

Figure 7-12: Predicted 99 <sup>th</sup> percentile 24-hour SO <sub>2</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario C (2036) (NAAQS limit 125 ug/m <sup>3</sup> ) .....	61
Figure 7-13: Predicted 99 <sup>th</sup> percentile 1-hour SO <sub>2</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario C (2036) (NAAQS limit 350 ug/m <sup>3</sup> ) ...	62
Figure 7-14: Predicted annual average SO <sub>2</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario D (MES) (NAAQS limit 50 ug/m <sup>3</sup> ) .....	63
Figure 7-15: Predicted 99 <sup>th</sup> percentile 24-hour SO <sub>2</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario D (MES) (NAAQS limit 125 ug/m <sup>3</sup> ) .....	64
Figure 7-16: Predicted 99 <sup>th</sup> percentile 1-hour SO <sub>2</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario D (MES) (NAAQS limit 350 ug/m <sup>3</sup> ) ....	65
Figure 7-17: Predicted annual average NO <sub>2</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario 1 (Current) (NAQAS limit 40 ug/m <sup>3</sup> ) ..	67
Figure 7-18: Predicted 99 <sup>th</sup> percentile 1-hour NO <sub>2</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario 1 (Current) (NAAQS limit 200 ug/m <sup>3</sup> )	68
Figure 7-19: Predicted annual average NO <sub>2</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario A (2025) (NAAQS limit 40 ug/m <sup>3</sup> ) .....	69
Figure 7-20: Predicted 99 <sup>th</sup> percentile 1-hour NO <sub>2</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario A (2025) (NAAQS limit 200 ug/m <sup>3</sup> ) ...	70
Figure 7-21: Predicted annual average NO <sub>2</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario B (2031) (NAAQS limit 40 ug/m <sup>3</sup> ) .....	71
Figure 7-22: Predicted 99 <sup>th</sup> percentile 1-hour NO <sub>2</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario B (2031) (NAAQS limit 200 ug/m <sup>3</sup> ) ...	72
Figure 7-23: Predicted annual average NO <sub>2</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario C (2036) (NAAQS limit 40 ug/m <sup>3</sup> ) .....	73
Figure 7-24: Predicted 99 <sup>th</sup> percentile 1-hour NO <sub>2</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario C (2036) (NAAQS limit 200 ug/m <sup>3</sup> ) ...	74
Figure 7-25: Predicted annual average NO <sub>2</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario D (MES) (NAAQS limit 40 ug/m <sup>3</sup> ) .....	75
Figure 7-26: Predicted 99 <sup>th</sup> percentile 1-hour NO <sub>2</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario D (MES) (NAAQS limit 200 ug/m <sup>3</sup> ) ....	76
Figure 7-27: Predicted annual average PM <sub>10</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario 1 (Current) (NAAQS limit 40 ug/m <sup>3</sup> ) ..	78
Figure 7-28: Predicted 99 <sup>th</sup> percentile of the 24-hour PM <sub>10</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario 1 (Current) (NAAQS limit 75 ug/m <sup>3</sup> ) .....	79
Figure 7-29: Predicted annual average PM <sub>10</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario A (2025) (NAAQS limit 40 ug/m <sup>3</sup> ) .....	80
Figure 7-30: Predicted 99 <sup>th</sup> percentile of the 24-hour PM <sub>10</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario A (2025) (NAAQS limit 75 ug/m <sup>3</sup> ) .....	81
Figure 7-31: Predicted annual average PM <sub>10</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario B (2031) (NAAQS limit 40 ug/m <sup>3</sup> ) .....	82

Figure 7-32: Predicted 99 <sup>th</sup> percentile of the 24-hour PM <sub>10</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario B (2031) (NAAQS limit 75 ug/m <sup>3</sup> ) .....	83
Figure 7-33: Predicted annual average PM <sub>10</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario C (2036) (NAAQS limit 40 ug/m <sup>3</sup> ) .....	84
Figure 7-34: Predicted 99 <sup>th</sup> percentile of the 24-hour PM <sub>10</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario C (2036) (NAAQS limit 75 ug/m <sup>3</sup> ) .....	85
Figure 7-35: Predicted annual average PM <sub>10</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario D (MES) (NAAQS limit 40 ug/m <sup>3</sup> ) .....	86
Figure 7-36: Predicted 99 <sup>th</sup> percentile of the 24-hour PM <sub>10</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario D (MES) (NAAQS limit 75 ug/m <sup>3</sup> ) .....	87
Figure 7-37: Predicted annual average PM <sub>2.5</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario 1 (Current) (NAAQS limit 20 ug/m <sup>3</sup> ) ..	89
Figure 7-38: Predicted 99 <sup>th</sup> percentile of the 24-hour PM <sub>2.5</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario 1 (Current) (NAAQS limit 40 ug/m <sup>3</sup> ) .....	90
Figure 7-39: Predicted annual average PM <sub>2.5</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario A (2025) (NAAQS limit 20 ug/m <sup>3</sup> ) .....	91
Figure 7-40: Predicted 99 <sup>th</sup> percentile of the 24-hour PM <sub>2.5</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario A (2025) (NAAQS limit 40 ug/m <sup>3</sup> ) .....	92
Figure 7-41: Predicted annual average PM <sub>2.5</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario B (2031) (NAAQS limit 15 ug/m <sup>3</sup> ) .....	93
Figure 7-42: Predicted 99 <sup>th</sup> percentile of the 24-hour PM <sub>2.5</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario B (2031) (NAAQS limit 25 ug/m <sup>3</sup> ) .....	94
Figure 7-43: Predicted annual average PM <sub>2.5</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario C (2036) (NAAQS limit 15 ug/m <sup>3</sup> ) .....	95
Figure 7-44: Predicted 99 <sup>th</sup> percentile of the 24-hour PM <sub>2.5</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario C (2036) (NAAQS limit 25 ug/m <sup>3</sup> ) .....	96
Figure 7-45: Predicted annual average PM <sub>2.5</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario D (MES) (NAAQS limit 15 ug/m <sup>3</sup> ) .....	97
Figure 7-46: Predicted 99 <sup>th</sup> percentile of the 24-hour PM <sub>2.5</sub> concentrations in µg/m <sup>3</sup> resulting from emissions from Lethabo: Scenario D (MES) (NAAQS limit 25 ug/m <sup>3</sup> ) .....	98

# 1. INTRODUCTION

Eskom operates a fleet of 14 coal-fired power stations, collectively generating more than 39 000 MW of electricity. The combustion of coal to generate steam for the generation of electricity is a Listed Activity in terms of the National Environmental Management: Air Quality Act (Act No. 39 of 2004). Eskom holds Atmospheric Emission Licenses (AELs) for the respective power plants and is obligated to operate these plants according to conditions specified in the respective AELs. Minimum Emission Standards (MES) for Listed Activities were published in 2010 (DEA, 2010) including compliance timeframes for existing and new plants, however existing activities had to comply with the MES for new plants by 30 April 2020.

Between 2018 and 2020, Eskom submitted applications to the Department of Forestry, Fisheries and the Environment (DFFE) based on an internally approved Emission Reduction Plan, which defined which power stations in the fleet of 15 would have emission reduction technology installed and when. The National Air Quality Officer (NAQO) made decisions on these applications in 2019, which were not in favour of Eskom. Eskom appealed the NAQO's decision, and the Minister established the National Environmental Consultative and Advisory (NECA) Forum to advise her on the issue.

The Minister ruled on the Eskom appeals on 22 May 2024. The Minister granted the suspension of the Minimum Emission Standards (MES) at five (5) power stations up to 31 March 2030. The Minister further directed Eskom to submit an application in terms of Section 59 of the National Environmental Management: Air Quality Act for the exemption of the MES for eight (8) power stations that will continue to operate post 2030. The five power stations that will close by 2030 are Arnot, Camden, Grootvlei, Hendrina and Kriel. The eight power stations that will operate post 2030 are Duvha, Kendal, Lethabo, Majuba, Matimba, Matla, Medupi and Tutuka.

In terms of the Minister's ruling, Eskom Holdings SOC Ltd appointed WSP Group Africa (Pty) Ltd to prepare the necessary applications. WSP Group Africa (Pty) Ltd sub-contracted uMoya-NILU Consulting (Pty) Ltd to prepare the associated Atmospheric Impact Reports (AIRs) (DEA, 2013a) to support these applications.

Lethabo Power Station (hereafter referred to as Lethabo) is located in the Vaal Triangle Priority Air-Shed Area, 14 km northeast of Sasolburg, and southeast of Vereeniging and Vanderbijlpark. It has a base load generation capacity of 3 708 MW. Lethabo will be shutdown, starting in 2037 and completed by 2042. Eskom is currently applying for exemption from aspects of the MES for Lethabo until the shutdown.

## 2. ENTERPRISE DETAILS

### 2.1 Enterprise Details

The details of Lethabo are summarised in Table 2-1.

**Table 2-1: Enterprise details**

<b>Entity Name:</b>	Eskom Holdings SOC Limited
<b>Trading as:</b>	Lethabo Power Station
<b>Type of Enterprise, e.g. Company/Close Corporation/Trust, etc.:</b>	State Owned Company
<b>Company/Close Corporation/Trust Registration Number (Registration Numbers if Joint Venture):</b>	2002/015527/30
<b>Registered Address:</b>	Megawatt Park, Maxwell Drive, Sunninghill, Sandton
<b>Postal Address:</b>	P O Box 415, Vereeniging, 1930
<b>Telephone Number (General):</b>	016 457 5111
<b>Fax Number (General):</b>	Not applicable
<b>Company Website:</b>	www.eskom.co.za
<b>Industry Type/Nature of Trade:</b>	Electricity Generation
<b>Land Use Zoning as per Town Planning Scheme:</b>	Agricultural/Heavy industry
<b>Land Use Rights if outside Town Planning Scheme:</b>	Not applicable
<b>Responsible Person:</b>	Karabo Rakgolela
<b>Emissions Control Officer:</b>	Willem de Klerk
<b>Telephone Number:</b>	016 457 5500
<b>Cell Phone Number:</b>	072 797 8019
<b>Fax Number:</b>	Not applicable
<b>Email Address:</b>	rakgolk@eskom.co.za
<b>After Hours Contact Details:</b>	016 457 5604

### 2.2 Location and extent of the power station

Lethabo Power Station is located in the Vaal Triangle Priority Air-Shed Area, approximately 13 km northeast of Sasolburg in the Free State Province. The relevant site information is provided in Table 2-2. Its relative location is illustrated in Figure 2-1 and Figure 7-1.



**Table 2-2: Site information**

<b>Physical Address of the Licensed Premises:</b>	Farm Lethabo Power Station No. 1814
<b>Description of Site:</b>	Farm Lethabo Power Station No. 1814
<b>Property Registration Number (Surveyor-General Code):</b>	N/A
<b>Coordinates (latitude, longitude) Centre of Operations (Decimal Degrees):</b>	Latitude: -26.741035° Longitude: 27.975780°
<b>Coordinates (UTM) Centre of Operations (UTM 35S):</b>	UTM reference – Grid Zone: 35S Easting: 597 035.77 m E Northing: 7041 875.20 m S
<b>Extent (km<sup>2</sup>):</b>	10.85
<b>Elevation Above Mean Sea Level (m):</b>	1 465 m
<b>Province:</b>	Free State
<b>District/Metropolitan Municipality:</b>	Fezile Dabi District Municipality
<b>Local Municipality:</b>	Metsimaholo Local Municipality
<b>Designated Priority Area (if applicable):</b>	Vaal Triangle Air-Shed Priority Area


## 2.3 Description of surrounding land use

The Code of Practice for Air Dispersion Modelling in Air Quality Management in South Africa (DEA, 2014a) recommends the Land Use Procedure as sufficient for determining the urban/rural status of a modelling domain. The classification of the study area as urban or rural is based on the Auer method (Auer, 1978), as specified in the USEPA guideline on air dispersion models (USEPA, 2005). From the Auer's method, areas typically defined as rural include residences with grass lawns and trees, large estates, metropolitan parks and golf courses, agricultural areas, undeveloped land and water surfaces. An area is defined as urban if it has less than 35% vegetation coverage or it falls into one of the use types in Table 2-3.

**Table 2-3: Land types, use and structures and vegetation cover**

<b>Type</b>	<b>Use and Structures</b>	<b>Vegetation</b>
<b>I1</b>	Heavy industrial	Less than 5 %
<b>I2</b>	Light/moderate industrial	Less than 5 %
<b>C1</b>	Commercial	Less than 15 %
<b>R2</b>	Dense single / multi-family	Less than 30 %
<b>R3</b>	Multi-family, two-story	Less than 35 %

Lethabo Power Station is located approximately 13 km northeast of Sasolburg in the Free State Province. The surrounding land use includes coal mining, heavy industry, agricultural and residential areas. Figure 2-1 shows the location of Lethabo and landuses within a 5 km radius.



**Figure 2-1: Relative location of Lethabo showing a 5 km radius from the centre of the site (Google Earth, 2024)**

The US Environmental Protection Agency (USEPA, 2024a) recognise Sensitive Receptors as areas which include, but are not limited to hospitals, schools, daycare facilities, elderly housing and convalescent facilities or specialised healthcare facilities. These are areas where the occupants are more susceptible to the adverse effects of exposure to toxic chemicals, pesticides and other pollutants. The California Air Resources Board (CARB, 2024) identify Sensitive Receptors as children, elderly, asthmatics and others who are at a heightened risk of negative health outcomes due to exposure to air pollution. Five ambient air quality monitoring stations (AQMS) and 54 sensitive receptor points were identified within 30 km of Lethabo (Table 2-4).

**Table 2-4: Sensitive receptors and AQMS within 30 km of Lethabo**

Receptor	UTMx	UTMy
Sharpeville - Monitoring Station	586.333	7047.627
Sebokeng - Monitoring Station	583.743	7058.929
Three Rivers - Monitoring Station	599.457	7051.167
Zamdela - Monitoring Station	584.958	7030.458
Rand Water - Monitoring Station	600.337	7047.863
Vaal Power AH	598.896	7032.778
Sasolburg Provincial Hospital	582.219	7035.338
Moredou Old Age Home	581.349	7033.170
Ons Gryse Jeug Old Age Home	582.418	7034.454
Noord Primêre Skool	582.807	7034.439
Sasolburg High School	581.052	7034.405
Sakhubusa Secondary School	586.659	7028.288
Bekezela Primary School	588.929	7028.948
Isaac Mhlambi Primary	585.492	7030.636
Refenkgotso Primary School	606.444	7024.545
Deneysville Primary school	608.441	7024.753
Netcare Vaalpark Hospital	583.511	7038.440
Vaalpark Articon Secondary School	584.962	7039.086
Mediclinic Emfuleni	583.308	7045.959
Jeugland Old Age Home	582.458	7044.947
Herfsoord Huis Old Age Home	582.423	7045.946
Huis Princilla	582.585	7047.990
Laerskool Emfulenipark	584.348	7042.455
NW University - Vaal Campus	587.758	7043.265
Emfuleni Primary School	579.441	7046.407
Mediclinic Vereeniging	592.269	7049.848
Kopanong Provincial Hospital (Duncanville)	592.900	7053.274
Avondrus Eventide Old Age Home	593.006	7052.795
Riviera On Vaal Resort	593.483	7049.158
Sedibeng TVET college	592.728	7048.750
General Smuts High School	591.307	7049.467
Eureuka School & Selbourne Primary	591.006	7049.754



Receptor	UTMx	UTMy
Midvaal Private Hospital (Three Rivers)	596.465	7050.419
Three Rivers Retirement Village	596.630	7051.472
Drie Riviere Aftreeoord Old Age Home	596.758	7052.137
Riverside High School	599.249	7051.128
Risiville Primary School	597.737	7052.417
Sebokeng Hospital	584.382	7056.795
Clinix Naledzi Private Hospital	584.451	7055.815
Mohloli Secondary School	587.419	7047.400
Tshirela Primary School (Boipatong)	584.244	7050.154
Tsoaranang Primary School (Thepiso)	587.115	7049.512
Thepiso Primary School	587.145	7051.767
Emmanuel Primary School	587.884	7049.120
Rust Ter Vaal Combined School	594.323	7060.208
Roshnee Primary School	593.719	7062.193
Roshnee High School	593.851	7061.252
Hoerskool DR Malan	601.513	7061.343
Laerskool Voorwaarts	604.200	7057.246
Meyerton Secondary School	599.881	7059.032
Ratasetjhaba Primary School	597.928	7062.652
Meyerton Primary School	601.629	7062.614
Oprah Leadership Academy	605.123	7063.300
Henley River Retirement Village	605.847	7063.097
Henley High & Preparatory School	605.696	7065.359
Randvaal Clinic	604.115	7066.811
Laerskool Japie Greyling	606.189	7069.320
Thomas Nhlapo Primary	606.621	7067.814
Randvaal Old Age Home	602.857	7069.487

## 2.4 Emission Control Officer

Lethabo's Emission Control Officer (ECO) is Willem de Klerk. See Table 2-1 for contact details.

## 2.5 Atmospheric Emission License (AEL) and other Authorisations

The Atmospheric Emissions Licence (AEL) (No. FDDM-MET-2011-08-P1) held by Lethabo was issued by the Fezile Dabi District Municipality in April 2015 Fezile Dabi District Municipality, 2015) and was valid until 31 March 2020. The AEL was renewed and then expired on 31 March 2023. The AEL is in respect of three Listed Activities (Table 2-5) and specifies permissible stack emission concentrations for particulate matter (PM), sulphur dioxide (SO<sub>2</sub>) and oxides of nitrogen (NO<sub>x</sub>). The AEL renewal process is on hold until a decision is made

concerning the exemption application, however the station has a communication from DFFE stating that the existing AEL remain valid.

**Table 2-5: Current authorisations related to air quality**

<b>Atmospheric Emission License</b>	<b>Dates</b>	<b>Listed Activity Category</b>	<b>Sub-category</b>	<b>Listed Activity Process Description</b>
FDDM-MET-2011-08-P1	Issued: 01 April 2015	1	1.1	Solid Fuel Combustion Installations
	Expired: 31 March 2020	2	2.4	Storage and Handling of Petroleum Products

## 2.6 Modelling contractor

The dispersion modelling for this AIR is conducted by:

Company: uMoya-NILU Consulting (Pty) Ltd  
 Modellers: Dr Mark Zunckel, Atham Raghunandan, Nopasika Xulu  
 Contact details: Tel: 031 262 3265  
 Cell: 083 690 2728  
 email: mark@umoya-nilu.co.za  
 atham@umoya-nilu.co.za  
 nopasika@umoya-nilu.co.za

See Annexure 2 for abridged CV's

## 2.7 Terms of Reference

The Terms of Reference are to prepare an Atmospheric Impact Report (AIR) according to regulations prescribing the format of an AIR (DEA, 2013a), to support the application for exemption of the MES for Lethabo Power Station. In so doing, five emission scenarios are assessed to support Eskom's application for exemption from the MES at Lethabo. These are:

- Scenario 1 (Current): The baseline scenario using actual monthly stack emissions for 2021-2023 and fugitive emissions from the ash dump.
- Scenario A (2025): Eskom's planned 2025 stack emissions, representing anticipated station performance between 2025 – 2030, including fugitive emissions from the ash dump.
- Scenario B (2031): Eskom's planned 2031 stack emissions, representing anticipated station performance between 2031 – 2035, including fugitive emissions from the ash dump.
- Scenario C (2036): Eskom's planned 2036 stack emissions, representing anticipated station performance from 2036 onwards, including fugitive emissions from the ash dump.

Scenario D (MES): Full compliance with the MES, including fugitive emissions from the ash dump

## **2.8 Assumptions**

The following assumptions are relevant to this AIR:

- a) No ambient monitoring is done in this assessment, rather available ambient air quality data is used.
- b) The assessment of potential human health impacts is based on predicted (modelled) ambient concentrations of SO<sub>2</sub>, NO<sub>2</sub>, PM<sub>10</sub> and PM<sub>2.5</sub> and the health-based National Ambient Air Quality Standards (NAAQS).
- c) The PM emissions are not speciated into PM<sub>10</sub> and PM<sub>2.5</sub>, rather all PM emitted is assumed to be PM<sub>10</sub>, and all PM emitted is assumed to be PM<sub>2.5</sub>. This represents a worse-case emission scenario for PM<sub>10</sub> and PM<sub>2.5</sub>.
- d) Assumptions regarding emissions from the ash dump are included in Section 5.4



### 3. NATURE OF THE PROCESS

#### 3.1 Listed Activity or Activities

As a measure to reduce emissions from industrial sources and to improve ambient air quality, Listed Activities and associated Minimum Emission Standards (MES) were initially published in 2010 in Government Notice 248 (DEA, 2010) with the most recent revision applicable in 2020 (Government Notice 421, DEA, 2020).

The Listed Activities relevant to Lethabo Power Station are listed in Table 3-1.

**Table 3-1: Details of the Listed Activity for Lethabo Power Station according to GN 248 (DEA, 2010) and its amendments (DEA, 2013b, 2019, 2020)**

Category of Listed Activities	Sub-category of Listed Activity	Description of Listed Activity	Description and Application of the Listed Activity
1: Combustion Installations	1.1: Solid Fuel Combustion Installations	Solid fuels combustion installations used primarily for steam raising or electricity generation.	All installations with design capacity equal to or greater than 50 MW heat input per unit, based on the lower calorific value of the fuel used.
2: Petroleum Industry, the production of gaseous and liquid fuels as well as petrochemicals from crude oil, coal, gas or biomass	2.4: Storage and handling of petroleum products	Petroleum products storage tanks and product transfer facilities.	All permanent immobile liquid storage facilities at a single site with a combined storage capacity of greater than 1 000 cubic metres.

#### 3.2 Process Description

Eskom Holdings SOC Limited is a South African utility that generates, transmits and distributes electricity. The bulk of that electricity is generated by large coal-fired power stations that are situated close to the sources of coal. Lethabo is one such station. Lethabo has a base load generation capacity of 3 810 MW, generated in 6 units, each with a maximum installed capacity of 635 MW.

Lethabo receives coal from the nearby coal mine, New Vaal Colliery. The coal is conveyed to the coal stockyard on site where it is milled to pulverised fuel and fed to the six boilers. Combustion of the coal in the boilers heats water to superheated steam, which drives the turbines. In turn, the turbines drive the generators which generate electricity.

### 3.3 Air pollutants resulting from the process

#### 3.3.1 Air pollutants

Atmospheric emissions depend on the fuel composition and rate of consumption, boiler design and operation, and the efficacy of pollution control devices. Emissions from the boilers are emitted via two stacks and include sulphur dioxide (SO<sub>2</sub>), oxides of nitrogen (NO + NO<sub>2</sub> = NO<sub>x</sub>) and Particulate Matter (PM).

SO<sub>2</sub> is produced from the combustion of sulphur bound in coal. The stoichiometric ratio of SO<sub>2</sub> to sulphur dictates that 2 kg of SO<sub>2</sub> are produced from every kilogram of sulphur combusted. The coal used by the Lethabo Power Station has a sulphur content (wt %) of less than 1 %. NO<sub>x</sub> is produced from thermal fixation of atmospheric nitrogen in the combustion flame and from oxidation of nitrogen bound in the coal. The quantity of NO<sub>x</sub> produced is directly proportional to the temperature of the flame.

The non-combustible portion of the fuel remains as solid waste. The coarse, heavier waste is called 'bottom ash' and is extracted from the boiler, and the light, finer portion is 'fly ash' and is usually suspended in the flue gas, and in the absence of any emission control would be emitted as PM through the stack. The coal used at Lethabo has an ash content of between 40 and 45%.

#### 3.3.2 National Ambient Air Quality Standards

National Ambient Air Quality Standards (NAAQS) (DEA, 2009, 2012) apply to the pollutants emitted by Lethabo. The NAAQS consists of a 'limit' value and a permitted frequency of exceedance. The limit value is the fixed concentration level aimed at reducing the harmful effects of a pollutant. The permitted frequency of exceedance represents the acceptable number of exceedances of the limit value expressed as the 99<sup>th</sup> percentile. Compliance with the ambient standard implies that the frequency of exceedance of the limit value does not exceed the permitted tolerance. The NAAQS for SO<sub>2</sub>, NO<sub>2</sub>, PM<sub>10</sub> and PM<sub>2.5</sub> are presented in Table 3-2. The NAAQS are health-based standards and compliance with the NAAQS implies an acceptable level of risk.

**Table 3-2: NAAQS for pollutants relevant to Lethabo**

Pollutant	Averaging period	Limit value (µg/m <sup>3</sup> )	Tolerance
SO <sub>2</sub>	1 hour	350	88
	24 hour	125	4
	1 year	50	0
NO <sub>2</sub>	1 hour	200	88
	1 year	40	0
PM <sub>10</sub>	24 hour	75	4
	1 year	40	0
PM <sub>2.5</sub>	24 hour	40 (25 <sup>a</sup> )	4
	1 year	20 (15 <sup>a</sup> )	0


(a): Applicable from 01 January 2030

### 3.4 Unit Processes

A summary of the different unit process at Lethabo is provided in Table 3-3. The relative location of these at Lethabo is shown in Figure 3-1.

**Table 3-3: Unit processes at Lethabo**

Unit Process	Function of Unit Process	Batch or Continuous Process
<b>Boiler Unit 1</b>	Generation of electricity from coal	Continuous
<b>Boiler Unit 2</b>	Generation of electricity from coal	Continuous
<b>Boiler Unit 3</b>	Generation of electricity from coal	Continuous
<b>Boiler Unit 4</b>	Generation of electricity from coal	Continuous
<b>Boiler Unit 5</b>	Generation of electricity from coal	Continuous
<b>Boiler Unit 6</b>	Generation of electricity from coal	Continuous
<b>Fuel oil storage tanks</b>	Storage of fuel oil	Continuous



**Figure 3-1: Relative location of the different process units at Lethabo**

## 4. TECHNICAL INFORMATION

### 4.1 Raw materials used

The permitted raw materials consumption rate, the permitted production rates and the energy sources at Lethabo are listed in Table 4-1 to Table 4-3 according to the AEL.

**Table 4-1: Raw Materials Used**

Type	Maximum Permitted Consumption Rate	Design Consumption Rate	Actual Average Consumption Rate	Unit
Coal	2 000 000	2 000 000	2 000 000	Tonnes/month
Fuel oil	1 700	1 700	1 700	Tonnes/month

**Table 4-2: Production and by-product rates at Lethabo**

Product/by-product	Maximum Production capacity permitted (volume)	Unit (quantity/period)
Electricity	3 810	MW
Ash	9 600 000	Tonnes/year

**Table 4-3: Materials used in energy sources**

Raw Material	Maximum Permitted Consumption Rate	Unit	Material Characteristics (Monthly Average)
Coal	2 000 000	tonnes/month	Sulfur content: 0.6 – 1.2% Ash content: 40 – 45%
Fuel oil	1 700	tonnes/month	Sulfur content: 3.5 max % Ash content: 0.1%

### 4.2 Appliances and Abatement Equipment Control Technology

Decommissioning of Lethabo is planned from 2037 to 2042. In the meantime, particulate emissions are controlled by operating and maintaining Electrostatic Precipitators on Units 1 to 5, and SO<sub>3</sub> Injection Plants on Units 2, 3 and 5. The installation of Low NO<sub>x</sub> burners are planned from 2027.

**Table 4-4: Appliance and abatement equipment control technology currently used at Lethabo Power Station**

<b>Appliance Name</b>	<b>Appliance Type/Description</b>	<b>Appliance Function / Purpose</b>
Electrostatic Precipitator (ESP)	Electrostatic Precipitator (ESP) with High Frequency Power Supply (HFPS)	An ESP removes particles from the flue stream using the force of an induced electrostatic charge on the ash particle that is then attracted to and held on a plate. HFPS increase collection efficiency of the ESP. SO <sub>3</sub> injection (i.e. Flue Gas Conditioning Plan) decreases the resistivity of the particles, and significantly improves the performance of the ESP.
SO <sub>3</sub> Plant	SO <sub>3</sub> Injection	

## 5. ATMOSPHERIC EMISSIONS

### 5.1 Point Source Parameters

The physical stack parameters and emission parameters for stacks at Lethabo are listed in Table 5-1 and Table 5-2 respectively.

**Table 5-1: Lethabo physical stack parameters**

Stack ID	Point Source Code	Source Name	Stack Orientation	Lat (dec degs)	Longitude (dec deg)	Height of Release (m)		Diameter at Stack Tip (m <sup>a</sup> )
						Above Ground	Above nearest bldg	
Stack 1	Boiler unit 1-3	SV Unit 1-3	Vertical	7 041 798 S	597 261 E	275	200	13.34
Stack 2	Boiler unit 4-6	SV Unit 4-6	Vertical	7 041 693 S	597 029 E	275	200	13.34

(a): Individual boiler flues have a diameter of approximately 8.275 m. The combined stack diameter is 13.34 m.

**Table 5-2: Lethabo stack emission parameters**

Scenario	Stack ID	Actual Gas Exit Temp (K)	Actual Gas Volumetric Flow (Am <sup>3</sup> /s)	Normal Gas Volumetric Flow (Nm <sup>3</sup> /s) <sup>b</sup>	Actual Gas Exit Velocity (m/s) <sup>c</sup>
<b>Scenario 1 (Current)</b>	Stack 1	418	3 159	1 711	22.6
	Stack 2	418	3 159	1 711	22.6
<b>Scenario A (2025)</b>	Stack 1	418	2 656	1 438	19
	Stack 2	418	2 656	1 438	19
<b>Scenario B (2031)</b>	Stack 1	418	1 705	923	12.2
	Stack 2	418	1 705	923	12.2
<b>Scenario C (2036)</b>	Stack 1	418	1 887	1 022	13.5
	Stack 2	418	1 887	1 022	13.5
<b>Scenario D (MES)</b>	Stack 1	418	1 887	1 022	13.5
	Stack 2	<b>418</b>	<b>1 887</b>	<b>1 022</b>	13.5

(a): Normal flow corrected to 10% O<sub>2</sub>, 101 kPa and 273.15K

(b): The average of the actual gas exit velocity was used in the simulations

### 5.2 Point Source Emission Rates (Emission scenarios)

Five emission scenarios are assessed to support Eskom's application for exemption from the MES at Lethabo. These are:



Scenario 1 (Current): The baseline scenario using actual monthly stack emissions for 2021-2023 and fugitive emissions from the ash dump.

Scenario A (2025): Eskom's planned 2025 stack emissions, representing anticipated station performance between 2025 – 2030, including fugitive emissions from the ash dump.

Scenario B (2031): Eskom's planned 2031 stack emissions, representing anticipated station performance between 2031 – 2035, including fugitive emissions from the ash dump.

Scenario C (2036): Eskom's planned 2036 stack emissions, representing anticipated station performance from 2036 onwards, including fugitive emissions from the ash dump.

Scenario D (MES): Full compliance with the MES, representing the unattainable scenario.

The estimated emission rates and equivalent emission concentrations that are used in the dispersion modelling for the two stacks are shown in Table 5-3. The maximum anticipated emissions during each period are used for simulation in the model. The boiler units are assumed to operate continuously, i.e. 24 hours a day. Since each future scenario is a snapshot of period of operation (e.g. Scenario A = 2025 to 2030), the maximum anticipated emissions during that period, in a single year was selected for simulation in the model.

**Table 5-3: Stack emission rates and equivalent concentrations for this assessment**

Scenario	Stack	Emission rate (tons/annum)			Emission concentration @ 10% O <sub>2</sub> and average load (mg/Nm <sup>3</sup> )		
		NO <sub>x</sub>	SO <sub>2</sub>	PM	NO <sub>x</sub>	SO <sub>2</sub>	PM
1 <sup>a</sup>	Stack 1	51 234	100 147	5 740	696	1 360	78
	Stack 2	51 234	100 147	5 740	696	1 360	78
A	Stack 1	46 808	99 197	3 720	755	1 600	60
	Stack 2	46 808	99 197	3 720	755	1 600	60
B	Stack 1	28 583	56 370	1 393	718	1 416	35
	Stack 2	28 583	56 370	1 393	718	1 416	35
C	Stack 1	22 246	59 258	1 542	505	1 345	35
	Stack 2	22 246	59 258	1 542	505	1 345	35
D	Stack 1	22 246	17 777	1 542	505	404	35
	Stack 2	22 246	17 777	1 542	505	404	35
MES					750	1 000	50

(a): Average from actual monthly emissions

### 5.3 Point Source Maximum Emission Rates (Start Up, Shut-Down, Upset and Maintenance Conditions)

Lethabo is required to conduct continuous emission measurements. Maximum emissions during start-up, shut-down, maintenance or upset conditions are accounted for in the actual monthly emissions provided to the modelling team. These conditions are therefore incorporated into the simulations for Scenario A (Current).

## 5.4 Fugitive Emissions

The methodology to estimate emission rates of particulates from the ash dumping activities for the power station is described in this section.

A general equation for emission estimation is:  $E = A \times EF \times (1-ER/100)$

where: E = emissions;  
A = activity rate;  
EF = emission factor; and  
ER = overall emission reduction efficiency (%)

An emission factor is a representative value that relates the quantity of a pollutant released to the atmosphere with an activity associated with the release of that pollutant. These factors are usually expressed as the weight of the pollutant divided by a unit weight, volume, distance, or duration of the activity emitting the pollutant (e.g., kg of particulate emitted per tonne of coal crushed). Such factors facilitate estimation of emissions from various sources of air pollution. In most cases, these factors are simply averages of all available data of acceptable quality, and are generally assumed to be representative of long-term averages for all facilities in the source category (USEPA, 2024b).

The emission factors used for the calculation of particulates in this study are the most recent factors published in the United States Environmental Protection Agency (US EPA), AP 42, Fifth Edition, Compilation of Air Pollutant Emission Factors, Volume 1: Stationary Point and Area Sources, Chapter 13: Section 13.2.4 Aggregate Handling and Storage Piles; Section 13.2.5 Industrial Wind Erosion; (USEPA, 2024b).

Wind entrainment of particulates from the ash dump is a function of the physical size of the facility and the nature of the exposed surface, i.e. the moisture content, silt content, size of the particles on the surface and wind speed. Characteristics of the ash dump at the power station is shown in Table 5-4.

**Table 5-4: Characteristics of the ash dump at the Power Station**

Parameter	Ash dump
Quantity of material disposed (tonnes/year)	5 085 191
Moisture content (%)	27
Silt content (%)	80
Exposed surface area (m <sup>2</sup> )	1 105 898
Height (m)	43
Dry area (%)	80
Dust abatement method	Spraying of dust using water during operation, top soil and vegetation coverage at incremental heights
Ashing system	Dry (delivered by truckconveyor belts)

The ash dump, by nature, is generally in a damp state depending on rainfall conditions, and if the ash is pumped onto the ash dump in a fluid state or trucked in. Rising green walls will provide vegetation cover on the sides and it is expected that most of the ash dump area exposed at the top will include a wet beach area. These initiatives, together with occasional wetting will reduce the amount of dust entrainment from the ash dump.

In this assessment, the ash dump is modelled under worst case conditions (e.g. drought conditions), where it is assumed that it is mostly dry and 80% of the surface area is exposed to wind erosion. This provides a worst-case (environmentally conservative) scenario. The annual emission rates for the ash dump is shown in Table 5-5.

**Table 5-5: Fugitive sources at Lethabo Power Station**

Source name	Emission (tonnes/year)		
	TSP	PM <sub>10</sub>	PM <sub>2.5</sub>
Ash Dump	6 175	3 087	1 235

## 5.5 Emergency Incidents

A record is maintained for all emergency incidents at Lethabo reported in terms of Section 30 of the National Environmental Management Act. A list of emergency incidents at Lethabo Power Station from 2021 to 2023 is provided in Table 5-6.

**Table 5-6: Emergency incidents at Lethabo Power Station**

<b>ID</b>	<b>Event date</b>	<b>Event</b>	<b>Incident Root Cause Summary</b>
114291	2021/01/01	Unit 2 NEMA S30	Sulphur supply line steam jacket leak
113098	2021/01/02	Unit 5 NEMA S30	SO <sub>3</sub> plant combustion air inlet pipe expansion joint gasket damaged
114208	2021/01/11	Unit 1 NEMA S30	SO <sub>3</sub> plant combustion chamber flooded with sulphur
113389	2021/01/31	Unit 3 NEMA S30	SO <sub>3</sub> plant failed as a result of converter air pipe expansion joint
114605	2021/04/20	Unit 1 NEMA S30	Insufficient build-up of heat in the sulphur inlet pipes due to condensate caused by damaged drain valve plug.
114910	2021/05/11	Unit 6 NEMA S30	Turbine trip due to HP Exhaust Shell thermocouple faulty.
114989	2021/05/18	Unit 5 NEMA S30	Fire in the SO <sub>3</sub> plant resulting in plant equipment damage.
115126	2021/05/31	Unit 4 NEMA S30	Damage turbulator outlet pipe resulting in sulphur leak in the SO <sub>3</sub> plant.
116261	2021/08/30	Unit 2 NEMA S30	Damage SO <sub>3</sub> air heater gasket causing high air heater leakages resulting in sulphur build up on the combustion chamber
116438	2021/09/14	Unit 2 NEMA S30	Both Air heaters and air blower silencer were identified to be leaking during the normal plant operation.
116694	2021/10/07	Unit 1 NEMA S30	Poor performance of the electrostatic precipitators(ESP's) Left hand Inner and Outer casing
117432	2021/12/09	Unit 3 NEMA S30	Poor ESPs casing performance, attributed to defective fields.
117709	2022/01/11	Unit 4 NEMA S30	SO <sub>3</sub> plant air heater thyristor drive failure which affected the SO <sub>3</sub> plant temperature increase to start dosing sulphur
118094	2022/02/08	Unit 6 NEMA S30	Both stackers and emergency offloading were unavailable.
118101	2022/02/09	Unit 5 NEMA S30	Both stackers and emergency offloading were unavailable.
118107	2022/02/10	Unit 4 NEMA S30	Both stackers and emergency offloading were unavailable.
118254	2022/02/21	Unit 2 NEMA S30	Damaged sulphur control valve diaphragm

ID	Event date	Event	Incident Root Cause Summary
118902	2022/04/14	Unit 2 NEMA S30	Damaged RH Side Draught Group ID fan electrical cable
119022	2022/04/28	Unit 1 NEMA S30	Sustained high hopper levels for 4 days due to standing and constant tripping of ash conveyor belts
119624	2022/06/25	Unit 4 NEMA S30	Leaking sulphur supply isolation valve and defective air combustion inlet valve gasket
120196	2022/08/10	Unit 4 NEMA S30	Damaged combustion air supply control valve
121808	2022/12/25	Unit 5 NEMA S30	Leaking steam on sulphur supply line and damage combustion chamber skin
122293	2023/02/06	Unit 5 PM Exceedances	Possible steam leak within the combustion chamber
122398	2023/02/15	Unit 6 PM Exceedances	Unavailability of ash overland conveyor system led to tripping-out
123442	2023/05/14	Unit 5 PM Exceedance	SO <sub>3</sub> plant return to service delay and poorly performing ESP casings
123443	2023/05/15	Unit 3 PM Exceedance	Spares available with GE not at EMS workshop resulting in long lead-time to access them for utilization
123773	2023/06/19	Unit 5 PM exceedance	SO <sub>3</sub> - plant return to service delay and poorly performing ESP casings
125963	2023/12/06	Unit 4 PM Exceedances	High hopper levels in all ESP casing fields initiating free ash flow inside

## 6. BASELINE CONDITIONS


The description of the baseline conditions of the area provide an understand on the receiving atmospheric environment so that changes as a result of the application for exemption of the MES can be assessed. The baseline description therefore includes an overview of the climatology and meteorology of the area, and an assessment of ambient air quality over the last three years measured at monitoring stations in the area. Other sources of air pollution in the area are also discussed.

### 6.1 Climate and meteorology

#### 6.1.1 Temperature and rainfall

The climate of a given location is affected by its latitude, terrain and altitude, as well as nearby water bodies and their currents. Climates are classified according to the average and typical ranges of different variables, most commonly temperature and precipitation.

Lethabo is located in the Vaal Triangle, in temperate latitudes between 26° S and 27° S and 27° E to 28° E, and approximately 1 465 m above sea level. The area experiences a temperate humid subtropical climate (Köppen CWA classification). It has very warm summers (from December to February) and mild winters (from June to August). Precipitation occurs mainly in summer. Temperature and rainfall over the Vaal Triangle are well illustrated by climate data at Vereeniging (Figure 6-1). The area receives an average of 719 mm of rainfall annually, with 85% of the rainfall occurring in the summer months between October and March (Figure 6-1). Rainfall occurs occasionally in winter.




**Figure 6-1: Average monthly maximum and minimum temperature, and average monthly rainfall at Vereeniging**  
[https://www.meteoblue.com/en/weather/historyclimate/climatemodelled/vereeniging\\_south-africa\\_944385](https://www.meteoblue.com/en/weather/historyclimate/climatemodelled/vereeniging_south-africa_944385)




## 6.1.2 Wind

A windrose illustrates the frequency of hourly wind from the 16 cardinal wind directions, with wind indicated from the direction it blows, i.e. easterly winds blow from the east. It also illustrates the frequency of average hourly wind speed in six wind speed classes.

The annual windrose at the Rand Water AQMS is presented in Figure 6-2 for the 3-year period, 2021 to 2023. The AQMS is located approximately 7 km northeast of Lethabo. The wind is mostly light with wind speeds generally less than 6 m/s (Figure 6-2). Stronger winds reaching 8 m/s or more do occur throughout the year (Figure 6-3). The wind is mostly from the sector northwest to northeast, and occasionally from southeast and southwest (Figure 6-3).



**Figure 6-2: Annual windrose at the Rand Water AQMS**



**Figure 6-3: Seasonal (top) and diurnal (bottom) windroses at the Rand Water AQMS**

### 6.1.3 Air Pollution Dispersion Potential

The air pollution dispersion of an area refers to the ability of atmospheric processes, or meteorological mechanisms, to disperse and remove pollutants from the atmosphere. Dispersion comprises both vertical and horizontal components of motion. The vertical component is defined by the stability of the atmosphere and the depth of the surface mixing layer. The horizontal dispersion of pollution in the boundary layer is primarily a function of the wind field and atmospheric stability. The wind speed determines the rate of downwind transport and wind direction and the variability in wind direction determines the general path of the pollutant. Atmospheric stability, or instability, determines the ability of the atmosphere to mix and dilute pollutants. Stability is a function of solar radiation (thermal turbulence) and wind speed and surface roughness, which induce mechanical turbulence. The dispersion potential of an area therefore experiences diurnal and seasonal changes.

By day, with strong insolation (in-coming solar radiation) and stronger winds, the dispersion potential is generally efficient through vertical dilution and horizontal dispersion. The dispersion potential is generally better on summer days than winter days. At night, as the surface temperature inversion develops, the lowest layer of the atmosphere becomes more stable, reaching a maximum at sunrise. As a result, the dispersion potential typically becomes less efficient during the night and the poorest conditions generally occur at sunrise. Thermal turbulence disappears when the sun sets, and mechanical turbulence decreases as the wind speeds drops at night. Pollutants tend to accumulate near the point of release under these conditions, particularly if these are released close to ground level. The dispersion potential is generally poorer on winter nights than summer nights.

In the Lethabo study area the dispersion potential is expected to be relatively good during the day in summer and winter as a result of daytime temperatures and a relatively high frequency of moderate winds. Summer rainfall is an important removal mechanism for air pollutants. Night-time surface temperature inversions are prevalent in winter and tend to trap pollutants that are released at or near ground level. Generally, there is better air pollution dispersion in summer when air pollutants disperse easily, compared with winter when pollutants can accumulate in stable night-time conditions.

## **6.2 Ambient Air Quality**

Agricultural and mining activities, as well as residential areas, are the key land use activities surrounding Lethabo Power Station. The Three Rivers residential area is located approximately 8 km north of Lethabo, whilst a smaller residential area is located approximately 3.2 km to the southwest. Local sources of air pollution therefore include agricultural activities, domestic fuel and waste burning, vehicle emissions, mining activities and power generation (Lethabo).

Two ambient air quality monitoring stations (AQMS) are located relatively close to Lethabo. These are the Eskom Rand Water AQMS (Rand Water AQMS), and the South African Weather Service (SAWS) Three Rivers AQMS (Three Rivers AQMS) located 7.2 km and 9.5 km north-northeast of Lethabo respectively. Ambient air quality at the AQMS will be influenced by local (nearby) sources, but ambient concentrations measured at these AQMS will also be influenced by emissions from Lethabo. Pollutant concentrations measured at the two AQMS for 2021 to 2023 are presented here and are referenced against the respective NAAQS which appear in Table 3-2.

### **6.2.1 Data recovery**

Data recovery for the Rand Water AQMS was above 90% for SO<sub>2</sub> (2021 to 2023), NO<sub>2</sub> (2021 to 2022) and PM<sub>10</sub> (in 2021) (Table 6-1). This is above the minimum data recovery requirement of 90% as stipulated by the SANAS TR 07-03 (SANAS, 2012). Data recovery for NO<sub>2</sub> (2023) and PM<sub>2.5</sub> (2022 and 2023) was between 76.4% and 88.5%. These are below the minimum requirement of 90% and although discussed in this section, must be viewed with caution. Notably, PM<sub>10</sub> is not measured by the Rand Water AQMS.

Data recovery for the Three Rivers AQMS was above 90% for SO<sub>2</sub> (2023) (Table 6-1), above the minimum requirement of 90% (SANAS, 2012). Data recovery for SO<sub>2</sub> (2021), NO<sub>2</sub> (2021 and 2023), PM<sub>10</sub> (2021 and 2023) and PM<sub>2.5</sub> (2021 and 2023) was between 60.9% and 88.0%, and below the minimum requirement of 90% and although discussed in this section, must be viewed with caution.

Data recovery for the Sharpeville AQMS was below 90% for all pollutants between 2021 and 2023, below the minimum requirement of 90% (SANAS, 2012). Data recovery for all pollutants in 2022 and 2023 was between 50% and 89.9%, which is below the minimum requirement of 90% and although discussed in this section, must be viewed with caution.

Pollutants with a data recovery below 50% in a single year were not considered in this baseline discussion and are highlighted in bold in Table 6-1.

**Table 6-1: Data recovery at the Rand Water, Three Rivers AQMS and Sharpeville AQMS from 2021 to 2023**

Year	Data recovery (%)			
	SO <sub>2</sub>	NO <sub>2</sub>	PM <sub>10</sub>	PM <sub>2.5</sub>
<b>Rand Water AQMS</b>				
<b>2021</b>	96.0	93.8	Not measured	92.7
<b>2022</b>	94.2	98.5	Not measured	76.4
<b>2023</b>	98.7	79.0	Not measured	88.5
<b>Three Rivers AQMS</b>				
<b>2021</b>	64.5	67.6	69.1	60.9
<b>2022</b>	<b>37.9</b>	<b>38.4</b>	<b>41.9</b>	<b>41.4</b>
<b>2023</b>	92.0	73.1	88.0	86.4
<b>Sharpeville AQMS</b>				
<b>2021</b>	<b>22.5</b>	<b>45.3</b>	<b>14.7</b>	<b>13.8</b>
<b>2022</b>	76.9	75.4	77.0	80.0
<b>2023</b>	60.0	58.7	74.7	76.1
<b>Note:</b>	Data recovery for Rand Water AQMS based on 10-minute average data, while Three Rivers AQMS is based on 1-hour average data.			

## 6.2.2 Sulphur Dioxide (SO<sub>2</sub>)

### Rand Water AQMS

- The 10-min average (Figure 6-4) SO<sub>2</sub> concentrations exceeded the 10-min (500 µg/m<sup>3</sup>) NAAQS in 2021 (33 times), 2022 (30 times) and 2023 (five times), however remaining compliant as 526 exceedances of the 10-min NAAQS are permitted per calendar year.
- The 1-hour average (Figure 6-5) SO<sub>2</sub> concentrations exceeded the 1-hour (350 µg/m<sup>3</sup>) NAAQS in 2021 (seven times), 2022 (twelve times) and 2023 (three times), however remaining compliant as 88 exceedances of the 1-hour NAAQS are permitted per calendar year.
- The 24-hour average (Figure 6-6) SO<sub>2</sub> concentrations exceeded the 24-hour (125 µg/m<sup>3</sup>) NAAQS in 2022 (one time), however remaining compliant as four exceedances of the 24-hour NAAQS are permitted per calendar year. The 24-hour average SO<sub>2</sub> concentrations remained below the 24-hour (125 µg/m<sup>3</sup>) NAAQS in 2021 and 2023, with no exceedances recorded, thus remaining compliant.
- The annual average SO<sub>2</sub> concentrations for 2021 (15.2 µg/m<sup>3</sup>), 2022 (13.5 µg/m<sup>3</sup>) and 2023 (13.7 µg/m<sup>3</sup>) remained below the annual average NAAQS (50 µg/m<sup>3</sup>), thus remaining compliant.

### Three Rivers AQMS

- The 1-hour average (Figure 6-5) SO<sub>2</sub> concentrations exceeded the 1-hour (350 µg/m<sup>3</sup>) NAAQS in 2021 (five times) and 2023 (three times), however remaining compliant as 88 exceedances of the 1-hour NAAQS are permitted per calendar year.

- The 24-hour average (Figure 6-6) SO<sub>2</sub> concentrations remained below the 24-hour (125 µg/m<sup>3</sup>) NAAQS for 2021 and 2023, with no exceedances recorded, thus remaining compliant.
- The annual average SO<sub>2</sub> concentrations for 2021 (17.8 µg/m<sup>3</sup>) and 2023 (13.3 µg/m<sup>3</sup>) remained below the annual average NAAQS (50 µg/m<sup>3</sup>), thus compliant with the respective NAAQS.

#### **Sharpeville AQMS**

- While the Sharpeville AQMS has SO<sub>2</sub> concentrations in 10-min averages, this data was not available from the SAAQIS, thus is it not presented.
- The 1-hour average (Figure 6-5) SO<sub>2</sub> concentrations exceeded the 1-hour (350 µg/m<sup>3</sup>) NAAQS in 2022 (one time) and 2023 (four times), thus compliant with the respective NAAQS as 88 exceedances of the 1-hour NAAQS are permitted per calendar year.
- The 24-hour average (Figure 6-6) SO<sub>2</sub> concentrations remained below the 24-hour (125 µg/m<sup>3</sup>) NAAQS for 2022 and 2023, with no exceedances recorded, thus compliant with the respective NAAQS.
- The annual average SO<sub>2</sub> concentrations for 2022 (19.8 µg/m<sup>3</sup>) and 2023 (17.5 µg/m<sup>3</sup>) remained below the annual average NAAQS (50 µg/m<sup>3</sup>), thus compliant with the respective NAAQS.

### **6.2.3 Nitrogen Dioxide (NO<sub>2</sub>)**

#### **Rand Water AQMS**


- The 1-hour average (Figure 6-7) NO<sub>2</sub> concentrations remained below the 1-hour NAAQS (200 µg/m<sup>3</sup>) between 2021 and 2023, with no exceedances recorded, thus compliant with the respective NAAQS.
- The annual average NO<sub>2</sub> concentrations for 2021 (12.2 µg/m<sup>3</sup>), 2022 (11.8 µg/m<sup>3</sup>) and 2023 (12.6 µg/m<sup>3</sup>) remained below the annual average NAAQS (40 µg/m<sup>3</sup>), thus compliant with the respective NAAQS.

#### **Three Rivers AQMS**


- The 1-hour average (Figure 6-7) NO<sub>2</sub> concentrations remained below the 1-hour NAAQS (200 µg/m<sup>3</sup>) between for 2021 and 2023, with no exceedances recorded, thus compliant with the respective NAAQS.
- The annual average NO<sub>2</sub> concentrations for 2021 [2021](#) (20.2 µg/m<sup>3</sup>) and 2023 (19.4 µg/m<sup>3</sup>) remained below the annual average NAAQS (40 µg/m<sup>3</sup>), thus compliant with the respective NAAQS.

#### **Sharpeville AQMS**

- The 1-hour average (Figure 6-7) NO<sub>2</sub> concentrations remained below the 1-hour NAAQS (200 µg/m<sup>3</sup>) in 2022 and 2023, with no exceedances recorded, thus compliant with the respective NAAQS.
- The annual average NO<sub>2</sub> concentrations for 2022 (27.0 µg/m<sup>3</sup>) and 2023 (29.0 µg/m<sup>3</sup>) remained below the annual average NAAQS (40 µg/m<sup>3</sup>), thus compliant with the respective NAAQS.




**Figure 6-4: 10-minute average SO<sub>2</sub> concentrations at Rand Water AQMS from 2021 to 2023**




**Figure 6-5: 1-hour average SO<sub>2</sub> concentrations at Rand Water, Three Rivers and Sharpeville AQMS from 2021 to 2023**





**Figure 6-6: 24-hour average SO<sub>2</sub> concentrations at Rand Water, Three Rivers and Sharpeville AQMS from 2021 to 2023**



**Figure 6-7: 1-hour average NO<sub>2</sub> concentrations at Rand Water, Three Rivers and Sharpeville AQMS from 2021 to 2023**

## 6.2.4 Particulates (PM<sub>10</sub> and PM<sub>2.5</sub>)

### Rand Water AQMS


- The 24-hour average (Figure 6-9) PM<sub>2.5</sub> concentrations exceeded the 24-hour average NAAQS (40 µg/m<sup>3</sup>) in 2021 (five times) and 2023 (nine times), thus are non-compliant as four exceedances per year are permitted. The 24-hour average PM<sub>2.5</sub> concentrations exceeded the 24-hour average NAAQS (40 µg/m<sup>3</sup>) in 2022 (four times); however, remaining compliant, as four exceedances per year are permitted.
- The annual average PM<sub>2.5</sub> concentrations for 2021 (18.0 µg/m<sup>3</sup>), 2022 (18.5 µg/m<sup>3</sup>) and 2023 (19.1 µg/m<sup>3</sup>) remained below the annual average NAAQS (20 µg/m<sup>3</sup>), thus remaining compliant.

### Three Rivers AQMS


- The 24-hour average (Figure 6-9) PM<sub>10</sub> concentrations exceeded the 24-hour average NAAQS (75 µg/m<sup>3</sup>) in 2021 (98 times) and 2023 (75 times), thus are non-compliant as four exceedances per year are permitted.
- The annual average PM<sub>10</sub> concentrations for 2022 (65.6 µg/m<sup>3</sup>) and 2023 (55.1 µg/m<sup>3</sup>) exceeded the annual average NAAQS (40 µg/m<sup>3</sup>), thus are non-compliant.
- The 24-hour average (Figure 6-8) PM<sub>2.5</sub> concentrations exceeded the 24-hour average NAAQS (40 µg/m<sup>3</sup>) in 2021 (45 times) and 2023 (113 times), thus are non-compliant as four exceedances per year are permitted.
- The annual average PM<sub>2.5</sub> concentrations for 2022 (28.1 µg/m<sup>3</sup>) and 2023 (34.9 µg/m<sup>3</sup>) exceeded the annual average NAAQS (20 µg/m<sup>3</sup>), thus are non-compliant.

### Sharpeville AQMS

- The 24-hour average (Figure 6-9) PM<sub>10</sub> concentrations exceeded the 24-hour average NAAQS (75 µg/m<sup>3</sup>) in 2022 (86 times) and 2023 (107 times), thus are non-compliant as four exceedances per year are permitted.
- The annual average PM<sub>10</sub> concentrations for 2022 (53.4 µg/m<sup>3</sup>) and 2023 (64.0 µg/m<sup>3</sup>) exceeded the annual average NAAQS (40 µg/m<sup>3</sup>), thus are non-compliant.
- The 24-hour average (Figure 6-8) PM<sub>2.5</sub> concentrations exceeded the 24-hour average NAAQS (40 µg/m<sup>3</sup>) in 2022 (67 times) and 2023 (97 times), thus are non-compliant as four exceedances per year are permitted.
- The annual average PM<sub>2.5</sub> concentrations for 2022 (22.1 µg/m<sup>3</sup>) and 2023 (33.6 µg/m<sup>3</sup>) exceeded the annual average NAAQS (20 µg/m<sup>3</sup>), thus are non-compliant.



**Figure 6-8: 24-hour average  $\text{PM}_{10}$  concentrations at Three Rivers and Sharpeville AQMS for 2021 to 2023**



**Figure 6-9: 24-hour average  $\text{PM}_{2.5}$  concentrations at Rand Water, Three Rivers and Sharpeville AQMS for 2021 to 2023**

## 6.2.5 Ambient pollutant summary

A summary of exceedances of the limit value of the NAAQS for all pollutants is presented in (Table 6-2). Despite the proximity of a number of sources of SO<sub>2</sub> and NO<sub>2</sub> to the three monitoring sites, including Lethabo, no exceedances of the NAAQS for SO<sub>2</sub> and NO<sub>2</sub> were recorded during the period 2021 to 2023.

The key pollutants of concern however, are PM<sub>10</sub> and PM<sub>2.5</sub>. During the period 2021 to 2023 numerous exceedances of the NAAQS limit value for both the 24-hour and annual average for PM<sub>10</sub> and PM<sub>2.5</sub> were recorded at both monitoring sites. The exceedances are attributed to the proximity of sources of particulates to these monitoring sites.

**Table 6-2: Pollutant exceedance summary at the Rand Water and Three Rivers AQMS from 2021 to 2023**

Pollutant	Averaging Period	Limit value µg/m <sup>3</sup>	Permitted Number of Exceedances	2021	2022	2023
<b>Rand Water AQMS</b>						
<b>SO<sub>2</sub></b>	10-min	500	526	0	0	0
	1-hour	350	88	0	0	0
	24-hour	125	4	0	0	0
	1-year	50	0	0	0	0
<b>NO<sub>2</sub></b>	1-hour	200	88	0	0	0
	1-year	40	0	0	0	0
<b>PM<sub>2.5</sub></b>	24-hour	40	4	5	4	9
	1-year	20	0	1	0	1
<b>Three Rivers AQMS</b>						
<b>SO<sub>2</sub></b>	10-min	500	526	- (1)	- (1)	- (1)
	1-hour	350	88	0	- (2)	1
	24-hour	125	4	0	- (2)	0
	1-year	50	0	0	- (2)	0
<b>NO<sub>2</sub></b>	1-hour	200	88	0	- (2)	0
	1-year	40	0	0	- (2)	0
<b>PM<sub>10</sub></b>	24-hour	75	4	98	- (2)	75
	1-year	40	0	1	- (2)	1
<b>PM<sub>2.5</sub></b>	24-hour	40	4	45	- (2)	113
	1-year	20	0	1	- (2)	1
<b>Sharpeville AQMS</b>						
<b>SO<sub>2</sub></b>	10-min	500	526	- (1)	- (1)	- (1)
	1-hour	350	88	- (2)	1	4
	24-hour	125	4	- (2)	0	0
	1-year	50	0	- (2)	0	0
<b>NO<sub>2</sub></b>	1-hour	200	88	- (2)	0	0
	1-year	40	0	- (2)	0	0
<b>PM<sub>10</sub></b>	24-hour	75	4	- (2)	86	107
	1-year	40	0	- (2)	1	1
<b>PM<sub>2.5</sub></b>	24-hour	40	4	- (2)	67	97
	1-year	20	0	- (2)	1	1
<b>Notes:</b>	(1): The Three Rivers AQMS does not measure data in 10-minute intervals. (2): Data recovery below 50%; thus, exceedances are not presented. Values in red indicate non-compliance against the respective standard.					

## **7. IMPACT OF ENTERPRISE ON THE RECEIVING ENVIRONMENT**

### **7.1 Dispersion Modelling**

#### **7.1.1 Models used**

A Level 3 air quality assessment must be conducted in situations where the purpose of the assessment requires a detailed understanding of the air quality impacts (time and space variation of the concentrations) and when it is important to account for causality effects, calms, non-linear plume trajectories, spatial variations in turbulent mixing, multiple source types and chemical transformations (DEA, 2014a). A Level 3 assessment may be used in situations where there is a need to evaluate air quality consequences under a permitting or environmental assessment process for large industrial developments that have considerable social, economic and potential environmental consequences. Under these circumstances, the assessment for Lethabo clearly demonstrates the need for a Level 3 assessment.

The CALPUFF suite of models are approved by the USEPA (<http://www.src.com/calpuff/calpuff1.htm>) and by the DEA for Level 3 assessments (DEA, 2014a). It consists of a meteorological pre-processor, CALMET, the dispersion model, CALPUFF, and the post-processor, CALPOST. It is an appropriate air dispersion model for the purpose of this assessment as it is well suited to simulate dispersion from several sources. It also has capability to simulate dispersion in the atmosphere's complex land-sea interface. More information about the model can be found in the User's Guide for the CALPUFF Dispersion Model (USEPA, 1995).

The Air Pollution Model (TAPM) (Hurley, 2000; Hurley et al., 2001; Hurley et al., 2002) is used to model surface and upper air meteorological data for the study domain. TAPM uses global gridded synoptic-scale meteorological data with observed surface data to simulate surface and upper air meteorology at given locations in the domain, taking the underlying topography and land cover into account. The global gridded data sets that are used are developed from surface and upper air data that are submitted routinely by all meteorological observing stations to the Global Telecommunication System of the World Meteorological Organisation. TAPM has been used successfully in Australia where it was developed (Hurley, 2000; Hurley et al., 2001; Hurley et al., 2002). It is an ideal tool for modelling applications where meteorological data does not adequately meet requirements for dispersion modelling. TAPM modelled output data is therefore used to augment the site-specific surface meteorological data for input to CALPUFF.

#### **7.1.2 TAPM and CALPUFF parameterisation**

The TAPM diagnostic meteorological model is used to generate a 3-dimensional temporally and spatially continuous meteorological field for 2021, 2022 and 2023 in hourly increments for the modelling domain.

TAPM is set-up in a nested configuration of three domains, centred on Lethabo. The outer domain is 600 km by 600 km at a 24 km grid resolution, the middle domain is 300 km by 300 km at a 12 km grid resolution and the inner domain is 75 km by 75 km at a 3 km grid resolution (Figure 7-1). The nesting configuration ensures that topographical effects on meteorology are captured and that meteorology is well resolved and characterised across the boundaries of the inner domain. Twenty-seven vertical levels are modelled in each nest from 10 m to 5 000 m, with a finer resolution in the lowest 1 000 m. The subset of the entire TAPM model output in the form of pre-processed gridded surface meteorological data fields is input into the dispersion model.

The 3-dimensional TAPM meteorological output on the inner grid includes hourly wind speed and direction, temperature, relative humidity, total solar radiation, net radiation, sensible heat flux, evaporative heat flux, convective velocity scale, precipitation, mixing height, friction velocity and Obukhov length. The spatially and temporally resolved TAPM surface and upper air meteorological data is used as input to the CALPUFF meteorological pre-processor, CALMET.


The CALPUFF modelling domain covers an area of 4 356 km<sup>2</sup>, where the domain extends 66 km (west-east) by 66 km (north-south) (Figure 7-1). It consists of a uniformly spaced receptor grid with 0.5 km spacing, giving 17 424 grid cells (132 x 132 grid cells).

The topographical and land use for the respective modelling domains is obtained from the dataset accompanying the Commonwealth Scientific and Industrial Research Organisation (CSIRO) The Air Pollution Model (TAPM) modelling package (CSIRO, 2008). This dataset includes global terrain elevation and land use classification data on a longitude/latitude grid at 30-second grid spacing from the US Geological Survey, Earth Resources Observation Systems (EROS) Data Center.

The CALPUFF modelling suite provides for the chemical conversion of SO<sub>2</sub> and NO<sub>x</sub> stack emissions to secondary particulates. The predicted PM<sub>10</sub> and PM<sub>2.5</sub> concentrations in this AIR include direct emissions of PM plus secondary particulates formed from Eskom's emissions.

The parameterisation of key variables that will apply in CALMET and CALPUFF are indicated in Table 7-1 and Table 7-2 respectively.





**Figure 7-1: TAPM and CALPUFF modelling domains for Lethabo**

**Table 7-1: Parameterisation of key variables for CALMET**

Parameter	Model value
12 vertical cell face heights (m)	0, 20, 40, 80, 160, 320, 640, 1000, 1500, 2000, 2500, 3000, 4000
Coriolis parameter (per second)	0.0001
Empirical constants for mixing height equation	Neutral, mechanical: 1.41 Convective: 0.15 Stable: 2400 Overwater, mechanical: 0.12
Minimum potential temperature lapse rate (K/m)	0.001
Depth of layer above convective mixing height through which lapse rate is computed (m)	200
Wind field model	Diagnostic wind module
Surface wind extrapolation	Similarity theory
Restrictions on extrapolation of surface data	No extrapolation as modelled upper air data field is applied
Radius of influence of terrain features (km)	5
Radius of influence of surface stations (km)	Not used as continuous surface data field is applied

**Table 7-2: Parameterisation of key variables for CALPUFF**

Parameter	Model value
Chemical transformation	Default NO <sub>2</sub> conversion factor is applied
Wind speed profile	Rural
Calm conditions	Wind speed < 0.5 m/s
Plume rise	Transitional plume rise, stack tip downwash, and partial plume penetration is modelled
Dispersion	CALPUFF used in PUFF mode
Dispersion option	Pasquill-Gifford coefficients are used for rural and McElroy-Pooler coefficients are used for urban
Terrain adjustment method	Partial plume path adjustment

### 7.1.3 Model accuracy

Air quality models attempt to predict ambient concentrations based on “known” or measured parameters, such as wind speed, temperature profiles, solar radiation and emissions. There are however, variations in the parameters that are not measured, the so-called “unknown” parameters as well as unresolved details of atmospheric turbulent flow. Variations in these “unknown” parameters can result in deviations of the predicted concentrations of the same event, even though the “known” parameters are fixed.

There are also “reducible” uncertainties that result from inaccuracies in the model, errors in input values and errors in the measured concentrations. These might include poor quality or unrepresentative meteorological, geophysical and source emission data, errors in the measured concentrations that are used to compare with model predictions and inadequate model physics and formulation used to predict the concentrations. “Reducible” uncertainties can be controlled or minimised. This is done by using accurate input data, preparing the input files correctly, checking and re-checking for errors, correcting for odd model behaviour, ensuring that the errors in the measured data are minimised and applying appropriate model physics.

Models recommended in the DEA dispersion modelling guideline (DEA, 2014a) have been evaluated using a range of modelling test kits (<http://www.epa.gov./scram001>). CALPUFF is one of the models that have been evaluated and it is therefore not mandatory to perform any modelling evaluations. Rather the accuracy of the modelling in this assessment is enhanced by every effort to minimise the “reducible” uncertainties in input data and model parameterisation.

#### **7.1.4 Assessment scenarios**

For this AIR five emission scenarios are assessed, namely:

Scenario 1 (Current): The baseline scenario using actual monthly tonnage of pollutants emitted per stack for 2021-2023 and fugitive emissions from the ash dump.

Scenario A (2025): Eskom’s planned 2025 stack emissions and fugitive emissions from the ash dump

Scenario B (2031): Eskom’s planned 2031 stack emissions and fugitive emissions from the ash dump

Scenario C (2036): Eskom’s planned 2036 stack emissions and fugitive emissions from the ash dump

Scenario D (MES): Emissions that are in full compliance with MES and fugitive emissions from the ash dump

### **7.2 Dispersion Modelling Results**

The dispersion modelling results are compared with the NAAQS for SO<sub>2</sub>, NO<sub>2</sub>, PM<sub>10</sub> and PM<sub>2.5</sub> (Table 3-2). It is not possible to apportion the PM<sub>10</sub> and PM<sub>2.5</sub> portion of the total PM emitted from the Lethabo stacks, so the PM emission is conservatively modelled as PM<sub>10</sub> and PM<sub>2.5</sub>, providing a worst environmental case. The CALPUFF modelling suite provides for the chemical conversion of SO<sub>2</sub> and NO<sub>x</sub> to secondary particulates, i.e. sulphate and nitrate in the modelling results. The predicted PM<sub>10</sub> and PM<sub>2.5</sub> concentrations presented here include direct emissions of PM plus secondary particulates formed from Lethabo’s emissions.

The 99<sup>th</sup> percentile predicted ambient SO<sub>2</sub>, NO<sub>2</sub>, PM<sub>10</sub> and PM<sub>2.5</sub> concentrations from the dispersion modelling for Lethabo for the five scenarios are presented as isopleth maps over the modelling domain. The DEA (2012c) recommend the 99<sup>th</sup> percentile concentrations for

short-term assessment with the NAAQS since the highest predicted ground-level concentrations can be considered outliers due to complex variability of meteorological processes. In addition, the limit value in the NAAQS is the 99<sup>th</sup> percentile.

### **7.2.1 Maximum predicted ambient concentrations**

The maximum predicted annual SO<sub>2</sub>, NO<sub>2</sub>, PM<sub>10</sub> and PM<sub>2.5</sub> concentrations and the 99<sup>th</sup> percentile of the 24-hour and 1-hour predicted concentrations are discussed here and are listed in Table 7-3 for the 5 scenarios. Exceedances of the limit value of the NAAQS are shown in red font.

For SO<sub>2</sub>, the predicted concentrations are attributed only to the stack emissions. The maximum predicted concentrations for the 5 scenarios are low relative to the limit values of the respective NAAQS. The highest of these predictions occurs for Scenario A (2025), and then systematically decrease with progressive years and the corresponding stack emission reductions.

For NO<sub>2</sub>, the predicted concentrations are attributed only to the stack emissions. The maximum predicted concentrations for the 5 scenarios are low relative to the limit values of the respective NAAQS. The highest of these predictions occurs for Scenario A (2025), and then systematically decrease in progressive years with the corresponding stack emission reductions. Scenario A represents anticipated operations from 2025 to 2030.

For PM<sub>10</sub> and PM<sub>2.5</sub>, the predicted concentrations are attributed to stack emissions, and the low-level fugitive sources (ash dump). The stack and fugitive PM emissions are not speciated into PM<sub>10</sub> and PM<sub>2.5</sub>, rather all PM emitted is assumed to be PM<sub>10</sub>, and all PM emitted is assumed to be PM<sub>2.5</sub>. In other words, PM = PM<sub>10</sub> = PM<sub>2.5</sub>. This is a worst-case environmental assumption that overestimates the ambient PM<sub>10</sub> and PM<sub>2.5</sub> concentrations.

Close to the power station the low-level fugitive sources have the greatest influence on predicted PM<sub>10</sub> and PM<sub>2.5</sub> ambient concentrations, while the stack emissions have an influence further from the power station. Included in the predicted concentrations is the formation of secondary particulates from SO<sub>2</sub> and NO<sub>2</sub> stack emissions.

For PM<sub>10</sub> and PM<sub>2.5</sub>, the maximum predicted concentrations are high relative to the limit values of the respective NAAQS. The predicted concentrations are similar for all of the scenarios as these occur close to the power station and are dominated by the fugitive sources which are the same for all scenarios (see Table 5-5).

**Table 7-3: Maximum predicted ambient annual SO<sub>2</sub>, NO<sub>2</sub>, PM<sub>10</sub> and PM<sub>2.5</sub> concentrations in µg/m<sup>3</sup> and the predicted 99<sup>th</sup> percentile concentrations for 24-hour and 1-hour averaging periods, with the South African NAAQS**

<b>Pollutant</b>			
<b>Predicted maximum SO<sub>2</sub></b>	<b>Annual</b>	<b>24-hour</b>	<b>1-hour</b>
Scenario 1 (Current)	5.2	99.3	155.0
Scenario A (2025)	6.0	113.4	175.3
Scenario B (2031)	5.0	79.5	143.3
Scenario C (2036)	4.8	76.6	140.1
Scenario D (MES)	1.4	23.0	42.0
<b>NAAQS</b>	<b>50</b>	<b>125</b>	<b>350</b>
<b>Predicted maximum NO<sub>2</sub></b>	<b>Annual</b>		<b>1-hour</b>
Scenario 1 (Current)	2.0		61.5
Scenario A (2025)	2.1		64.3
Scenario B (2031)	1.9		56.2
Scenario C (2036)	1.3		40.1
Scenario D (MES)	1.3		40.1
<b>NAAQS</b>	<b>40</b>		<b>200</b>
<b>Predicted maximum PM<sub>10</sub></b>	<b>Annual</b>	<b>24-hour</b>	
Scenario 1 (Current)	<b>174.6</b>	<b>513.3</b>	
Scenario A (2025)	<b>174.6</b>	<b>513.2</b>	
Scenario B (2031)	<b>174.5</b>	<b>511.9</b>	
Scenario C (2036)	<b>174.5</b>	<b>511.9</b>	
Scenario D (MES)	<b>174.4</b>	<b>510.5</b>	
<b>NAAQS</b>	<b>40</b>	<b>75</b>	
<b>Predicted maximum PM<sub>2.5</sub></b>	<b>Annual</b>	<b>24-hour</b>	
Scenario 1 (Current)	<b>174.6</b>	<b>513.3</b>	
Scenario A (2025)	<b>174.6</b>	<b>513.2</b>	
Scenario B (2031)	<b>174.5</b>	<b>511.9</b>	
Scenario C (2036)	<b>174.5</b>	<b>511.9</b>	
Scenario D (MES)	<b>174.4</b>	<b>510.5</b>	
<b>NAAQS</b>	<b>20</b>	<b>40</b>	Up to 31 Dec 2029
	<b>15</b>	<b>25</b>	From 01 Jan 2030

## 7.2.2 Predicted concentrations at AQMS and sensitive receptors

The predicted annual SO<sub>2</sub>, NO<sub>2</sub>, PM<sub>10</sub> and PM<sub>2.5</sub> concentrations and the 99<sup>th</sup> percentile of the 24-hour and 1-hour predicted concentrations at AQMS and the sensitive receptor points in the modelling area are presented in Table 7-4 to

Table 7-9. Exceedances of the limit value of the NAAQS are shown in red font. The number of exceedances (NoE) are also presented next to the averaging period if applicable, with exceedances of the tolerance value in red font.

A comparison of the annual averages is shown in Table 7-4 at the Rand Water and Three Rivers AQMS. For all pollutants the predicted ambient concentrations are lower than the monitored concentrations. This is to be expected since the emissions in the model are limited to the power station sources only, while the AQMS are exposed to all sources. The predicted concentrations provide an indication of the contribution of the power station sources at these points.

**Table 7-4: Measured annual average concentration the Rand Water and Three Rivers AQMS compared with predicted concentrations in  $\mu\text{g}/\text{m}^3$**

AQMS	Pollutant	2021	2022	2023	Predicted
Rand Water	SO <sub>2</sub>	15.2	13.5	13.7	2.3
Three Rivers		17.8	-	13.3	2.3
Rand Water	NO <sub>2</sub>	12.2	11.8	12.6	0.8
Three Rivers		20.2	-	19.4	0.7
Rand Water	PM <sub>10</sub>	-	-	-	-
Three Rivers		65.6	-	55.1	2.1
Rand Water	PM <sub>2.5</sub>	18.0	18.5	19.1	6.9
Three Rivers		28.1	-	34.9	2.1

At all of the sensitive receptors, the predicted ambient SO<sub>2</sub> and NO<sub>2</sub> concentrations are well below the limit values of the respective NAAQS. As discussed for the predicted maximum concentrations, the highest predicted concentrations occur in Scenario A (2025) at all receptor points, and then systematically decrease in progressive years with the corresponding stack emission reductions. The reductions are a result of load curtailment to address SO<sub>2</sub> emissions. Load reductions also reduce NO<sub>x</sub> emissions, which will also reduce with the installation of low-NO<sub>x</sub> burners.

For PM<sub>10</sub> and PM<sub>2.5</sub>, it must be remembered that the predicted concentrations are attributed to stack emissions and low-level fugitive sources (ash dump). Furthermore, the particulate emissions are not speciated into PM<sub>10</sub> and PM<sub>2.5</sub>, but rather all PM emitted is assumed to be PM<sub>10</sub>, and all PM emitted is assumed to be PM<sub>2.5</sub>. In addition, the predicted PM<sub>10</sub> and PM<sub>2.5</sub> concentrations account for the formation of secondary particulates from SO<sub>2</sub> and NO<sub>2</sub> stack emissions. This is a very conservative approach.

For PM<sub>10</sub>, the predicted annual average and 24-hour ambient concentrations are below the limit values of the NAAQS at all of the sensitive receptor points in all five scenarios. The predicted 24-concentration however exceeds the NAAQS limit value at the Rand Water AQMS in all five scenarios. Little change in the predicted concentration across the scenarios indicates the influence of the fugitive sources at this point.

For PM<sub>2.5</sub>, the predicted annual average ambient concentrations are below the limit values of the NAAQS at all of the sensitive receptor points. The predicted 24-hour concentration is generally below the limit value of the NAAQS. The NAAQS provides for 4 exceedances of the limit value per year. In the 3-year modelling period 12 exceedances will therefore be permitted. Exceedances of the limit value of 40  $\mu\text{g}/\text{m}^3$  are predicted at 6 sensitive receptors



in Scenario 1 (Current) and in Scenario A (2025). From 01 January 2030 the stricter limit value of 25  $\mu\text{g}/\text{m}^3$  is exceeded at 24 of the sensitive receptor points in Scenario B (2031), Scenario C (2036) and Scenario D (MES). Of these, the number of exceedances is more than 12 at 1 sensitive receptor point in Scenario A (Current) and at 9 sensitive receptor points in subsequent scenarios. These are therefore predicted to exceed the NAAQS.

The area where the NAAQS for  $\text{PM}_{2.5}$  is exceeded is discussed later (Section 7.2.3.4) and illustrated in the accompanying isopleth plot (Figure 7-38). The sensitive receptor points where the NAAQS is exceeded are within 10 km of Lethabo. Being relatively close to Lethabo it is likely that these exceedances are contributed to mostly by the low-level fugitive sources, rather than high-level stack emissions. The fugitive sources are released near ground-level and are not buoyant so dispersion is relatively poor. The stack emissions are released more than 200 m above ground level with considerable buoyancy so disperse well. Typically the highest ground level concentrations resulting from the stack emissions will occur well downwind from the power station.

**Table 7-5: Predicted concentrations in  $\mu\text{g}/\text{m}^3$  and number of exceedance (NoE) at the sensitive receptors for Scenario 1 (Current) (NAAQS limit values in brackets)**

Receptor	SO <sub>2</sub>			NO <sub>2</sub>		PM <sub>10</sub> Total			PM <sub>2.5</sub> Total		
	1-hr (350)	24-hr (125)	Annual (50)	1-hour (200)	Annual (40)	24-hr (75)	NoE	Annual (40)	24-hr (40)	NoE	Annual (20)
Sharpeville - Monitoring Station	29.7	24.2	1.2	7.1	0.4	35.3		3.1	35.3		3.1
Sebokeng - Monitoring Station	22.5	18.5	0.9	4.9	0.2	8.2		0.6	8.2		0.6
Three Rivers - Monitoring Station	58.7	51.2	2.3	17.9	0.7	31.4		2.1	31.4		2.1
Zamdela - Monitoring Station	40.6	32.9	1.6	13.1	0.5	34.1		2.7	34.1		2.7
Rand Water - Monitoring Station	59.6	50.7	2.3	18.3	0.8	112.8	11	6.9	112.8	45	6.9
Vaal Power AH	101.0	47.2	3.3	38.6	1.2	61.6		7.3	61.6	22	7.3
Sasolburg Provincial Hospital	42.6	34.0	1.6	12.7	0.5	23.2		2.0	23.2		2.0
Moredou Old Age Home	38.3	31.6	1.4	11.0	0.4	22.8		1.9	22.8		1.9
Ons Gryse Jeug Old Age Home	41.4	33.5	1.5	11.7	0.5	25.9		2.1	25.9		2.1
Noord Primêre Skool	42.1	34.0	1.6	12.0	0.5	26.3		2.3	26.3		2.3
Sasolburg High School	41.5	31.1	1.4	11.3	0.5	21.0		1.8	21.0		1.8
Sakhubusa Secondary School	48.0	29.8	1.7	15.3	0.6	31.3		2.9	31.3		2.9
Bekezela Primary School	59.0	32.8	1.9	20.5	0.6	36.0		3.4	36.0		3.4
Isaac Mhlambi Primary	40.8	35.3	1.6	13.1	0.5	36.8		3.0	36.8		3.0
Refenkgotso Primary School	107.0	34.9	4.0	41.4	1.4	23.1		2.3	23.1		2.3
Deneysville Primary school	104.5	32.6	3.9	38.9	1.4	15.9		1.8	15.9		1.8
Netcare Vaalpark Hospital	39.3	34.4	1.5	11.1	0.5	32.4		3.0	32.4		3.0
Vaalpark Articon Secondary School	38.3	40.4	1.6	10.6	0.5	38.2		3.6	38.2		3.6
Mediclinic Emfuleni	29.1	26.9	1.2	6.9	0.4	23.2		2.1	23.2		2.1
Jeugland Old Age Home	27.2	29.3	1.2	6.7	0.4	28.7		2.2	28.7		2.2
Herfsoord Huis Old Age Home	26.7	25.7	1.2	7.3	0.4	19.4		1.8	19.4		1.8
Huis Prinscilla	26.1	21.3	1.0	6.4	0.3	24.2		1.8	24.2		1.8
Laerskool Emfulenipark	32.1	36.7	1.4	7.6	0.4	39.2		3.6	39.2		3.6
NW University - Vaal Campus	30.9	29.3	1.4	7.4	0.5	56.5		5.3	56.5	12	5.3
Emfuleni Primary School	25.1	21.9	1.0	6.6	0.3	14.9		1.3	14.9		1.3
Mediclinic Vereeniging	30.3	24.7	1.2	6.9	0.4	35.6		2.9	35.6		2.9
Kopanong Provincial Hospital	36.6	28.8	1.4	8.6	0.4	18.0		1.3	18.0		1.3
Avondrus Eventide Old Age Home	38.2	30.3	1.5	8.7	0.4	21.0		1.4	21.0		1.4
Riviera On Vaal Resort	34.2	28.2	1.3	7.5	0.4	43.3		3.7	43.3	1	3.7
Sedibeng TVET college	31.1	26.5	1.2	6.4	0.4	47.1		4.3	47.1	1	4.3

Receptor	SO <sub>2</sub>			NO <sub>2</sub>		PM <sub>10</sub> Total			PM <sub>2.5</sub> Total		
	1-hr (350)	24-hr (125)	Annual (50)	1-hour (200)	Annual (40)	24-hr (75)	NoE	Annual (40)	24-hr (40)	NoE	Annual (20)
General Smuts High School	27.5	26.3	1.2	6.3	0.3	39.1		3.2	39.1		3.2
Eureuka School & Selbourne Primary	27.8	28.1	1.2	6.4	0.3	34.8		2.9	34.8		2.9
Midvaal Private Hospital	47.7	37.4	1.7	11.7	0.5	44.1		3.0	44.1	1	3.0
Three Rivers Retirement Village	46.5	36.1	1.7	12.6	0.5	32.1		2.1	32.1		2.1
Drie Riviere Aftreeoord Old Age Home	44.7	34.1	1.7	12.5	0.5	27.9		1.8	27.9		1.8
Riverside High School	58.0	50.6	2.3	17.5	0.7	35.2		2.3	35.2		2.3
Risiville Primary School	51.0	42.2	1.9	13.8	0.6	27.0		1.8	27.0		1.8
Sebokeng Hospital	24.4	21.0	1.0	5.2	0.3	10.4		0.7	10.4		0.7
Clinix Naledzi Private Hospital	26.1	23.0	1.0	5.5	0.3	10.4		0.8	10.4		0.8
Mohloli Secondary School	30.1	26.4	1.2	7.2	0.4	42.1		3.5	42.1	1	3.5
Tshirela Primary School (Boipatong)	26.5	24.4	1.1	6.1	0.3	23.8		1.8	23.8		1.8
Tsoaranang Primary School	28.4	29.8	1.2	6.4	0.4	32.3		2.4	32.3		2.4
Thepiso Primary School	26.6	28.6	1.2	6.1	0.3	21.0		1.6	21.0		1.6
Emmanuel Primary School	28.7	29.4	1.3	6.5	0.4	36.0		2.8	36.0		2.8
Rust Ter Vaal Combined School	33.1	27.0	1.2	7.8	0.3	11.0		0.7	11.0		0.7
Roshnee Primary School	29.8	24.5	1.1	7.4	0.3	9.6		0.6	9.6		0.6
Roshnee High School	31.3	26.0	1.1	7.5	0.3	10.4		0.6	10.4		0.6
Hoerskool DR Malan	48.1	31.4	1.5	11.9	0.4	10.7		0.7	10.7		0.7
Laerskool Voorwaarts	54.8	33.9	1.8	14.7	0.5	13.8		0.9	13.8		0.9
Meyerton Secondary School	50.6	33.0	1.5	12.5	0.4	12.3		0.8	12.3		0.8
Ratasetjhaba Primary School	37.1	23.6	1.2	8.7	0.3	8.4		0.6	8.4		0.6
Meyerton Primary School	45.4	29.1	1.5	11.3	0.4	10.2		0.6	10.2		0.6
Oprah Leadership Academy	47.3	29.0	1.5	11.8	0.4	9.1		0.6	9.1		0.6
Henley River Retirement Village	46.6	29.1	1.5	11.2	0.4	9.6		0.6	9.6		0.6
Henley High & Preparatory School	44.1	25.9	1.4	11.1	0.4	8.1		0.5	8.1		0.5
Randvaal Clinic	42.3	26.6	1.3	9.6	0.4	7.8		0.5	7.8		0.5
Laerskool Japie Greyling	37.1	23.7	1.2	8.9	0.3	6.5		0.4	6.5		0.4
Thomas Nhlapo Primary	39.9	25.4	1.3	9.8	0.4	7.4		0.4	7.4		0.4
Randvaal Old Age Home	34.7	20.2	1.1	8.1	0.3	6.1		0.4	6.1		0.4

**Table 7-6: Predicted concentrations in  $\mu\text{g}/\text{m}^3$  and number of exceedance (NoE) at the sensitive receptors for Scenario A (2025) (NAAQS limit values in brackets)**

Receptor	SO <sub>2</sub>			NO <sub>2</sub>		PM <sub>10</sub> Total			PM <sub>2.5</sub> Total		
	1-hr (350)	24-hr (125)	Annual (50)	1-hour (200)	Annual (40)	24-hr (75)	NoE	Annual (40)	24-hr (40)	NoE	Annual (20)
Sharpeville - Monitoring Station	34.2	28.1	1.4	8.1	0.4	35.7		3.1	35.7		3.1
Sebokeng - Monitoring Station	24.0	20.8	1.0	5.2	0.3	8.0		0.5	8.0		0.5
Three Rivers - Monitoring Station	68.8	57.7	2.5	21.3	0.8	31.7		2.1	31.7		2.1
Zamdela - Monitoring Station	54.0	32.1	1.8	16.4	0.5	35.0		2.7	35.0		2.7
Rand Water - Monitoring Station	68.3	51.2	2.6	21.0	0.8	113.6	11	6.8	113.6	45	6.8
Vaal Power AH	125.9	51.9	4.0	43.9	1.3	62.0		7.3	62.0	22	7.3
Sasolburg Provincial Hospital	55.8	38.2	1.8	15.1	0.5	23.4		2.0	23.4		2.0
Moredou Old Age Home	50.9	34.3	1.6	13.4	0.5	23.3		1.9	23.3		1.9
Ons Gryse Jeug Old Age Home	55.4	37.4	1.7	14.0	0.5	26.3		2.1	26.3		2.1
Noord Primêre Skool	56.3	38.4	1.8	14.2	0.5	26.7		2.3	26.7		2.3
Sasolburg High School	51.7	35.1	1.6	13.5	0.5	21.4		1.8	21.4		1.8
Sakhubusa Secondary School	56.9	32.5	1.9	17.4	0.6	32.0		2.9	32.0		2.9
Bekezela Primary School	70.6	37.9	2.2	22.5	0.7	36.1		3.4	36.1		3.4
Isaac Mhlambi Primary	54.9	34.4	1.8	16.3	0.5	37.4		3.0	37.4		3.0
Refenkgotso Primary School	116.3	38.6	4.4	40.7	1.5	23.3		2.2	23.3		2.2
Deneysville Primary school	111.8	36.0	4.4	38.6	1.4	16.0		1.7	16.0		1.7
Netcare Vaalpark Hospital	48.0	37.7	1.8	12.6	0.5	32.6		3.0	32.6		3.0
Vaalpark Articon Secondary School	48.2	44.0	1.8	12.8	0.5	38.8		3.5	38.8		3.5
Mediclinic Emfuleni	32.7	28.4	1.3	8.2	0.4	22.9		2.1	22.9		2.1
Jeugland Old Age Home	31.1	29.3	1.3	7.2	0.4	28.7		2.2	28.7		2.2
Herfsoord Huis Old Age Home	31.6	26.6	1.3	8.2	0.4	19.3		1.8	19.3		1.8
Huis Prinscilla	28.5	22.1	1.2	7.0	0.3	24.2		1.8	24.2		1.8
Laerskool Emfulenipark	38.3	34.5	1.6	9.4	0.5	39.1		3.6	39.1		3.6
NW University - Vaal Campus	36.5	39.4	1.6	8.4	0.5	56.9		5.2	56.9	12	5.2
Emfuleni Primary School	27.6	22.7	1.1	7.2	0.3	14.8		1.3	14.8		1.3
Mediclinic Vereeniging	33.2	30.6	1.4	7.5	0.4	35.9		2.9	35.9		2.9
Kopanong Provincial Hospital	43.8	34.4	1.6	10.4	0.5	18.4		1.3	18.4		1.3
Avondrus Eventide Old Age Home	45.6	35.2	1.6	10.5	0.5	21.5		1.4	21.5		1.4

Receptor	SO <sub>2</sub>			NO <sub>2</sub>		PM <sub>10</sub> Total			PM <sub>2.5</sub> Total		
	1-hr (350)	24-hr (125)	Annual (50)	1-hour (200)	Annual (40)	24-hr (75)	NoE	Annual (40)	24-hr (40)	NoE	Annual (20)
Riviera On Vaal Resort	36.7	33.7	1.6	8.9	0.5	44.1		3.7	44.1	1	3.7
Sedibeng TVET college	33.4	32.6	1.4	6.9	0.4	48.0		4.3	48.0	1	4.3
General Smuts High School	31.2	33.6	1.3	7.2	0.4	39.6		3.2	39.6		3.2
Eureuka School & Selbourne Primary	31.3	33.9	1.3	7.2	0.4	35.3		2.9	35.3		2.9
Midvaal Private Hospital	53.8	40.8	2.0	14.4	0.6	44.2		3.0	44.2		3.0
Three Rivers Retirement Village	52.7	41.5	2.0	14.5	0.6	32.5		2.0	32.5		2.0
Drie Riviere Aftreeoord Old Age Home	52.1	39.9	2.0	15.5	0.6	28.2		1.7	28.2		1.7
Riverside High School	70.7	58.3	2.5	20.2	0.8	35.4		2.2	35.4		2.2
Risiville Primary School	58.2	39.4	2.1	16.3	0.6	26.8		1.8	26.8		1.8
Sebokeng Hospital	26.3	21.2	1.0	5.3	0.3	10.1		0.7	10.1		0.7
Clinix Naledzi Private Hospital	28.0	22.7	1.1	5.3	0.3	10.3		0.8	10.3		0.8
Mohloli Secondary School	34.8	31.6	1.4	8.6	0.4	42.2		3.5	42.2		3.5
Tshirela Primary School (Boipatong)	31.4	27.0	1.2	7.3	0.3	23.9		1.8	23.9		1.8
Tsoaranang Primary School (Thepiso)	33.1	36.3	1.4	7.1	0.4	32.8		2.4	32.8		2.4
Thepiso Primary School	30.6	31.2	1.3	6.1	0.4	21.5		1.6	21.5		1.6
Emmanuel Primary School	33.3	35.4	1.4	6.7	0.4	36.5		2.8	36.5		2.8
Rust Ter Vaal Combined School	39.1	25.2	1.3	9.1	0.4	11.2		0.7	11.2		0.7
Roshnee Primary School	35.8	24.2	1.2	8.5	0.3	9.6		0.6	9.6		0.6
Roshnee High School	37.4	25.2	1.2	8.6	0.3	10.6		0.6	10.6		0.6
Hoerskool DR Malan	53.2	33.1	1.6	13.0	0.5	10.4		0.7	10.4		0.7
Laerskool Voorwaarts	59.4	35.1	1.9	17.0	0.6	14.1		0.8	14.1		0.8
Meyerton Secondary School	59.1	32.0	1.7	13.7	0.5	12.9		0.8	12.9		0.8
Ratasetjhaba Primary School	43.9	24.7	1.3	9.9	0.4	8.3		0.6	8.3		0.6
Meyerton Primary School	50.2	30.6	1.6	12.0	0.4	9.8		0.6	9.8		0.6
Oprah Leadership Academy	49.9	28.2	1.6	13.2	0.4	8.5		0.5	8.5		0.5
Henley River Retirement Village	50.1	27.5	1.6	12.8	0.4	8.9		0.6	8.9		0.6
Henley High & Preparatory School	47.3	27.1	1.5	11.9	0.4	7.7		0.5	7.7		0.5
Randvaal Clinic	45.0	24.9	1.4	10.8	0.4	7.5		0.5	7.5		0.5
Laerskool Japie Greyling	39.8	22.9	1.2	9.6	0.3	6.4		0.4	6.4		0.4
Thomas Nhlapo Primary	42.8	24.3	1.4	10.9	0.4	7.1		0.4	7.1		0.4
Randvaal Old Age Home	38.6	21.6	1.2	8.5	0.3	5.8		0.4	5.8		0.4

**Table 7-7: Predicted concentrations in  $\mu\text{g}/\text{m}^3$  and number of exceedance (NoE) at the sensitive receptors for Scenario B (2031)(NAAQS limit values in brackets)**

Receptor	SO <sub>2</sub>			NO <sub>2</sub>		PM <sub>10</sub> Total			PM <sub>2.5</sub> Total		
	1-hr (350)	24-hr (125)	Annual (50)	1-hour (200)	Annual (40)	24-hr (75)	NoE	Annual (40)	24-hr (25)	NoE	Annual (15)
Sharpeville - Monitoring Station	24.8	18.2	1.0	7.0	0.3	34.1		3.0	34.1	13	3.0
Sebokeng - Monitoring Station	17.1	12.5	0.6	3.9	0.2	6.9		0.5	6.9		0.5
Three Rivers - Monitoring Station	60.4	36.7	1.9	19.1	0.6	30.1		1.9	30.1	1	1.9
Zamdela - Monitoring Station	44.3	22.9	1.3	14.3	0.4	33.4		2.6	33.4	7	2.6
Rand Water - Monitoring Station	64.4	43.4	2.1	22.9	0.7	112.0	11	6.7	112.0	79	6.7
Vaal Power AH	110.6	38.1	3.3	41.9	1.2	60.1		7.1	60.1	78	7.1
Sasolburg Provincial Hospital	44.1	24.2	1.3	14.0	0.4	21.8		1.9	21.8		1.9
Moredou Old Age Home	39.7	21.9	1.2	11.8	0.4	21.9		1.8	21.9		1.8
Ons Gryse Jeug Old Age Home	41.9	25.6	1.3	12.7	0.4	25.1		2.0	25.1	11	2.0
Noord Primêre Skool	42.5	25.0	1.3	13.0	0.4	25.4		2.2	25.4		2.2
Sasolburg High School	40.4	23.4	1.2	12.0	0.4	20.1		1.7	20.1		1.7
Sakhubusa Secondary School	45.9	21.4	1.4	14.4	0.5	30.5		2.8	30.5	7	2.8
Bekezela Primary School	55.2	23.8	1.6	18.1	0.5	34.6		3.3	34.6	8	3.3
Isaac Mhlambi Primary	44.6	21.7	1.4	14.2	0.4	36.0		2.9	36.0	14	2.9
Refenkgotso Primary School	78.1	27.1	3.2	29.3	1.1	21.6		2.0	21.6		2.0
Deneysville Primary school	74.7	23.9	3.1	28.0	1.1	14.4		1.5	14.4		1.5
Netcare Vaalpark Hospital	39.0	24.8	1.3	11.3	0.4	31.4		2.9	31.4	8	2.9
Vaalpark Articon Secondary School	39.1	29.1	1.4	12.6	0.4	37.6		3.5	37.6	19	3.5
Mediclinic Emfuleni	27.2	18.7	0.9	7.2	0.3	21.8		2.1	21.8		2.1
Jeugland Old Age Home	25.3	19.4	0.9	6.8	0.3	27.7		2.1	27.7		2.1
Herfsoord Huis Old Age Home	25.6	17.9	0.9	7.1	0.3	18.4		1.7	18.4		1.7
Huis Prinscilla	23.7	15.2	0.8	6.4	0.3	23.4		1.8	23.4		1.8
Laerskool Emfulenipark	30.5	25.8	1.1	8.4	0.4	38.2		3.5	38.2	20	3.5
NW University - Vaal Campus	33.9	32.0	1.3	9.5	0.4	55.5		5.2	55.5	54	5.2
Emfuleni Primary School	22.6	16.0	0.8	6.1	0.2	13.8		1.2	13.8		1.2
Mediclinic Vereeniging	27.8	23.2	1.1	7.1	0.3	34.4		2.8	34.4	7	2.8
Kopanong Provincial Hospital	33.6	25.1	1.2	9.2	0.4	17.2		1.2	17.2		1.2
Avondrus Eventide Old Age Home	35.0	25.6	1.2	9.3	0.4	20.0		1.3	20.0		1.3
Riviera On Vaal Resort	30.1	24.6	1.2	7.8	0.4	42.7		3.7	42.7	28	3.7
Sedibeng TVET college	26.8	23.2	1.1	7.2	0.3	46.5		4.2	46.5	33	4.2



Receptor	SO <sub>2</sub>			NO <sub>2</sub>		PM <sub>10</sub> Total			PM <sub>2.5</sub> Total		
	1-hr (350)	24-hr (125)	Annual (50)	1-hour (200)	Annual (40)	24-hr (75)	NoE	Annual (40)	24-hr (25)	NoE	Annual (15)
General Smuts High School	26.4	20.1	1.0	6.6	0.3	38.2		3.1	38.2	11	3.1
Eureuka School & Selbourne Primary	25.5	20.4	1.0	6.5	0.3	34.0		2.8	34.0	8	2.8
Midvaal Private Hospital	43.0	31.0	1.6	13.8	0.5	42.5		2.9	42.5	17	2.9
Three Rivers Retirement Village	46.0	31.1	1.6	13.9	0.5	31.2		2.0	31.2	2	2.0
Drie Riviere Aftreeoord Old Age Home	43.9	29.7	1.5	14.2	0.5	27.0		1.7	27.0		1.7
Riverside High School	57.2	36.7	1.9	18.7	0.6	34.0		2.1	34.0	6	2.1
Risiville Primary School	48.3	28.0	1.6	15.3	0.5	25.7		1.7	25.7		1.7
Sebokeng Hospital	18.7	13.7	0.7	4.0	0.2	8.9		0.6	8.9		0.6
Clinix Naledzi Private Hospital	19.3	15.5	0.7	4.1	0.2	9.4		0.7	9.4		0.7
Mohloli Secondary School	25.4	19.6	1.0	7.0	0.3	40.4		3.5	40.4	19	3.5
Tshirela Primary School (Boipatong)	22.3	16.9	0.8	5.5	0.2	23.1		1.7	23.1		1.7
Tsoaranang Primary School (Thepiso)	22.8	18.4	0.9	5.4	0.3	31.6		2.3	31.6	2	2.3
Thepiso Primary School	22.6	19.4	0.9	4.9	0.3	20.3		1.5	20.3		1.5
Emmanuel Primary School	22.5	18.8	0.9	5.5	0.3	35.1		2.7	35.1	10	2.7
Rust Ter Vaal Combined School	28.9	18.9	1.0	7.4	0.3	10.4		0.6	10.4		0.6
Roshnee Primary School	27.2	17.3	0.9	7.2	0.2	8.6		0.5	8.6		0.5
Roshnee High School	27.3	17.8	0.9	7.3	0.3	9.7		0.5	9.7		0.5
Hoerskool DR Malan	40.6	20.7	1.2	10.5	0.3	9.1		0.6	9.1		0.6
Laerskool Voorwaarts	44.0	23.1	1.4	13.0	0.4	12.2		0.8	12.2		0.8
Meyerton Secondary School	42.6	20.5	1.2	12.2	0.4	11.6		0.8	11.6		0.8
Ratasetjhaba Primary School	31.8	16.8	1.0	8.1	0.3	7.4		0.5	7.4		0.5
Meyerton Primary School	38.5	19.5	1.1	9.7	0.3	8.5		0.5	8.5		0.5
Oprah Leadership Academy	34.6	19.2	1.1	9.2	0.3	7.3		0.4	7.3		0.4
Henley River Retirement Village	35.6	18.4	1.1	9.7	0.3	7.4		0.5	7.4		0.5
Henley High & Preparatory School	32.6	17.9	1.0	8.2	0.3	6.5		0.4	6.5		0.4
Randvaal Clinic	32.2	16.4	1.0	7.9	0.3	6.3		0.4	6.3		0.4
Laerskool Japie Greyling	27.2	14.3	0.8	6.9	0.2	5.1		0.3	5.1		0.3
Thomas Nhlapo Primary	29.4	15.9	0.9	7.5	0.3	5.9		0.3	5.9		0.3
Randvaal Old Age Home	27.8	13.5	0.8	6.8	0.2	4.7		0.3	4.7		0.3

**Table 7-8: Predicted concentrations in  $\mu\text{g}/\text{m}^3$  and number of exceedance (NoE) at the sensitive receptors for Scenario C (2036) (NAAQS limit values in brackets)**

Receptor	SO <sub>2</sub>			NO <sub>2</sub>		PM <sub>10</sub> Total			PM <sub>2.5</sub> Total		
	1-hr (350)	24-hr (125)	Annual (50)	1-hour (200)	Annual (40)	24-hr (75)	NoE	Annual (40)	24-hr (25)	NoE	Annual (15)
Sharpeville - Monitoring Station	23.9	18.4	1.0	4.6	0.2	34.0		3.0	<b>34.0</b>	<b>13</b>	3.0
Sebokeng - Monitoring Station	16.6	12.5	0.6	2.8	0.1	6.9		0.5	6.9		0.5
Three Rivers - Monitoring Station	56.0	37.7	1.8	13.9	0.5	30.1		1.9	<b>30.1</b>	1	1.9
Zamdela - Monitoring Station	43.0	23.7	1.3	9.6	0.3	33.5		2.6	<b>33.5</b>	7	2.6
Rand Water - Monitoring Station	60.8	41.4	2.0	15.2	0.5	<b>112.0</b>	11	6.7	<b>112.0</b>	<b>79</b>	6.7
Vaal Power AH	104.7	38.5	3.3	29.7	0.9	60.1		7.1	<b>60.1</b>	<b>78</b>	7.1
Sasolburg Provincial Hospital	41.6	24.6	1.3	9.4	0.3	21.7		1.9	21.7		1.9
Moredou Old Age Home	39.6	21.6	1.2	8.3	0.3	22.0		1.8	22.0		1.8
Ons Gryse Jeug Old Age Home	41.6	25.6	1.3	9.0	0.3	25.1		2.0	<b>25.1</b>		2.0
Noord Primêre Skool	42.1	25.8	1.3	9.1	0.3	25.4		2.2	<b>25.4</b>		2.2
Sasolburg High School	38.2	23.4	1.2	8.2	0.3	19.9		1.7	19.9		1.7
Sakhubusa Secondary School	45.3	21.8	1.4	10.3	0.3	30.6		2.8	<b>30.6</b>	7	2.8
Bekezela Primary School	53.4	24.9	1.6	13.3	0.4	34.5		3.3	<b>34.5</b>	8	3.3
Isaac Mhlambi Primary	43.4	25.3	1.3	9.9	0.3	36.1		2.9	<b>36.1</b>	<b>14</b>	2.9
Refenkgotso Primary School	78.8	26.7	3.2	21.6	0.8	21.6		2.0	21.6		2.0
Deneysville Primary school	75.2	24.9	3.1	20.6	0.8	14.4		1.5	14.4		1.5
Netcare Vaalpark Hospital	37.0	25.2	1.3	7.8	0.3	31.2		2.9	<b>31.2</b>	8	2.9
Vaalpark Articon Secondary School	39.5	27.2	1.3	9.1	0.3	37.5		3.5	<b>37.5</b>	<b>19</b>	3.5
Mediclinic Emfuleni	24.0	18.0	0.9	4.6	0.2	21.8		2.1	21.8		2.1
Jeugland Old Age Home	23.1	20.6	0.9	4.3	0.2	27.7		2.1	<b>27.7</b>	1	2.1
Herfsoord Huis Old Age Home	23.0	17.6	0.9	4.5	0.2	18.3		1.7	18.3		1.7
Huis Prinscilla	21.9	15.0	0.8	4.2	0.2	23.3		1.8	23.3		1.8
Laerskool Emfulenipark	29.0	25.8	1.1	5.8	0.3	38.2		3.5	<b>38.2</b>	<b>20</b>	3.5
NW University - Vaal Campus	31.2	33.4	1.2	6.0	0.3	55.5		5.2	<b>55.5</b>	<b>54</b>	5.2
Emfuleni Primary School	20.8	14.5	0.8	4.3	0.2	13.8		1.2	13.8		1.2
Mediclinic Vereeniging	26.5	22.2	1.0	4.7	0.2	34.4		2.8	<b>34.4</b>	7	2.8
Kopanong Provincial Hospital	33.2	25.1	1.2	6.5	0.3	17.2		1.2	17.2		1.2
Avondrus Eventide Old Age Home	33.5	25.5	1.2	6.5	0.3	20.0		1.3	20.0		1.3
Riviera On Vaal Resort	30.4	23.8	1.2	5.5	0.3	42.8		3.7	<b>42.8</b>	<b>28</b>	3.7
Sedibeng TVET college	26.6	21.7	1.1	5.1	0.2	46.5		4.2	<b>46.5</b>	<b>33</b>	4.2

Receptor	SO <sub>2</sub>			NO <sub>2</sub>		PM <sub>10</sub> Total			PM <sub>2.5</sub> Total		
	1-hr (350)	24-hr (125)	Annual (50)	1-hour (200)	Annual (40)	24-hr (75)	NoE	Annual (40)	24-hr (25)	NoE	Annual (15)
General Smuts High School	24.7	20.8	1.0	4.3	0.2	38.2		3.1	38.2	11	3.1
Eureuka School & Selbourne Primary	24.0	20.1	1.0	4.3	0.2	34.1		2.8	34.1	8	2.8
Midvaal Private Hospital	42.3	33.8	1.6	9.1	0.4	42.5		2.9	42.5	17	2.9
Three Rivers Retirement Village	43.4	31.4	1.6	9.9	0.4	31.2		2.0	31.2	2	2.0
Drie Riviere Aftreeoord Old Age Home	43.3	29.3	1.5	9.8	0.4	27.0		1.7	27.0		1.7
Riverside High School	55.4	37.3	1.8	13.5	0.4	34.1		2.1	34.1	6	2.1
Risiville Primary School	46.3	28.0	1.5	10.7	0.4	25.8		1.7	25.8		1.7
Sebokeng Hospital	17.4	14.1	0.7	2.8	0.1	8.9		0.6	8.9		0.6
Clinix Naledzi Private Hospital	18.6	16.0	0.7	2.6	0.1	9.3		0.7	9.3		0.7
Mohloli Secondary School	25.7	20.2	1.0	4.7	0.2	40.5		3.5	40.5	19	3.5
Tshirela Primary School (Boipatong)	21.5	17.5	0.8	3.8	0.2	23.0		1.7	23.0		1.7
Tsoaranang Primary School (Thepiso)	22.7	19.2	0.9	3.7	0.2	31.5		2.3	31.5	3	2.3
Thepiso Primary School	21.8	19.5	0.9	3.5	0.2	20.3		1.5	20.3		1.5
Emmanuel Primary School	22.4	19.0	0.9	3.7	0.2	35.2		2.7	35.2	10	2.7
Rust Ter Vaal Combined School	28.6	19.0	1.0	5.2	0.2	10.3		0.6	10.3		0.6
Roshnee Primary School	26.6	18.0	0.9	4.9	0.2	8.6		0.5	8.6		0.5
Roshnee High School	26.7	18.9	0.9	5.0	0.2	9.6		0.5	9.6		0.5
Hoerskool DR Malan	39.7	21.9	1.2	7.5	0.3	9.1		0.6	9.1		0.6
Laerskool Voorwaarts	44.5	23.4	1.4	9.2	0.3	12.2		0.8	12.2		0.8
Meyerton Secondary School	42.9	22.4	1.2	8.7	0.3	11.7		0.7	11.7		0.7
Ratasetjhaba Primary School	32.4	17.8	1.0	5.8	0.2	7.5		0.5	7.5		0.5
Meyerton Primary School	38.1	20.4	1.1	6.8	0.2	8.5		0.5	8.5		0.5
Oprah Leadership Academy	35.1	20.1	1.1	6.6	0.2	7.3		0.4	7.3		0.4
Henley River Retirement Village	36.0	19.2	1.1	6.7	0.2	7.4		0.5	7.4		0.5
Henley High & Preparatory School	32.9	18.6	1.0	6.0	0.2	6.6		0.4	6.6		0.4
Randvaal Clinic	32.6	17.0	1.0	5.5	0.2	6.3		0.4	6.3		0.4
Laerskool Japie Greyling	28.0	14.8	0.9	5.0	0.2	5.1		0.3	5.1		0.3
Thomas Nhlapo Primary	29.6	16.7	0.9	5.4	0.2	6.0		0.3	6.0		0.3
Randvaal Old Age Home	27.6	14.8	0.8	4.9	0.2	4.8		0.3	4.8		0.3

**Table 7-9: Predicted concentrations in  $\mu\text{g}/\text{m}^3$  and number of exceedance (NoE) at the sensitive receptors for Scenario D (MES) (NAAQS limit values in brackets)**

Receptor	SO <sub>2</sub>			NO <sub>2</sub>		PM <sub>10</sub> Total			PM <sub>2.5</sub> Total		
	1-hr (350)	24-hr (125)	Annual (50)	1-hour (200)	Annual (40)	24-hr (75)	NoE	Annual (40)	24-hr (25)	NoE	Annual (15)
Sharpeville - Monitoring Station	7.2	5.5	0.3	4.6	0.2	33.1		2.9	<b>33.1</b>	<b>13</b>	2.9
Sebokeng - Monitoring Station	5.0	3.8	0.2	2.8	0.1	6.2		0.4	6.2		0.4
Three Rivers - Monitoring Station	16.8	11.3	0.6	13.9	0.5	28.4		1.9	<b>28.4</b>	1	1.9
Zamdela - Monitoring Station	12.9	7.1	0.4	9.6	0.3	32.1		2.6	<b>32.1</b>	7	2.6
Rand Water - Monitoring Station	18.2	12.4	0.6	15.2	0.5	<b>110.3</b>	11	6.7	<b>110.3</b>	<b>79</b>	6.7
Vaal Power AH	31.4	11.6	1.0	29.7	0.9	58.5		7.0	<b>58.5</b>	<b>78</b>	7.0
Sasolburg Provincial Hospital	12.5	7.4	0.4	9.4	0.3	20.2		1.9	20.2		1.9
Moredou Old Age Home	11.9	6.5	0.4	8.3	0.3	20.5		1.8	20.5		1.8
Ons Gryse Jeug Old Age Home	12.5	7.7	0.4	9.0	0.3	23.4		2.0	23.4		2.0
Noord Primêre Skool	12.6	7.8	0.4	9.1	0.3	23.8		2.1	23.8		2.1
Sasolburg High School	11.5	7.0	0.4	8.2	0.3	18.4		1.6	18.4		1.6
Sakhubusa Secondary School	13.6	6.5	0.4	10.3	0.3	29.3		2.7	<b>29.3</b>	7	2.7
Bekezela Primary School	16.0	7.5	0.5	13.3	0.4	33.2		3.2	<b>33.2</b>	8	3.2
Isaac Mhlambi Primary	13.0	7.6	0.4	9.9	0.3	34.7		2.9	<b>34.7</b>	<b>14</b>	2.9
Refenkgotso Primary School	23.6	8.0	1.0	21.6	0.8	20.0		1.9	20.0		1.9
Deneysville Primary school	22.6	7.5	0.9	20.6	0.8	12.9		1.4	12.9		1.4
Netcare Vaalpark Hospital	11.1	7.6	0.4	7.8	0.3	29.9		2.8	<b>29.9</b>	8	2.8
Vaalpark Articon Secondary School	11.9	8.2	0.4	9.1	0.3	36.2		3.4	<b>36.2</b>	<b>19</b>	3.4
Mediclinic Emfuleni	7.2	5.4	0.3	4.6	0.2	20.8		2.0	20.8		2.0
Jeugland Old Age Home	6.9	6.2	0.3	4.3	0.2	26.7		2.1	<b>26.7</b>		2.1
Herfsoord Huis Old Age Home	6.9	5.3	0.3	4.5	0.2	17.5		1.7	17.5		1.7
Huis Prinscilla	6.6	4.5	0.2	4.2	0.2	22.5		1.7	22.5		1.7
Laerskool Emfulenipark	8.7	7.7	0.3	5.8	0.3	37.0		3.4	<b>37.0</b>	<b>20</b>	3.4
NW University - Vaal Campus	9.3	10.0	0.4	6.0	0.3	54.3		5.1	<b>54.3</b>	<b>54</b>	5.1
Emfuleni Primary School	6.2	4.4	0.2	4.3	0.2	13.0		1.2	13.0		1.2
Mediclinic Vereeniging	8.0	6.7	0.3	4.7	0.2	33.2		2.7	<b>33.2</b>	7	2.7
Kopanong Provincial Hospital	10.0	7.5	0.4	6.5	0.3	16.0		1.1	16.0		1.1
Avondrus Eventide Old Age Home	10.1	7.6	0.4	6.5	0.3	18.7		1.3	18.7		1.3
Riviera On Vaal Resort	9.1	7.2	0.3	5.5	0.3	41.4		3.6	<b>41.4</b>	<b>28</b>	3.6
Sedibeng TVET college	8.0	6.5	0.3	5.1	0.2	45.2		4.2	<b>45.2</b>	<b>33</b>	4.2

Receptor	SO <sub>2</sub>			NO <sub>2</sub>		PM <sub>10</sub> Total			PM <sub>2.5</sub> Total		
	1-hr (350)	24-hr (125)	Annual (50)	1-hour (200)	Annual (40)	24-hr (75)	NoE	Annual (40)	24-hr (25)	NoE	Annual (15)
General Smuts High School	7.4	6.2	0.3	4.3	0.2	37.2		3.0	37.2	11	3.0
Eureuka School & Selbourne Primary	7.2	6.0	0.3	4.3	0.2	33.0		2.7	33.0	8	2.7
Midvaal Private Hospital	12.7	10.1	0.5	9.1	0.4	40.9		2.9	40.9	17	2.9
Three Rivers Retirement Village	13.0	9.4	0.5	9.9	0.4	29.7		1.9	29.7	2	1.9
Drie Riviere Aftreeoord Old Age Home	13.0	8.8	0.5	9.8	0.4	25.5		1.6	25.5		1.6
Riverside High School	16.6	11.2	0.6	13.5	0.4	32.2		2.0	32.2	6	2.0
Risiville Primary School	13.9	8.4	0.5	10.7	0.4	24.2		1.6	24.2		1.6
Sebokeng Hospital	5.2	4.2	0.2	2.8	0.1	8.1		0.6	8.1		0.6
Clinix Naledzi Private Hospital	5.6	4.8	0.2	2.6	0.1	8.5		0.7	8.5		0.7
Mohloli Secondary School	7.8	6.1	0.3	4.7	0.2	39.5		3.4	39.5	19	3.4
Tshirela Primary School (Boipatong)	6.4	5.3	0.2	3.8	0.2	22.1		1.7	22.1		1.7
Tsoaranang Primary School (Thepiso)	6.8	5.8	0.3	3.7	0.2	30.6		2.3	30.6	3	2.3
Thepiso Primary School	6.5	5.9	0.3	3.5	0.2	19.3		1.5	19.3		1.5
Emmanuel Primary School	6.7	5.7	0.3	3.7	0.2	34.1		2.6	34.1	10	2.6
Rust Ter Vaal Combined School	8.6	5.7	0.3	5.2	0.2	9.0		0.5	9.0		0.5
Roshnee Primary School	8.0	5.4	0.3	4.9	0.2	7.4		0.4	7.4		0.4
Roshnee High School	8.0	5.7	0.3	5.0	0.2	8.4		0.5	8.4		0.5
Hoerskool DR Malan	11.9	6.6	0.4	7.5	0.3	7.7		0.5	7.7		0.5
Laerskool Voorwaarts	13.3	7.0	0.4	9.2	0.3	10.8		0.7	10.8		0.7
Meyerton Secondary School	12.9	6.7	0.4	8.7	0.3	10.2		0.7	10.2		0.7
Ratasetjhaba Primary School	9.7	5.3	0.3	5.8	0.2	6.3		0.4	6.3		0.4
Meyerton Primary School	11.4	6.1	0.3	6.8	0.2	7.2		0.5	7.2		0.5
Oprah Leadership Academy	10.5	6.0	0.3	6.6	0.2	5.9		0.4	5.9		0.4
Henley River Retirement Village	10.8	5.8	0.3	6.7	0.2	6.0		0.4	6.0		0.4
Henley High & Preparatory School	9.9	5.6	0.3	6.0	0.2	5.2		0.3	5.2		0.3
Randvaal Clinic	9.8	5.1	0.3	5.5	0.2	5.0		0.3	5.0		0.3
Laerskool Japie Greyling	8.4	4.4	0.3	5.0	0.2	4.0		0.3	4.0		0.3
Thomas Nhlapo Primary	8.9	5.0	0.3	5.4	0.2	4.7		0.3	4.7		0.3
Randvaal Old Age Home	8.3	4.4	0.2	4.9	0.2	3.7		0.3	3.7		0.3

## **7.2.4 Isopleth maps**

Isopleth maps of predicted ambient SO<sub>2</sub>, NO<sub>2</sub>, PM<sub>10</sub> and PM<sub>2.5</sub> concentrations are presented in the following sections. The predicted concentrations are shown as isopleths, lines of equal concentration, in µg/m<sup>3</sup> for the respective NAAQS averaging periods. The isopleths are depicted as coloured lines on the various maps, corresponding to a particular predicted ambient concentration. Areas within red isopleths indicate an area where exceedances of the respective NAAQS limit value are predicted to occur.

The South African NAAQS permits 4 exceedances of the 24-hour or daily limit value per annum, implying 12 permitted exceedances in a three-year modelling period. For the 24-hour or daily isopleth maps, areas within burgundy isopleths indicate areas where more than 12 exceedances of the limit value are predicted over a 3-year period. The predicted 24-hour concentrations in these areas do not comply with the NAAQS.

The South African NAAQS also permits 88 exceedances of the 1-hour or hourly limit value per annum, implying 264 permitted exceedances in a three-year modelling period. For the 1-hour or hourly isopleth maps, areas within burgundy isopleths indicate areas where more than 264 exceedances of the limit value are predicted over a 3-year period. The predicted 1-hour concentrations in these areas do not comply with the NAAQS.

On the isopleth maps, the green squares indicate the sensitive receptors and the white squares are the AQMS.

### **7.2.3.1 Sulphur dioxide (SO<sub>2</sub>)**


The isopleth maps showing the predicted annual average SO<sub>2</sub> concentrations clearly demonstrate the effect of the predominant northerly winds, with dispersion generally to the south and southeast of the power plant. In all scenarios the maximum predicted annual average concentrations occurs within 10 km of the power station and to the south-southeast.

There is little increase in the emissions from Scenario 1 (Current) to Scenario A (2025). However, there is an increase in the predicted ambient concentrations and an increase in the affected area for all averaging periods. The increase is attributed to reduced exit velocities due to reduced loads in Scenario A (2025). Low stack exit velocities restrict plume height and dispersion.

Notable is the decrease from Scenario A (2025) to Scenarios B (2031) and in Scenario C (2036), then a further decrease in the affected area for Scenario D (MES) associated with the decrease in emissions.


For all five scenarios and all averaging times the predicted ambient SO<sub>2</sub> concentrations are well below the respective NAAQS.






**Figure 7-2: Predicted annual average SO<sub>2</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario 1 (Current)(NAAQS limit 50 ug/m<sup>3</sup>)**






**Figure 7-3: Predicted 99<sup>th</sup> percentile 24-hour SO<sub>2</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario 1 (Current) (NAAQS limit 125 µg/m<sup>3</sup>)**






**Figure 7-4: Predicted 99<sup>th</sup> percentile 1-hour SO<sub>2</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario 1 (Current) (NAAQS limit 350 ug/m<sup>3</sup>)**






**Figure 7-5: Predicted annual average SO<sub>2</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario A (2025) (NAAQS limit 50 µg/m<sup>3</sup>)**






**Figure 7-6: Predicted 99<sup>th</sup> percentile 24-hour SO<sub>2</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario A (2025) (NAAQS limit 125 ug/m<sup>3</sup>)**






**Figure 7-7: Predicted 99<sup>th</sup> percentile 1-hour SO<sub>2</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario A (2025) (NAAQS limit 300 µg/m<sup>3</sup>)**






**Figure 7-8: Predicted annual average  $\text{SO}_2$  concentrations in  $\mu\text{g}/\text{m}^3$  resulting from emissions from Lethabo: Scenario B (2031) (NAAQS limit  $50 \mu\text{g}/\text{m}^3$ )**






**Figure 7-9: Predicted 99<sup>th</sup> percentile 24-hour SO<sub>2</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario B (2031) (NAAQS limit 125 ug/m<sup>3</sup>)**






**Figure 7-10: Predicted 99<sup>th</sup> percentile 1-hour SO<sub>2</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario B (2031) (NAAQS limit 350 µg/m<sup>3</sup>)**






**Figure 7-11: Predicted annual average SO<sub>2</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario C (2036) (NAAQS limit 50 ug/m<sup>3</sup>)**






**Figure 7-12: Predicted 99<sup>th</sup> percentile 24-hour SO<sub>2</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario C (2036) (NAAQS limit 125 µg/m<sup>3</sup>)**






**Figure 7-13: Predicted 99<sup>th</sup> percentile 1-hour SO<sub>2</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario C (2036) (NAAQS limit 350 µg/m<sup>3</sup>)**






**Figure 7-14: Predicted annual average SO<sub>2</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario D (MES) (NAAQS limit 50 µg/m<sup>3</sup>)**





**Figure 7-15: Predicted 99<sup>th</sup> percentile 24-hour SO<sub>2</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario D (MES) (NAAQS limit 125 ug/m<sup>3</sup>)**





**Figure 7-16: Predicted 99<sup>th</sup> percentile 1-hour SO<sub>2</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario D (MES) (NAAQS limit 350 µg/m<sup>3</sup>)**

### **7.2.3.2 Nitrogen dioxide (NO<sub>2</sub>)**

The isopleth maps showing the predicted annual average NO<sub>2</sub> concentrations also demonstrate the effect of the predominant northerly winds on dispersion which is generally to the south and southeast of the power plant. In all scenarios the maximum predicted annual average concentrations occurs within approximately 10 km of the power station and to the south-southeast.


Similarly, the maximum predicted 1-hour NO<sub>2</sub> concentrations also occur south east of Lethabo.

There is little increase in the emissions from Scenario 1 (Current) to Scenario A (2025). However, there is an increase in the predicted ambient concentrations and an increase in the affected area for all averaging periods. The increase is attributed to reduced exit velocities due to reduced loads in Scenario A (2025). Low stack exit velocities restrict plume height and dispersion.

Notable is the decrease from Scenario A (2025) to Scenarios B (2031) and in Scenario C (2036), then a further decrease in the affected area for Scenario D (MES) associated with the decrease in emissions.


For all five scenarios and all averaging times the predicted ambient NO<sub>2</sub> concentrations are well below the respective NAAQS.






**Figure 7-17: Predicted annual average NO<sub>2</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario 1 (Current) (NAQAS limit 40 µg/m<sup>3</sup>)**






**Figure 7-18: Predicted 99<sup>th</sup> percentile 1-hour NO<sub>2</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario 1 (Current) (NAAQS limit 200 µg/m<sup>3</sup>)**






**Figure 7-19: Predicted annual average NO<sub>2</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario A (2025) (NAAQS limit 40 µg/m<sup>3</sup>)**






**Figure 7-20: Predicted 99<sup>th</sup> percentile 1-hour NO<sub>2</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario A (2025) (NAAQS limit 200 µg/m<sup>3</sup>)**






**Figure 7-21: Predicted annual average NO<sub>2</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario B (2031) (NAAQS limit 40 µg/m<sup>3</sup>)**






**Figure 7-22: Predicted 99<sup>th</sup> percentile 1-hour NO<sub>2</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario B (2031) (NAAQS limit 200 µg/m<sup>3</sup>)**






**Figure 7-23: Predicted annual average NO<sub>2</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario C (2036) (NAAQS limit 40 ug/m<sup>3</sup>)**






**Figure 7-24: Predicted 99<sup>th</sup> percentile 1-hour NO<sub>2</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario C (2036) (NAAQS limit 200 µg/m<sup>3</sup>)**





**Figure 7-25: Predicted annual average NO<sub>2</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario D (MES) (NAAQS limit 40 ug/m<sup>3</sup>)**





**Figure 7-26: Predicted 99<sup>th</sup> percentile 1-hour NO<sub>2</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario D (MES) (NAAQS limit 200 µg/m<sup>3</sup>)**


### **7.2.3.3      Particulates (PM<sub>10</sub>)**

The isopleth plots for PM<sub>10</sub> are similar for all of the scenarios, particularly close to the power plant, due to the significant contribution of the low-level fugitive sources to the ambient concentrations, particularly the ash dump.

The area where the predicted annual average concentrations exceed the NAAQS of 40 µg/m<sup>3</sup> extends approximately 3 km from the ash dump.


The area where the predicted 24-hour concentrations exceed the limit value of 75 µg/m<sup>3</sup> extends up 10 km to the south and southeast, and somewhat less in other directions from the ash dump. The NAAQS for PM<sub>10</sub> is exceeded where 13 or more exceedances are predicted (the shaded burgundy area in the figures below). This area is smaller than the area where the limit value is exceeded. It must be remembered that the predictions are conservative given the assumption that TPM = PM<sub>10</sub> = PM<sub>2.5</sub>. Remembering too that the fugitive emissions have the greatest effect on ambient concentrations close to the source, while the effect of the stack emissions is generally further from the power station.






**Figure 7-27: Predicted annual average PM<sub>10</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario 1 (Current) (NAAQS limit 40 ug/m<sup>3</sup>)**






**Figure 7-28: Predicted 99<sup>th</sup> percentile of the 24-hour PM<sub>10</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario 1 (Current) (NAAQS limit 75 µg/m<sup>3</sup>)**






**Figure 7-29: Predicted annual average PM<sub>10</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario A (2025) (NAAQS limit 40 ug/m<sup>3</sup>)**






**Figure 7-30: Predicted 99<sup>th</sup> percentile of the 24-hour PM<sub>10</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario A (2025) (NAAQS limit 75 µg/m<sup>3</sup>)**






**Figure 7-31: Predicted annual average PM<sub>10</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario B (2031) (NAAQS limit 40 ug/m<sup>3</sup>)**






**Figure 7-32: Predicted 99<sup>th</sup> percentile of the 24-hour PM<sub>10</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario B (2031) (NAAQS limit 75 µg/m<sup>3</sup>)**






**Figure 7-33: Predicted annual average PM<sub>10</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario C (2036) (NAAQS limit 40 ug/m<sup>3</sup>)**






**Figure 7-34: Predicted 99<sup>th</sup> percentile of the 24-hour PM<sub>10</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario C (2036) (NAAQS limit 75 µg/m<sup>3</sup>)**





**Figure 7-35: Predicted annual average PM<sub>10</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario D (MES) (NAAQS limit 40 µg/m<sup>3</sup>)**





**Figure 7-36: Predicted 99<sup>th</sup> percentile of the 24-hour PM<sub>10</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario D (MES) (NAAQS limit 75 µg/m<sup>3</sup>)**

#### **7.2.3.4      Particulates (PM<sub>2.5</sub>)**

The isopleth plots for PM<sub>2.5</sub> as similar for all of the scenarios, particularly close to the power plant, due to the significant contribution of the low-level fugitive sources to the ambient concentrations, particularly the ash dump.


The area where the predicted annual average concentrations exceed the NAAQS of 20 µg/m<sup>3</sup> extends with a radius of approximately 5 km around the ash dump.

There area where the predicted 24-hour concentrations exceed the limit value of 40 µg/m<sup>3</sup> in Scenario 1 (Current) and scenario A (2025) extend up 15 km to the south and southeast, and somewhat less in other directions from the ash dump.

The NAAQS for PM<sub>10</sub> is exceeded where 13 or more exceedances are predicted (the sharded area in the figures below). This area is smaller than the area where the limit value is exceeded. These areas of exceedance of the limit value and the NAAQS increase in Scenario B (2031), Scenario C (2036) and Scenario D (MES) when the 2023 limit value of 25 is in effect. It must be remembered that the predictions are conservative given the assumption that TPM = PM<sub>10</sub> = PM<sub>2.5</sub>. Because of this assumption the predicted PM<sub>2.5</sub> is actually PM<sub>10</sub> being compared against the more stringent NAAQS for PM<sub>2.5</sub>.


Remembering too that the fugitive emission have the greatest effect on ambient concentrations close to the source, while the effect of the stack emissions is generally further from the power station.






**Figure 7-37: Predicted annual average PM<sub>2.5</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario 1 (Current) (NAAQS limit 20 ug/m<sup>3</sup>)**






**Figure 7-38: Predicted 99<sup>th</sup> percentile of the 24-hour PM<sub>2.5</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario 1 (Current) (NAAQS limit 40 µg/m<sup>3</sup>)**






**Figure 7-39: Predicted annual average PM<sub>2.5</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario A (2025) (NAAQS limit 20 ug/m<sup>3</sup>)**






**Figure 7-40: Predicted 99<sup>th</sup> percentile of the 24-hour PM<sub>2.5</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario A (2025) (NAAQS limit 40 µg/m<sup>3</sup>)**






**Figure 7-41: Predicted annual average PM<sub>2.5</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario B (2031) (NAAQS limit 15 ug/m<sup>3</sup>)**






**Figure 7-42: Predicted 99<sup>th</sup> percentile of the 24-hour PM<sub>2.5</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario B (2031) (NAAQS limit 25 ug/m<sup>3</sup>)**






**Figure 7-43: Predicted annual average PM<sub>2.5</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario C (2036) (NAAQS limit 15 ug/m<sup>3</sup>)**






**Figure 7-44: Predicted 99<sup>th</sup> percentile of the 24-hour PM<sub>2.5</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario C (2036) (NAAQS limit 25 ug/m<sup>3</sup>)**





**Figure 7-45: Predicted annual average PM<sub>2.5</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario D (MES) (NAAQS limit 15 µg/m<sup>3</sup>)**





**Figure 7-46: Predicted 99<sup>th</sup> percentile of the 24-hour PM<sub>2.5</sub> concentrations in µg/m<sup>3</sup> resulting from emissions from Lethabo: Scenario D (MES) (NAAQS limit 25 ug/m<sup>3</sup>)**



### **7.3 Analysis of Emissions' Impact on the Environment**

This AIR has focused on comparing modelled concentrations of SO<sub>2</sub>, NO<sub>2</sub>, PM<sub>10</sub> and PM<sub>2.5</sub> with the respective health-based NAAQS. An assessment of the atmospheric impact of the facility on the environment was therefore not undertaken as part of this AIR.

## **8. COMPLAINTS**

Lethabo maintains a complaints register. One (1) air quality related complaint was received during the 3-year assessment period, 2021 to 2023. This was in November 2022 relating to dust from the ash dump.

Whilst outside the study period during 2024 Lethabo received a number of air quality complaints. The higher than usual particulate matter emission levels are associated with the breakdown of poor performing emission abatement equipment which is already scheduled for upgrading. The station is implementing additional measures to reduce its impacts while completion of the required projects is awaited.

## **9. CURRENT OR PLANNED AIR QUALITY MANAGEMENT INTERVENTIONS**

Decommissioning of Lethabo is planned from 2037 to 2042. In the meantime, particulate emissions are controlled by operating and maintaining Electrostatic Precipitators on Units 1 to 5, and SO<sub>3</sub> Injection Plants on Units 2, 3 and 5. The installation of Low NO<sub>x</sub> burners are planned from 2027.

In respect of SO<sub>2</sub>, Eskom is considering multiple factors including costs and benefits and does not intend to install SO<sub>2</sub> reduction technology but will rather reduce its emission impact by improving operational efficiencies.

## **10. COMPLIANCE AND ENFORCEMENT ACTIONS**

A pre-compliance notice was received in 2020/21 relating to air quality, waste and environmental authorisations. This was addressed and closed by Eskom.

## **11. SUMMARY AND CONCLUSION**

In this AIR five emission scenarios are assessed for Lethabo to support Eskom's application for exemption from the MES using dispersion modelling to simulate the resultant ambient concentrations. These are:

Scenario 1 (Current): The baseline scenario using actual monthly stack emissions for 2021-2023 and fugitive emissions from the ash dump.

Scenario A (2025): Eskom's planned 2025 stack emissions, representing anticipated station performance between 2025 – 2030, including fugitive emissions from the ash dump.

- Scenario B (2031): Eskom's planned 2031 stack emissions, representing anticipated station performance between 2031 – 2035, including fugitive emissions from the ash dump.
- Scenario C (2036): Eskom's planned 2036 stack emissions, representing anticipated station performance from 2036 onwards, including fugitive emissions from the ash dump.
- Scenario D (MES): Full compliance with the MES, representing the unattainable scenario.

Noteworthy findings from the modelling results may be summarised as follows:

- i) For NO<sub>x</sub> actual emissions and Eskom's proposed emissions in 2025, 2031 and 2036, there is general compliance with the NAAQS.
- ii) For SO<sub>2</sub> actual emissions and Eskom's proposed emissions in 2025, 2031 and 2036, there is general compliance with the NAAQS.
- iii) For PM<sub>10</sub> and PM<sub>2.5</sub> exceedances of the NAAQS are predicted up to 15 km from Lethabo, mainly as a result of the low-level fugitive sources from the ash dump. Beyond this there is general compliance with the NAAQS.
- iv) There is a notable difference between Eskom's proposed 2036 emissions and full compliance with the MES for SO<sub>2</sub>, with the MES scenario being lower. Despite this, the predicted concentrations comply with the NAAQS throughout the modelling domain.
- v) There is no discernible difference between the effects of Eskom's proposed emission in 2036 and full compliance with the MES for NO<sub>x</sub> and PM.

The AIR for Eskom's MES exemption application for Lethabo (uMoya-NILU, 2018) considered stack emissions only, i.e. fugitive sources were excluded. This AIR therefore provides insights into the contribution of stack emission to ground-level concentrations. In that AIR, the actual PM emissions of 4 718 tonnes/annum from each of the two stacks was simulated. The maximum predicted ambient PM<sub>10</sub> concentration was 0.3 µg/m<sup>3</sup>, approximately 6 km southeast of Lethabo. The 99<sup>th</sup> percentile of the 24-hour predicted PM<sub>10</sub> concentrations was 4.3 µg/m<sup>3</sup> and occurred approximately 4 km to the east of Lethabo.

In this AIR, the PM emission for Scenario 1 (Current) are 22% higher than the 2018 AIR, i.e. 5 740 tonnes/annum for each stack. By comparison, the predicted annual PM<sub>10</sub> concentrations 6 km southeast of Lethabo are between 5 and 10 µg/m<sup>3</sup>. The predicted 24-hour PM<sub>10</sub> concentrations 4 km east of Lethabo are between 50 and 75 µg/m<sup>3</sup>. The difference in predicted ambient PM<sub>10</sub> concentrations between the 2018 AIR and the current AIR may partly be attributed to the higher stack emission, but also emphasizes the contribution of the low-level fugitive sources.

Given the conservative approach to the fugitive emission source simulations, and that this has provided an absolute worst-case emission scenario, and based on recommendations received from uMoya-Nilu, Eskom will be undertaking an additional modelling scenario, assessing only PM, SO<sub>2</sub>, and NO<sub>x</sub> stack emissions. NO<sub>x</sub> and SO<sub>2</sub> emissions will be included in this scenario to ensure secondary particulate formation is accounted for. This will provide improved insight to impacts directly related to stack emissions, which are the focus of this exemption application.

## 12. REFERENCES

- Auer, A.H. (1978): Correlation of Land Use and Cover with Meteorological Anomalies, *Journal of Applied Meteorology*, 17:636-643.
- CARB (2024): <https://ww2.arb.ca.gov/capp-resource-center/community-assessment/sensitive-receptor-assessment>.
- CSIRO (2008): TAPM V4. User Manual. Prepared by Peter Hurley, CSIRO Marine and Atmospheric Research Internal Report No. 5, October 2008, ISBN: 978-1-921424-73-1.
- DEA (2009): National Ambient Air Quality Standards, Government Gazette, 32861, Vol. 1210, 24 December 2009.
- DEA (2010): Listed Activities and Associated Minimum Emission Standards identified in terms of Section 21 of the National Environmental Management: Air Quality Act, 2004 (Act No. 39 of 2004), Government Gazette 33064, Notice No. 248 of 31 March 2010.
- DEA (2012): National Ambient Air Quality Standard for Particulate Matter of Aerodynamic Diameter less than 2.5 micrometers, Notice 486, 29 June 2012, Government Gazette, 35463.
- DEA (2013a): Regulations Prescribing the Format of the Atmospheric Impact Report, Government Gazette 36904, Notice No. 747 of 11 October 2013.
- DEA (2013b): Listed Activities and Associated Minimum Emission Standards identified in terms of Section 21 of the National Environmental Management: Air Quality Act, 2004 (Act No. 39 of 2004), Government Gazette 37054, Notice No. 893 of 22 November 2013.
- DEA (2014a): Code of Practice for Air Dispersion Modelling in Air Quality Management in South Africa, Government Notice R.533, Government Gazette, no. 37804, 11 July 2014.
- DEA (2014b): Environmental Assessment Regulations, 2014 identified in terms of the National Environmental Management: Air Quality Act, 2004 (Act No. 39 of 2004), Government Gazette 38282, Notice No. R 982 of 4 December 2014.
- DEA (2019): Listed Activities and Associated Minimum Emission Standards identified in terms of Section 21 of the National Environmental Management: Air Quality Act, 2004 (Act No. 39 of 2004), Government Gazette 42472, Notice No. 893 of 22 May 2019.
- DEA (2020): Listed Activities and Associated Minimum Emission Standards identified in terms of Section 21 of the National Environmental Management: Air Quality Act, 2004 (Act No. 39 of 2004), Government Gazette 43174, Notice No. 421 of 27 March 2020.
- Fezile Dabi District Municipality (2015): AEL for Lethabo Power Station, FDDM-MET-2011-08-P1.
- Hurley, P. (2000): Verification of TAPM meteorological predictions in the Melbourne region for a winter and summer month. *Australian Meteorological Magazine*, 49, 97-107.
- Hurley, P.J., Blockley, A. and Rayner, K. (2001): Verification of a prognostic meteorological and air pollution model for year-long predictions in the Kwinana industrial region of Western Australia. *Atmospheric Environment*, 35(10), 1871-1880.
- Hurley, P.J., Physick, W.L. and Ashok, K.L. (2002): The Air Pollution Model (TAPM) Version 2, Part 21: summary of some verification studies, CSIRO Atmospheric Research Technical Paper No. 57, 46 p.
- Nkangala District Municipality (2017): AEL for Lethabo Power Station, AEL No.: 17/04/AEL/MP312/11/07.

- SANAS (2012): Tr 07-03 Supplementary Requirements for the Accreditation of Continuous Ambient Air Quality Monitoring Stations (pp. 112).
- uMoya-NILU (2018): Dispersion modelling report as input to the Atmospheric Impact Report in support of Eskom's application for exemption from the minimum emission standards and/or extension of the minimum emission standards compliance timeframes for the Lethabo Power Station, Report No. uMN122-18, August 2018
- USEPA (1995): A user's guide for the CALPUFF dispersion model (version 5). Prepared by Scire, J., Strimaitis, D. and Yamartino, Robert.
- USEPA (2005): Revision to the Guideline on Air Quality Models: Adoption of a Preferred General Purpose (Flat and Complex Terrain) Dispersion Model and Other Revisions, 40 CFR Part 51, US Environmental Protection Agency 40 CFR Part 51.
- USEPA (2024a): <https://www.epa.gov/newenglandhc/environmental-issues-concern-urban-communities-resources>.
- USEPA (2024b): Compilation of Air Pollutant Emission Factors, AP-42, Fifth Edition, Volume I: Stationary Point and Area Sources. Chapter 13: Miscellaneous Sources. <http://www.epa.gov/ttn/chief/ap42/ch13/index.html>.



### **13. FORMAL DECLARATIONS**

A declaration of the accuracy of the information contained in this Atmospheric Impact Report is included here. A declaration of the independence of the practitioners in the uMoya-NILU consultancy team that compiled this AIR is also included.

---

## DECLARATION OF ACCURACY OF INFORMATION – APPLICANT

---

**Name of Enterprise: uMoya-NILU Consulting (Pty) Ltd**

Declaration of accuracy of information provided:

### **Atmospheric Impact Report in terms of Section 30 of the Act**

I, Mark Zunckel [duly authorised], declare that the information provided in this atmospheric impact report is, to the best of my knowledge, in all respects factually true and correct. I am aware that the supply of false or misleading information to an air quality office is a criminal offence in terms of section 51(1)(g) of this Act.

Signed at Durban on this 14<sup>th</sup> day of October 2024.



---

**SIGNATURE**

Managing Director – uMoya-NILU Consulting

**CAPACITY OF SIGNATORY**

---

## DECLARATION OF INDEPENDENCE – PRACTITIONER

---

**Name of Practitioner: Mark Zunckel**

**Name of Registered Body: South African Council for Natural Scientific Professionals**

**Professional Registration Number: 400449/04**

Declaration of independence and accuracy of information provided:

### **Atmospheric Impact Report in terms of Section 30 of the Act**

I, Mark Zunckel declare that I am independent of the applicant. I have the necessary expertise to conduct the assessment required for the report and will perform the work relating to the application in an objective manner, even if this results in views and findings that are not favourable to the applicant. I will disclose to the applicant and the air quality officer all material information in my possession that reasonably has or may have the potential of influencing any decision to be taken with respect to the application by the air quality officer. The information provided in the atmospheric impact report is, to the best of my knowledge, in all respects factually true and correct. I am aware that the supply of false or misleading information to an air quality office is a criminal offence in terms of section 51(1)(g) of this Act.

Signed at Durban on this 14<sup>th</sup> of October 2024.



**SIGNATURE**

Managing Director – uMoya-NILU Consulting

**CAPACITY OF SIGNATORY**

## **ANNEXURE 1: NEMA REGULATION – APPENDIX 6**

Specialist Reports as per the NEMA EIA Regulations, 2014 (as amended), must contain the information outlined according to Appendix 6 (1) of the Regulations. Table A1 indicates where this information is included in the AIR.



**Table A1: Prescribed contents of the Specialist Reports (Appendix 6 of the EIA Regulations, 2014)**

Relevant section in GNR. 982	Requirement description	Relevant section in this report
(a) details of—	(i) the specialist who prepared the report; and	Section 2.6
	(ii) the expertise of that specialist to compile a specialist report including a curriculum vitae;	Section 2.6 & Annexure 2
(b)	a declaration that the specialist is independent in a form as may be specified by the competent authority;	Section 13
(c)	an indication of the scope of, and the purpose for which, the report was prepared;	Section 1 & 2.7
(cA)	an indication of the quality and age of base data used for the specialist report;	Section 5, 6, 7
(cB)	a description of existing impacts on the site, cumulative impacts of the proposed development and levels of acceptable change;	Section 6.1
(d)	the duration, date and season of the site investigation and the relevance of the season to the outcome of the assessment;	Site investigation not applicable
(e)	a description of the methodology adopted in preparing the report or carrying out the specialised process inclusive of equipment and modelling used;	Section 5 & 7
(f)	details of an assessment of the specific identified sensitivity of the site related to the proposed activity or activities and its associated structures and infrastructure, inclusive of a site plan identifying site alternatives;	Section 2.2 & 2.3
(g)	an identification of any areas to be avoided, including buffers;	None identified
(h)	a map superimposing the activity including the associated structures and infrastructure on the environmental sensitivities of the site including areas to be avoided, including buffers;	Section 7.2
(i)	<p>a description of any assumptions made and any uncertainties or gaps in knowledge;</p> <p>Note: Uncertainties should be qualified within the report – there will always be uncertainties due to gaps in knowledge should also be qualified – a gap is to record that not all knowledge can be obtained for a study.</p>	Section 2.8 & 7.1.3
(j)	a description of the findings and potential implications of such findings on the impact of the proposed activity or activities;	Section 7
(k)	any mitigation measures for inclusion in the EMPr;	Section 7

Relevant section in GNR. 982	Requirement description	Relevant section in this report
	Note: We need to include whether these mitigation measures (excluding ongoing monitoring) can be practically implemented prior to commencement or not.	
(l)	any conditions for inclusion in the environmental authorisation;	
(m)	any monitoring requirements for inclusion in the EMPr or environmental authorisation;	
(n) a reasoned opinion—	(i) whether the proposed activity, activities or portions thereof should be authorised;	Section 11
	(iA) regarding the acceptability of the proposed activity or activities; and	Section 11
	(ii) if the opinion is that the proposed activity, activities or portions thereof should be authorised, any avoidance, management and mitigation measures that should be included in the EMPr, and where applicable, the closure plan;  Note: We need to include whether these mitigation measures (excluding ongoing monitoring) can be practically implemented prior to commencement or not.	Section 11
(o)	a description of any consultation process that was undertaken during the course of preparing the specialist report;	Section 1
(p)	a summary and copies of any comments received during any consultation process and where applicable all responses thereto; and	
(q)	any other information requested by the competent authority.	
(2)	Where a government notice gazetted by the Minister provides for any protocol or minimum information requirement to be applied to a specialist report, the requirements as indicated in such notice will apply.	Section 1 & 3

## **ANNEXURE 2: CURRICULUM VITAE**




---

Firm	: uMoya-NILU (Pty) Ltd
Profession	: Air quality consultant
Specialization	: Air quality assessment, air quality management planning, air dispersion modelling, boundary layer meteorology, project management
Position in Firm	: Managing director and senior consultant
Years with Firm	: Since 1 August 2007
Nationality	: South African
Year of Birth	: 1959
Language Proficiency	: English and Afrikaans

---

## **EDUCATION AND PROFESSIONAL STATUS**

Qualification	Institution	Year
National Diploma (Meteorology)	Technikon Pretoria	1980
BSc (Meteorology)	Univ. of Pretoria	1984
BSc Hons (Meteorology)	Univ. of Pretoria	1988
MSc	Univ. of Natal	1992
PhD	Univ. Witwatersrand	1999

Registered Natural Scientist: South African Society for Natural Scientific Professionals  
 Ex-Council Member: National Association for Clean Air  
 Member: National Association for Clean Air

## **EMPLOYMENT AND EXPERIENCE RECORD**

<b>Period</b>	<b>Organisation details and responsibilities/roles</b>
1976 – May 1992	<i>South African Weather Bureau</i> : Observer, junior forecaster, senior forecast, researcher, assistant director
June 1992 – July 2007	<i>CSIR</i> : Consultant and researcher, Research group Leader: Atmospheric Impacts
August 2007 to present	<i>uMoya-NILU Consulting</i> : Managing Director and senior air quality consultant

## **Key and Recent Project Experience:**

---

1996	Project leader & Principal researcher: Atmospheric impact assessment for the proposed Mozal aluminium smelter in Maputo, Mozambique.
------	--



1996	Project leader & Principal researcher: Dry sulphur deposition during the Ben MacDhui High Altitude Trace Gas and Transport Experiment (BATTEX) in the Eastern Cape.
1997	Project leader & Principal researcher: Atmospheric impact assessment of the proposed capacity expansion project for Alusaf in Richards Bay.
1997	Project leader & Principal researcher: The Uruguayan ambient air quality project with LATU.
1997	Principal researcher on the Air quality specialist study for the Strategic Environmental Assessment on the industrial and urban hinterland of Richards Bay.
1997	Project leader & Principal researcher: Feasibility study for the implementation of a fog detection system in the Cape Metropolitan area: Meteorological aspects.
2001	Project leader & Principal researcher: Air quality specialist study for the Environmental Impact Assessment for the proposed expansion of the Hillside Aluminium Smelter, Richards Bay.
2001-03	Researcher: The Cross Border air Pollution Impact (CAPIA) project. A 3-year modelling and impacts study in the SADC region.
2002	Project leader & Principal researcher: Air quality assessment specialist study for the proposed Pechiney Smelter at Coega.
2002	Project leader & Principal researcher: Air quality assessment specialist study for the proposed N2 Wild Coast Toll Road.
2002-05	Project leader on the NRF project – development of a dynamic air pollution prediction system
2004	Project leader on the specialist study for expansion at the Natal Portland Cement plant at Simuma, KwaZulu-Natal.
2004-05	Researcher: National Air Quality Management Plan implementation project for Department Environmental Affairs and Tourism.
2005	Researcher in the assessment of air quality impacts associated with the expansion of the Natal Portland Cement plant at Port Shepstone.
2006-07	Project team leader of a multi-national team to develop the National Framework for Air Quality Management for the Department of Environment Affairs and Tourism
2007	Air quality assessment for Mutla Early Production System in Uganda for ERM Southern Africa on behalf of Tullow Oil.
2007-10	Lead consultant on the development of a dust mitigation strategy for the Bulk Terminal Saldanha and an ambient guideline for Fe <sub>2</sub> O <sub>3</sub> dust for Transnet Projects and on-going monitoring.
2008	Lead consultant on the Air quality status quo assessment and scoping for the EIA for the Sonangol Refinery
2008-09	Lead consultant on the development of the air quality management plan for the Western Cape Provincial. Department of Environmental Affairs and Development Planning.
2008-10	Lead consultant on the development of the Highveld Priority Area air quality management plan for the Department of Environmental Affairs and Tourism.
2008	Lead consultant in the development of an odour management and implementation strategy for eThekweni, focussing on Wastewater Treatment Works and odorous industrial sources
2008&10	Lead consultant on the Air Quality Specialist Study for the EIA for the proposed Kalagadi Manganese Smelter at Coega

2008	Lead consultant on the Air Quality Assessment for the Proposed Construction and Operation of a Second Cement Mill at NPC-Cimpor, Simuma near Port Shepstone.
2008	Lead consultant on the Air Quality Specialist Study Report for the New Multi-Purpose Pipeline Project (NMPP) for Transnet Pipelines.
2008	Lead consultant on the Air quality assessment for the proposed UTE Power Plant and RMDZ coal mine at Moatize, Mozambique for Vale.
2008-09	Lead consultant on the Dust source apportionment study for the Coedmore region in Durban for NPC-Cimpor.
2009	Consultant on the Air quality specialist study for the upgrade of the Kwadukuza Landfill, KwaZulu-Natal
2009-10	Lead consultant on the Audit of ambient air quality monitoring programme and air quality training for air quality personnel at PetroSA
2010	Lead consultant on the Qualitative assessment of impact of dust on solar power station at Saldanha Bay
2010	Lead consultant on the Air quality specialist study for the EIA for the Kalagadi Manganese Smelter at Coega
2009-10	Lead consultant on the Air quality specialist study for the Environmental Management Framework for the Port of Richards Bay
2010	Lead consultant on the Air quality status quo assessment and abatement planning at Idwala Carbonates, Port Shepstone
2010	Lead consultant on the Air quality status quo assessment and abatement planning at Sappi Tugela, Mandeni
2010-11	Air quality status quo assessment and revision of the Air Quality Management Plan for City of Johannesburg
2010	Lead consultant on the Air quality status quo assessment and abatement planning at First Quantum Mining's Bwana Mkubwa and Kansanshi mines, Zambia
2010-11	Lead consultant on the Air quality specialist study for the EIA for the Alternative Fuel and Resources Project at Simuma, Port Shepstone
2010-11	Lead consultant on the Air quality specialist study for the EIA for the Coke Oven re-commissioning at ArcelorMittal Newcastle
2010	Qualitative air quality assessment for the EIA for the Mozpel sugar to ethanol project , Mozambique
2011	Development of the South African Air Quality Information System – Phase II The National Emission Inventory
2011	Ambient baseline monitoring for Riversdale's Zambezi Coal Project in Tete, Mozambique
2010-11	Ambient quality baseline assessment for the Ncondeze Coal Project, Tete Mozambique
2011-12	Air quality assessment for the mining and processing facilities at Longmin Platinum in Marikana
2012	Air quality assessment for the proposed LNG and OLNG plants in Mozambique
2012	Modelling study in Abu Dhabi for the transport and deposition of radio nuclides
2012	Air quality assessment for the proposed manganese ore terminal at the Ngqura Port
2012-13	Air quality management plan development for Stellenbosch Municipality
2012-12	Air quality management plan development for the Eastern Cape Province
2013	Air quality specialist for Tullow Oil Waraga-D and Kinsinsi environmental audit in Uganda

2013	Air quality specialist study for the EIA for the Thabametsi IPP station
2013	Air quality management plan for the Ugu District Municipality
2013-14	Air quality specialist study for the application for postponement of the minimum emission standards for 9 Eskom power stations
2014	Air quality specialist study for the application for postponement applications of the minimum emission standards for the Engen Refinery in Merebank, Durban
2014-15	Baseline assessment and AQMP development for the uThungulu District Municipality
2013-15	Baseline assessment, AQMP and Threat Assessment for the Waterberg-Bojanala Priority Area
2014-15	Review of the 2007 AQMP for eThekweni Municipality, including metropolitan emission inventory development for all sectors, i.e. industrial, transport, waste management, biomass burning, residential fuel burning, dispersion modelling and strategy development
2014-14	Dispersion modelling study for Richards Bay Minerals
2015	Air quality assessment for Rainbow Chickens at Hammersdale
2015	Air quality status quo assessment and planning for TNPA ports in South Africa
2016- 7	Lead author of the National State of Air Report for 2005 to 2015, including national emission inventory development for all sectors, i.e. industrial, transport, waste management, biomass burning, residential fuel burning
2016	Air quality assessment for Kanshansi Mine, Solwesi, Zambia
2016	Assessment of air quality impacts associated with activities at the Venetia Mine, Limpopo Province
2016	Assessment of air quality impacts associated with activities at the Komati Anthracite Mine, Mpumalanga Province
2016	Air quality assessment for the proposed Powership Project at the Port of Nacala, Mozambique
2016	Air quality assessment for the proposed Richards Bay Gas to Power Project
2017	Baseline assessment and review of the 2009 AQMP for Gauteng Province, including emission inventory development for all sectors, i.e. industrial, transport, waste management, biomass burning, residential fuel burning, and dispersion modelling
2017	Baseline assessment and air quality management plan for Northern Cape Province
2017	Air quality assessment for the EIA for the Thabametsi Power Station in Limpopo Province
2017	Air quality assessment for the EIA for the proposed Tshivasho Power Station in Limpopo Province
2018	Air quality assessment for the EIA for the proposed Bellmall Thermal Plant in Ekurhuleni
2018	Air quality assessment for the EIA for the proposed Simba Oil mini Refinery in Tororo, Uganda
2018-19	Air dispersion modelling for input to the Atmospheric Reports for the postponement application for 14 Eskom power stations
2019	Air quality impact assessment for the proposed NamPower expansion project in Walvis Bay
2019	Air quality assessment for the mine expansion project at the Akanani Mine
2019	Air quality impact assessment for the proposed power plant at Nacala, Mozambique

2020	AIR for the KarpowershipSA proposal in the Ports of Ngqura, Richards Bay and Saldanha Bay
2020	AIR for the Coega Development Corporation gas-to-power project at 4 sites in the CDC
2020	AIRs for 10 Eskom coal-fired power plants on the Highveld to support their postponement application
2020	AIR for the proposed Azure Power gas-to-power project in the Western Cape
2021	Air quality assessment for the proposed optimisation project at Beeshoek Iron Ore Mine, Postmasburg, Northern Cape
2021	AIR for the proposed Frontier Power Gas-to-Power project at Saldanha Bay, Western Cape
2021	AIR for the 2021 shutdown and start-up at Engen Refinery in Merebank
2021	AIR for the proposed expansion of the Swartkops Ore handling facility in Port Elizabeth, Eastern Cape
2016-21	AEL compliance monitoring for Joseph Grieveson, Durban, including dust fallout monitoring and reporting
2018-21	Dust fallout and HF monitoring and reporting for Hulamin, Richards Bay
2018-21	Dust fallout and H <sub>2</sub> S monitoring and reporting for at KwaDukuza Landfill for Dolphin Coast Landfill Management (DCLM)
2019-21	AEL compliance monitoring for Umgeni Iron and Steel Foundry, including dust fallout monitoring and reporting

## **PUBLICATIONS**

Author and co-author of 34 articles in scientific journals, chapters in books and conference proceedings. Author and co-author of more than 300 technical reports and presented 47 papers at local and international conferences.





---

Firm	: uMoya-NILU Consulting (Pty) Ltd
Profession	: Air Quality Consultant
Specialization	: Meteorological and Atmospheric Dispersion Modelling, Air Quality Specialist Studies, Project Management, Data Processing, Emission Inventories
Position in Firm	: Senior Air Quality Consultant
Years with Firm	: 14 years (appointed in 2008)
Nationality	: South African
Year of Birth	: 1977
Language Proficiency	: English (mother tongue), Afrikaans (fair)

---

## **EDUCATION AND PROFESSIONAL STATUS**

<b>Qualification</b>	<b>Institution</b>	<b>Year</b>
M.A. (Atmospheric Sciences)	University of Natal, Durban	2003
B.A. Hons. (Environmental Sciences)	University of Durban–Westville	2001
B.Paed. (Education)	University of Durban–Westville	2000

### **Memberships:**

- National Association for Clean Air (NACA)
- South African Society for Atmospheric Sciences (SASAS)
- South African Council of Educators (SACE)

## **EMPLOYMENT AND EXPERIENCE RECORD**

Period	Organisation details and responsibilities/roles
Jan 2003 – Oct 2008	CSIR: Consultant/Researcher in Air Quality Group, Research Group Leader – Air Quality Research Group
Nov 2008 – present	uMoya-NILU: Senior Air Quality Consultant

### **Key and Recent Project Experience:**

2003	Baseline air dispersion modelling study for Natal Portland Cement (Pty) Ltd – Simuma Plant, Port Shepstone – <i>Modelling and Reporting</i>
2004	Air Quality Screening Study for MOZAL 3 – <i>Modelling and Reporting</i>
2005	Air Quality Specialist Study for the Proposed Kudu Combined Cycle Gas Turbine Power Station at Oranjemund, Namibia (Site D) – <i>Modelling and Reporting</i>

- 2005 Air Quality Specialist Study for the Proposed Kudu Combined Cycle Gas Turbine Power Plant at Uubvlei, Namibia – *Modelling and Reporting*
- 2005 Air Quality Specialist Study for a Proposed Cement Milling, Storage and Packaging Facility and a Second Clinker Kiln at Natal Portland Cement (Pty) Ltd – Simuma Plant, Port Shepstone – *Modelling and Reporting*
- 2005 Technology Review: Air quality specialist study for the Coega Aluminium Smelter at Coega, Port Elizabeth – *Modelling and Reporting*
- 2005 Assessment of Development Scenarios for Hillside Aluminium using Sulphur Dioxide (SO<sub>2</sub>) as an Ambient Air Quality Indicator – *Modelling and Reporting*
- 2005 Air Quality Scoping Study for Eskom's Proposed Open Cycle Gas Turbine Power Station at Atlantis – *Modelling and Reporting*
- 2005 Air Quality Specialist Study for Eskom's Proposed Open Cycle Gas Turbine Power Station at Atlantis, Western Cape – *Modelling and Reporting*
- 2005 Air Quality Specialist Study for the Proposed Tata Steel Ferrochrome Project at Richards Bay – Alton North Site – *Modelling and Reporting*
- 2005 Air Quality Audit for the Amathole District Municipality - *Compilation of detailed emissions inventory*
- 2006 A Regional Scale Air Dispersion Modelling Study for Northeastern Uruguay – *Modelling and Reporting*
- 2006 Air Dispersion Modelling Study for Natal Portland Cement (Pty) Ltd for the Proposed AFR Programme at the Simuma Plant, Port Shepstone – *Modelling and Reporting*
- 2007 Development of an air quality management strategy for particulate matter at the Bulk Terminal Saldanha - *Project Leader and Reporting*
- 2007 Air Quality and Human Health Specialist Study for the Proposed Coega Integrated LNG to Power Project (CIP) within the Coega Industrial Zone, Port Elizabeth, South Africa - *Project Leader, Modelling and Reporting*
- 2008 Dispersion Modelling for the Proposed Coega Aluminium Smelter (CAL) at Port Elizabeth - *Project Leader, Modelling and Reporting*
- 2008 Modelled and Measured Vertical Ozone Profiles over Southern Africa (as part of the Young Researcher Establishment Fund (2005-2008)) - *Project Leader*
- 2008 Air Quality Specialist Study for the Proposed N2 Wild Coast Toll Highway - *Project Leader, Modelling and Reporting*
- 2008 Initial Air Quality Impact Assessment for the Proposed Illovo Ethanol Plant in Mali, West Africa - *Project Leader, Modelling and Reporting*
- 2008 Modelling Mercury Stack Emissions from South African Coal-fired Power Plants – *Modelling and Reporting*
- 2009 Air Quality Management Plan for the Western Cape Province – Baseline Assessment – *Modelling*
- 2009 Proposed Exxaro AlloyStream™ Manganese Project in the Coega Industrial Development Zone: Air Quality Impact Assessment – *Modelling and Reporting*
- 2009 Air Quality Specialist Study for the Kalagadi Manganese Smelter at Coega, Eastern Cape – *Modelling and Reporting*
- 2009 Qualitative Air Quality Impact Assessment for the Wearne Platkop Quarry – *Modelling and Reporting*
- 2009 Specialist Air Quality Study for the Vopak Terminal Durban Efficiency Project – *Modelling*
- 2009 Qualitative Air Quality Impact Assessment for the Proposed ETA STAR Coal Mine at Moatize, Mozambique – *Modelling and Reporting*

2009	Specialist Air Quality Study for the Kwadukuza Landfill Upgrade Project – <i>Modelling and Reporting</i>
2010	Ambient dust assessment at Saldanha Bay for the period October 2006 to September 2009 for Transnet Bulk Terminal Saldanha – <i>Reporting</i>
2010	Dust Impact Assessment for the Proposed Saldanha Bay Pilot PV plant – <i>Reporting</i>
2010	Modelling Particulate Emission Concentration Scenarios for Eskom’s Kriel Power Station – <i>Modelling and Reporting</i>
2010	Air Quality Dispersion Modelling for MOZAL, Mozambique – <i>Modelling and Reporting</i>
2010	Air Quality Management Plan for the Highveld Priority Area – Air Quality Baseline Assessment for the Highveld Priority Area – <i>Modelling</i>
2010	Ambient Air Quality Modelling and Monitoring at Sappi, Mandeni – <i>Modelling and Reporting</i>
2010	Dust Impact Study at Idwala Carbonates – <i>Modelling and Reporting</i>
2010	Air quality specialist study for the EIA for the proposed re-commissioning of an existing coke oven battery at ArcelorMittal South Africa, Newcastle Works – <i>Modelling</i>
2010	Air quality specialist study for the proposed storage and utilisation of alternative fuels and resources at NPC-Cimpor’s Simuma facility, Port Shepstone, KwaZulu-Natal – <i>Modelling and Reporting</i>
2010	Air quality status quo assessment and abatement planning at First Quantum Mining’s Bwana Mkubwa and Kansanshi mines, Zambia – <i>Modelling</i>
2010	Air quality specialist study for the proposed briquetting plant at the Mafube Colliery – <i>Modelling and Reporting</i>
2011	Air quality modelling study for the Copeland reactor at Sappi Stanger – <i>Modelling and Reporting</i>
2011	Air quality modelling study for the Copeland reactor at Sappi Tugela – <i>Modelling and Reporting</i>
2011	Air quality monitoring and modelling study for the Copeland reactor at Mpact Paper, Piet Retief – <i>Modelling and Reporting</i>
2011	Air Quality Study for the Basic Environmental Assessment for the Proposed Biomass Co-Firing Facility at the Arnot Power Station – <i>Modelling and Reporting</i>
2011	Assessment of Scenarios for Developing and Implementing a Sulphur Dioxide Emissions Licensing Strategy for Hillside Aluminum – <i>Modelling and Reporting</i>
2011-12	Air quality assessment for the mining and processing facilities at Lonmin Platinum in Marikana – <i>Modelling and Reporting</i>
2012	Development of an Air Quality Management Plan for Anglo’s Mafube Colliery in Mpumalanga – <i>Modelling and Reporting</i>
2012	Air quality assessment for the proposed manganese ore terminal at the Ngqura Port – <i>Modelling and Reporting</i>
2012	Air Quality Impact Assessment for NPC Cimpor – <i>Modelling and Reporting</i>
2013	Air Quality Impact Assessment for Proposed AfriSam Plant in Coega – <i>Modelling</i>
2013	Air quality assessment for the Orion Engineered Carbons Co-Gen Plant – <i>Modelling</i>

2013	Air quality assessment for the Orion Engineered Carbons - Main Boiler – <i>Modelling</i>
2013	Air quality assessment for the EIA for the Sekoko Coal Mine – <i>Modelling and Reporting</i>
2013	Air quality specialist study for the EIA for the Thabametsi IPP station – <i>Modelling and Reporting</i>
2013	Air quality specialist study for the EIA for the Mamathwane Common User facility – <i>Modelling and Reporting</i>
2013-14	Air quality specialist study for the application for postponement of the minimum emission standards for 16 Eskom power stations: Acacia, Arnot, Camden, Lethabo, Grootvlei, Hendrina, Kendal, Komati, Kriel, Lethabo, Majuba, Lethabo, Matla, Madupi, Tutuka, Port Rex – <i>Modelling and Reporting</i>
2014	Air quality specialist study for the application for postponement of the minimum emission standards for the Engen Refinery in Merebank, Durban – <i>Modelling and Reporting</i>
2013-14	Baseline assessment and air quality management plan for the Waterberg-Bojanala Priority Area – <i>Modelling</i>
2013	Air Quality Specialist Study for the EIA for the Pandora Platinum Mine Joint Venture – <i>Modelling and Reporting</i>
2013	Air Quality Specialist Study for the EIA for the Proposed New Tailings Storage Facility (TD8) and Associated Infrastructure at Lonmin's Western Platinum Mine and Eastern Platinum Mine – <i>Modelling and Reporting</i>
2015	Waterberg-Bojanala Priority Area Air Quality Management Plan and Threat Assessment – <i>Modelling</i>
2015	Air Quality Management Plan for eThekweni Municipality – <i>Modelling and Reporting</i>
2015	Air Quality Management Plan for the uThungulu District Municipality – <i>Modelling and Reporting</i>
2015	Dispersion Modelling for Richards Bay Minerals – <i>Modelling and Reporting</i>
2015	Atmospheric Impact Report in support of Sancryl Chemicals's application for a verification to the existing AEL as a result of the introduction of Ethyl Acrylate and Vinyl Acetate, Prospecton – <i>Modelling and Reporting</i>
2016	Dispersion Modelling Study for the City of Johannesburg – <i>Modelling and Reporting</i>
2016	Air Quality Specialist Study for the Department of Energy's Emergency Power IPP Project at Richards Bay and Saldanha Bay – <i>Modelling and Reporting</i>
2016	Atmospheric Impact Report in support of the EIA for the Proposed Gas to Power Plant in Zone 1F of the Richards Bay IDZ – <i>Modelling and Reporting</i>
2016	Atmospheric Impact Report for the EIA for the proposed Tshivhaso Coal-fired Power Plant, Lephalale – <i>Modelling and Reporting</i>
2016	TNPA Air Quality Study – Dispersion Modelling for 8 Ports in South Africa: Port of Richards Bay, Durban, East London, Ngqura, Port Elizabeth, Mossel Bay, Cape Town and Saldanha Bay – <i>Modelling and Reporting</i>
2016	Atmospheric Impact Report for Durran's Calcination Plant – <i>Modelling and Reporting</i>
2016	Air Quality Assessment for the EIA for the Floating Power Plant in Nacala, Mozambique – <i>Modelling and Reporting</i>



2016	Ambient Air Quality Assessment for 2016 for Kansanshi Mining Plc – <i>Modelling and Reporting</i>
2016	Air Quality Impact Assessment for the EIA for the Proposed Hilli FLNG Project in Cameroon – <i>Modelling and Reporting</i>
2016	Kansanshi Smelter and TSF1 Modelling Scenarios for Kansanshi Mining Plc – <i>Modelling and Reporting</i>
2016	Air Quality Assessment the Proposed Accommodation Facility at the Venetia Mine in Limpopo – <i>Modelling and Reporting</i>
2016	Atmospheric Impact Report in support of the EIA for the Proposed Optimisation of the Process Plant at Nkomati Anthracite Mine – <i>Modelling and Reporting</i>
2017	Atmospheric Impact Report in support of the DRDAR Atmospheric Emission License (AEL) application for the proposed replacement and use of an incinerator at their State Veterinary Laboratories located in Grahamstown, Middelburg and Quesentown in the Eastern Cape – <i>Modelling and Reporting</i>
2017	Baseline Assessment and Review of the 2009 AQMP for Gauteng Province, including emission inventory development for all sectors, i.e. industrial, transport, waste management, biomass burning, residential fuel burning, and dispersion modelling – <i>Modelling and Reporting</i>
2017	Baseline Assessment and Air Quality Management Plan for Northern Cape Province – <i>Modelling and Reporting</i>
2017	Atmospheric Impact Report in support of Maloka Machaba Surfacing's application for an Atmospheric Emission License (AEL) for a proposed asphalt plant located in Polokwane – <i>Modelling and Reporting</i>
2017	Assessment of modelling scenarios involving an increase in the open area of the cone on the Common Stack for the pretreater, reformer and CHD furnaces at Engen Refinery – <i>Modelling and Reporting</i>
2017	Atmospheric Impact Report in support of the Atmospheric Emission License (AEL) application and stack-height assessment for the proposed Thabametsi Power Plant near Lephalale, Limpopo – <i>Modelling and Reporting</i>
2017	Dispersion Modelling Study for the Beeshoek Mine, near Postmasburg, Northern Cape – <i>Modelling and Reporting</i>
2018	Air quality assessment for the EIA for the proposed Bellmall Thermal Plant in Ekurhuleni – <i>Modelling and Reporting</i>
2018	Air quality assessment for the EIA for the proposed Simba Oil mini Refinery in Tororo, Uganda – <i>Modelling and Reporting</i>
2018-19	Air dispersion modelling for input to the Atmospheric Reports for the postponement application for 14 Eskom power stations – <i>Modelling and Reporting</i>
2019	Air quality impact assessment for the proposed NamPower expansion project in Walvis Bay – <i>Modelling and Reporting</i>
2019	Air quality assessment for the mine expansion project at the Akanani Mine – <i>Modelling and Reporting</i>
2019	Air quality impact assessment for the proposed power plant at Nacala, Mozambique – <i>Modelling and Reporting</i>
2019	Atmospheric Impact Report in Support of the Atmospheric Emission License (AEL) Amendment Application and Basic Assessment for Dow Southern Africa - New Germany – <i>Modelling and Reporting</i>

2019	Atmospheric Impact Report in support of Tau-Pele Construction's application for an Atmospheric Emission License (AEL) for a proposed emulsion and asphalt plant located in Indwe, Eastern Cape – <i>Modelling and Reporting</i>
2019	Atmospheric Impact Report in Support of the EIA for the Proposed Material Source and Processing Sites Along the N3 Between Durban and Hilton, KwaZulu-Natal: RCL1, RCL9 and Harrison's Quarry – <i>Modelling and Reporting</i>
2019	Atmospheric Impact Report in Support of the Atmospheric Emission License (AEL) Amendment Application and Basic Assessment for the Vopak Efficiency (Growth 4) Expansion Project, Durban, South Africa – <i>Modelling and Reporting</i>
2020	AIR for the KarpowershipSA proposal in the Ports of Ngqura, Richards Bay and Saldanha Bay – <i>Modelling and Reporting</i>
2020	AIR for the Coega Development Corporation gas-to-power project at 4 sites in the CDC – <i>Modelling and Reporting</i>
2020	AIRs for 10 Eskom coal-fired power plants on the Highveld to support their postponement application – <i>Modelling and Reporting</i>
2020	AIR for the proposed Azura Power gas-to-power project in the Western Cape – <i>Modelling and Reporting</i>
2020	Atmospheric Impact Report for the proposed 315 MW LPG Power Plant at Saldanha Bay – <i>Modelling and Reporting</i>
2021	Air quality assessment for the proposed optimisation project at Beeshoek Iron Ore Mine, Postmasburg, Northern Cape – <i>Modelling and Reporting</i>
2021	Air quality assessment for the proposed expansion at Akanani Mine in Limpopo – <i>Modelling and Reporting</i>
2021	AIR for the proposed Frontier Power Gas-to-Power project at Saldanha Bay, Western Cape
2021	AIR for the 2021 shutdown and start-up at Engen Refinery in Merebank – <i>Modelling and Reporting</i>
2021	AIR for the proposed expansion of the Swartkops Ore handling facility in Port Elizabeth, Eastern Cape – <i>Modelling and Reporting</i>
2021	Atmospheric Impact Report in support of the Proposed 200 MW Engie CB Hybrid Power Project in the Coega Special Economic Zone (SEZ) – <i>Modelling and Reporting</i>
2021	Air Quality Impact Assessment for the proposed Mining of TSF-1 at the Stibium Mopani Mine near Gravelotte, Limpopo Province – <i>Modelling and Reporting</i>
2021	Addendum to the Atmospheric Impact Report in support of the proposed Mulilo-Total 200 MW Gas-fired Power Station, Coega Special Development Zone, Eastern Cape – <i>Reporting</i>
2021	Air Quality Assessment for the EIA for the Tete 1 400 MW Coal-Fired Power Plant, Tete Province, Mozambique – <i>Modelling and Reporting</i>
2021	Atmospheric Impact Report in support of Tugela Asphalt's application for an Atmospheric Emission License (AEL) for a proposed asphalt plant located in Mandini, KwaZulu-Natal – <i>Modelling</i>
2021	Atmospheric Impact Report for Nkomati Mine – <i>Modelling and Reporting</i>
2022	Emission Inventory for Lanxess for 2021 – <i>Reporting</i>

2022	Annual Report for Puregas: Atmospheric Emission License - Submission to the City of Ekurhuleni in compliance with the Atmospheric Emission Licence of the facility for the Reporting Period Year 2021 – <i>Reporting</i>
2022	Emission Inventory for Puregas for 2021 – <i>Reporting</i>
2022	Emission Inventory for Dow Advanced Materials for 2020 – <i>Reporting</i>
2022	Atmospheric Impact Report for the Engen Cape Town Terminal – <i>Modelling and Reporting</i>

## **PUBLICATIONS**

Author and co-author of 5 articles in scientific journals and conference proceedings. Author and co-author of more than 200 technical reports for external contract clients. Presented 4 papers at local conferences. A full list of publications, conference papers and contract reports is available on request.



Firm : uMoya-NILU (Pty) Ltd  
 Profession : Senior Air Quality Consultant  
 Specialization : Air Quality Assessment, Air Dispersion Modelling; Project Management; Data Analysis; Report Writing and Reviews  
 Position in Firm : Senior Air Quality Consultant  
 Years with Firm : Since 27 March 2023  
 Nationality : South African  
 Year of Birth : 1985  
 Language Proficiency : English and IsiZulu (read, write. Speak)

### EDUCATION AND PROFESSIONAL STATUS

Qualification	Institution	Year
BSc. Environmental Studies	Univ. of Witwatersrand	2011
BSc Hons (Env. Studies)	Univ. of Witwatersrand	2012
BSc MSc (Env Sciences)	NWU Potchefstroom	2017

### EMPLOYMENT AND EXPERIENCE RECORD

Period	Organisation details and responsibilities/roles
Oct 2016 – Dec 2018	<i>Gondwana Environmental Solutions (Pty) Ltd</i> : Air Quality Management Plans; Report Writing; Business Development and Marketing, Researcher,
July 2019 – March 2023	<i>Rayten Engineering Solutions (Pty) Ltd</i> : Air Quality Consultant, Project Management; Report Writing and Review; Data Analysis; Dispersion Modelling and Air Quality Impact Assessment; Research; Compiling Atmospheric Emission License (AEL) Applications; Populating National Atmospheric Emissions Inventory System; AEL Compliance Auditing; Dust Emission Reduction Plans; Greenhouse Gas Emissions Inventory Reporting; Facilitating/ Attending meetings; Liaising with Clients and Suppliers.
March 2023 – Present:	<i>uMoya – Nilu Consulting (Pty) Ltd</i> Senior Air Quality Consultant, Dispersion Modelling and Air Quality Impact Assessments; Project Management

### Key Project Experience:

**2019 – 2023:** Project Leader: Air Quality Impact Assessment projects (Harmony Moab Khotson; EzeeTile Bloemfontein, EzeeTile Mokopane; Transvaal Galvanizers; Duho Drying; Lingaro Drying; Nama Copper Pty Ltd) Project Leader: AEL Applications and Reporting (Harmony Kopanang Operations; Harmony Mponeng Operations; Sibanye Gold Mines; Sibanye Platinum



Mines; TotalEnergies Marketing; Matt Cast Supplies CC; Independent Crematorium SA; City of Tshwane Crematorium; Buffalo City Municipality Crematorium; Wahl Industries; Transvaal Galvanizers)

**2014 – 2017:** Researcher: Air Quality Assessment in low-income residential areas in the Highveld

---

**Publications:** Author: Xulu, N.A., Piketh, S.J. Feig,G.T., Lack, D.A and Garland,R.M., (2020).Characterizing Light Absorbing Aerosols in a Low –Income Settlement in South Africa. Aerosol Air Quality Aerosol Air Quality Research. <https://doi.org/10.4209/aaqr.2019.09.004>

---

**CONTACT INFORMATION:**

**Email:** nopasika@umoya-nilu.co.za

**Phone:** +27 63 1289 447